

LAMPASAS, TX, USA

WMO: 720647

Lat: 31.106N

Lon: 98.196W

Elev: 370

StdP: 96.96

Time Zone: -6.00 (NAC)

Period: 09-19

WBAN: 00229

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -5.0	(c) -2.1	(d) -12.8	(e) 1.3	(f) 2.6	(g) -10.4	(h) 1.6	(i) 3.0	(j) 8.9	(k) 11.3	(l) 8.2	(m) 11.5	(n) 2.8	(o) 0	(p) 0.412

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 12.4	(c) 37.9	(d) 21.9	(e) 37.2	(f) 22.0	(g) 36.0	(h) 22.8	(i) 25.8	(j) 32.8	(k) 25.3	(l) 32.3	(m) 24.8	(n) 31.3	(o) 3.7	(p) 150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.1	19.9	28.2	23.6	19.3	27.5	23.2	18.8	26.9	82.0	33.0	79.2	32.3	77.0	31.4	37.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 7.9	(b) 7.2	(c) 6.3	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 7.9	(b) 7.2	(c) 6.3	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.6	8.9	11.3	15.3	19.5	23.1	27.8	29.3	29.5	25.8	20.1	14.2	9.8
	DBStd	8.45	5.29	6.15	5.05	4.12	3.61	2.14	1.91	2.11	3.18	4.70	5.36	5.44
	HDD10.0	244	82	53	14	1	0	0	0	0	0	2	22	71
	HDD18.3	1101	293	203	117	34	8	0	0	0	1	37	141	268
	CDD10.0	3748	49	91	180	286	406	533	597	604	474	314	149	65
	CDD18.3	1561	1	7	24	70	154	283	339	346	224	90	18	4
	CDH23.3	17802	24	64	203	632	1403	3278	4403	4524	2283	824	128	34
	CDH26.7	8837	2	9	33	181	506	1659	2491	2596	1084	255	20	1
Wind	WSAvg	2.7	2.6	3.0	3.1	3.4	3.3	3.0	2.6	2.4	2.2	2.4	2.4	2.4
Precipitation	PrecAvg	807	45	59	59	67	104	86	55	65	74	88	59	55
	PrecMax	1079	204	199	172	225	234	222	373	328	237	256	204	251
	PrecMin	421	0	2	3	0	11	1	0	0	1	8	0	1
	PrecStd	174	38	43	43	51	55	57	67	66	50	64	42	45
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.8	27.7	29.5	33.4	35.1	38.3	40.7	39.7	37.6	33.6	29.0	26.4
		MCWB	13.6	14.7	16.6	19.2	22.4	21.9	22.3	21.9	19.4	21.3	20.5	16.8
	2%	DB	23.4	25.0	27.4	31.2	32.9	36.9	37.9	37.9	35.7	32.0	27.0	24.3
		MCWB	14.8	16.4	17.2	20.1	22.2	22.0	22.1	22.1	21.8	21.4	18.1	17.2
	5%	DB	21.1	23.5	25.6	28.5	31.8	35.3	36.9	37.3	34.2	29.1	24.5	21.7
		MCWB	14.4	16.4	17.4	19.4	21.8	22.8	22.5	22.1	22.4	20.7	18.1	16.4
	10%	DB	17.5	21.3	24.0	27.2	29.4	33.9	35.7	36.2	32.7	27.6	22.4	19.0
		MCWB	11.5	16.0	16.5	18.6	21.3	23.3	23.2	22.8	22.4	18.9	17.4	14.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.1	20.7	21.0	23.8	25.7	26.6	27.3	26.1	25.8	24.8	22.8	21.1
		MCDB	22.1	24.1	24.3	28.4	30.7	33.2	35.5	32.8	32.5	30.0	26.5	23.5
	2%	WB	16.8	19.4	20.1	22.5	24.5	25.6	25.8	25.3	25.0	23.7	21.2	19.5
		MCDB	21.2	22.1	24.0	26.6	28.8	32.3	33.3	32.8	31.4	27.6	23.8	22.4
	5%	WB	14.9	18.3	19.3	21.6	23.7	25.0	25.2	24.7	24.2	22.9	20.0	17.4
		MCDB	18.3	21.3	23.3	26.1	27.9	31.4	32.8	31.7	29.5	26.3	22.6	21.0
	10%	WB	13.0	16.6	18.4	20.7	23.0	24.4	24.6	24.2	23.8	22.0	18.7	15.3
		MCDB	17.2	19.9	22.1	24.7	27.3	30.1	31.5	30.7	28.6	25.8	21.4	18.3
Mean Daily Temperature Range	5% DB	MDBR	12.5	11.9	12.4	12.2	11.2	11.5	12.4	12.4	11.3	12.2	12.0	11.4
		MCDBR	16.2	14.3	13.6	14.2	13.3	13.3	13.9	13.7	13.7	13.2	12.9	14.1
		MCWBR	9.2	8.7	7.1	6.7	5.3	3.6	3.4	3.4	4.2	5.7	7.0	9.1
	5% WB	MCDBR	13.2	11.8	11.0	11.3	10.4	10.8	12.3	12.0	10.7	10.7	10.3	11.8
		MCWBR	9.5	8.8	7.3	7.3	5.3	4.0	3.9	3.7	3.7	6.1	7.2	9.1
Clear-Sky Solar Irradiance	taub	0.310	0.319	0.346	0.386	0.420	0.415	0.426	0.418	0.389	0.362	0.334	0.313	
	taud	2.523	2.501	2.439	2.350	2.309	2.365	2.375	2.376	2.405	2.469	2.483	2.517	
	Ebn at Noon	924	946	938	906	872	872	860	865	880	885	885	900	
	Edh at Noon	86	96	110	125	131	124	122	121	113	99	89	83	
All-Sky Solar Radiation	RadAvg	3.08	3.65	4.67	5.61	5.90	6.74	6.78	6.31	5.24	4.22	3.23	2.73	
	RadStd	0.33	0.57	0.41	0.52	0.58	0.52	0.53	0.38	0.46	0.63	0.40	0.37	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (43 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+75

Nomenclature: See separate page