

AUSTIN EXECUTIVE, TX, USA

WMO: 720648

Lat: 30.395N

Lon: 97.567W

Elev: 617

StdP: 14.37

Time Zone: -6.00 (NAC)

Period: 09-19

WBAN: 00230

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.1	31.6	12.1	10.4	34.3	16.3	12.8	40.4	27.7	48.5	25.2	46.6	10.4	10	0.427

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	21.9	100.0	75.4	98.9	74.8	95.3	75.0	80.1	87.9	78.3	87.8	77.6	86.8	7.5	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.5	151.6	80.8	76.8	143.1	79.5	75.3	135.8	79.1	43.8	88.4	42.2	87.9	41.3	86.1	98.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
22.7	19.5	17.4	DB	21.6	105.1	4.6	6.2	18.3	109.6	15.6	113.2	13.1	116.7	9.8	121.3
			WB	18.7	82.4	4.0	6.3	15.8	86.9	13.5	90.6	11.3	94.1	8.4	98.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	68.7	50.0	54.3	61.5	68.6	75.0	82.0	84.3	85.3	79.8	71.2	59.7	52.1
	DBStd	14.46	9.38	11.01	8.74	6.77	5.90	3.33	2.65	3.47	4.83	9.10	9.47	9.27
	HDD50	321	116	75	17	0	0	0	0	0	0	2	26	85
	HDD65	1672	469	323	169	41	7	0	0	0	1	41	209	412
	CDD50	7151	115	195	374	557	774	960	1063	1093	895	659	316	150
	CDD65	3025	3	23	60	147	316	510	598	628	445	234	50	11
	CDH74	32132	30	118	357	1097	2756	5600	7106	7996	4418	2320	284	50
	CDH80	15753	1	16	50	291	1054	2761	3819	4543	2137	1030	48	3
(14) Wind	WSAvg	7.4	8.2	9.3	9.0	8.5	8.0	6.6	6.4	6.2	5.5	6.5	7.3	7.9
(15) Precipitation	PrecAvg	35.2	2.6	2.0	2.7	2.9	4.2	3.3	2.5	2.1	3.1	4.3	3.0	2.6
	PrecMax	59.3	8.8	7.0	7.4	6.7	13.9	10.6	9.0	7.6	9.2	18.5	10.9	13.1
	PrecMin	17.0	0.0	0.0	0.2	0.4	0.1	0.3	0.2	0.0	0.2	0.1	0.1	0.3
	PrecStd	10.3	2.1	1.7	1.6	1.7	2.8	2.5	2.0	2.0	2.0	4.2	2.7	2.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.2	82.3	84.0	90.3	93.3	100.2	100.3	102.5	99.3	109.0	84.1	79.4
		MCWB	62.1	63.7	66.4	72.2	74.3	74.4	74.4	74.3	71.5	93.0	70.1	65.2
	2%	DB	73.2	77.3	81.4	86.1	90.9	96.5	99.1	100.2	95.4	94.7	81.3	74.7
		MCWB	59.8	62.5	65.2	69.1	74.1	74.5	74.4	74.8	73.2	82.5	67.6	64.3
	5%	DB	69.7	73.5	77.4	82.4	89.6	93.3	96.5	99.1	93.1	89.8	77.0	72.0
		MCWB	59.1	62.6	64.8	68.5	73.8	75.3	74.8	74.8	72.8	75.5	66.1	63.5
	10%	DB	65.7	71.6	75.0	81.0	85.9	91.2	94.6	96.6	90.8	84.4	73.3	67.7
		MCWB	57.6	61.9	64.2	67.9	72.6	75.8	75.1	74.7	73.3	71.2	66.0	62.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.9	69.4	71.3	75.5	77.9	79.5	79.5	78.7	78.9	93.8	74.0	71.5
		MCDB	71.9	75.3	78.1	82.6	87.5	89.8	90.0	90.4	85.0	101.6	78.2	74.2
	2%	WB	65.6	67.9	69.4	73.8	76.8	78.5	78.4	78.0	77.6	86.1	72.2	68.2
		MCDB	69.9	72.3	74.9	80.0	85.3	88.2	88.3	88.8	85.2	90.7	75.9	72.1
	5%	WB	62.6	66.2	68.3	72.3	75.7	77.9	77.8	77.4	76.9	77.0	69.9	66.1
		MCDB	66.6	70.3	73.5	79.3	83.7	87.3	87.4	87.6	84.5	82.7	74.7	69.9
	10%	WB	59.0	63.9	67.1	71.0	74.6	77.2	77.2	76.8	76.0	73.8	67.9	63.0
		MCDB	63.9	68.0	72.1	78.1	81.9	86.2	86.5	87.4	83.4	79.8	72.8	65.9
(35) Mean Daily Temperature Range	5% DB	MDBR	20.4	19.5	20.3	20.4	19.2	19.4	20.5	21.9	19.9	22.6	20.2	18.5
		MCDBR	26.3	21.9	21.7	22.3	21.4	21.2	23.3	24.5	23.0	28.7	21.6	22.8
	5% WB	MCWBR	15.6	12.8	11.6	10.3	8.0	5.4	4.8	4.9	6.3	13.8	12.0	14.5
		MCDWR	20.7	18.1	18.0	17.9	17.2	17.8	19.0	21.1	17.8	24.9	18.0	19.4
(40) Clear-Sky Solar Irradiance	taub		0.326	0.337	0.360	0.402	0.446	0.430	0.443	0.432	0.410	0.375	0.360	0.320
		taud	2.495	2.472	2.416	2.318	2.241	2.333	2.331	2.349	2.361	2.445	2.422	2.523
	Ebn at Noon		288	294	293	283	270	272	268	271	274	277	272	284
		Edh at Noon	29	32	36	41	45	41	41	39	37	32	30	26
(44) All-Sky Solar Radiation	RadAvg		952	1096	1426	1712	1828	2088	2110	1994	1646	1351	1012	840
	RadStd		101	198	131	151	157	146	170	103	148	190	116	109

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (40 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+153

Nomenclature: See separate page