

AUSTIN EXECUTIVE, TX, USA

WMO: 720648

Lat: 30.395N

Lon: 97.567W

Elev: 188

StdP: 99.09

Time Zone: -6.00 (NAC)

Period: 09-19

WBAN: 00230

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.7	-0.2	-11.1	1.5	1.3	-8.7	1.8	4.7	12.4	9.2	11.3	8.1	4.6	10	0.427

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.2	37.8	24.1	37.2	23.8	35.2	23.9	26.7	31.1	25.7	31.0	25.3	30.5	3.4	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.9	21.7	27.1	24.9	20.4	26.4	24.1	19.4	26.2	84.0	31.4	80.3	31.1	78.2	30.0	36.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.2	8.7	7.8	DB	-5.8	40.6	2.5	3.5	-7.6	43.1	-9.1	45.1	-10.5	47.1	-12.4	49.6	(4)
(5)			WB	-7.4	28.0	2.2	3.5	-9.0	30.5	-10.3	32.5	-11.5	34.5	-13.1	37.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.4	10.0	12.4	16.4	20.3	23.9	27.8	29.0	29.6	26.6	21.8	15.4	11.2
	DBStd	8.03	5.21	6.12	4.85	3.76	3.28	1.85	1.47	1.93	2.69	5.06	5.26	5.15
	HDD10.0	178	64	42	9	0	0	0	0	0	0	1	14	47
	HDD18.3	929	261	179	94	23	4	0	0	0	1	23	116	229
	CDD10.0	3973	64	108	208	309	430	533	591	607	497	366	176	83
	CDD18.3	1681	2	13	33	82	176	283	332	349	247	130	28	6
	CDH23.3	17851	17	66	198	609	1531	3111	3948	4442	2454	1289	158	28
CDH26.7	8752	1	9	28	162	586	1534	2122	2524	1187	572	27	2	
Wind	WSAvg	3.3	3.7	4.2	4.0	3.8	3.6	2.9	2.8	2.8	2.4	2.9	3.3	3.5
Precipitation	PrecAvg	895	65	52	69	74	106	85	63	54	79	108	75	66
	PrecMax	1507	224	179	188	170	354	268	228	194	234	470	278	333
	PrecMin	431	0	1	5	9	3	7	5	0	4	2	2	7
	PrecStd	261	54	43	40	43	72	63	52	52	52	106	68	65
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.1	27.9	28.9	32.4	34.0	37.9	37.9	39.1	37.4	42.8	29.0	26.3
		MCWB	16.7	17.6	19.1	22.3	23.5	23.5	23.6	23.5	22.0	33.9	21.2	18.5
	2%	DB	22.9	25.2	27.4	30.0	32.7	35.8	37.3	37.9	35.2	34.8	27.4	23.7
		MCWB	15.5	16.9	18.4	20.6	23.4	23.6	23.6	23.8	22.9	28.1	19.8	18.0
	5%	DB	20.9	23.1	25.2	28.0	32.0	34.0	35.8	37.3	33.9	32.1	25.0	22.2
		MCWB	15.0	17.0	18.2	20.3	23.2	24.1	23.8	23.8	22.7	24.2	19.0	17.5
	10%	DB	18.7	22.0	23.9	27.2	29.9	32.9	34.8	35.9	32.7	29.1	23.0	19.8
		MCWB	14.2	16.6	17.9	20.0	22.6	24.3	23.9	23.7	23.0	21.8	18.9	16.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.9	20.8	21.8	24.2	25.5	26.4	26.4	26.0	26.1	34.3	23.3	22.0
		MCDB	22.2	24.0	25.6	28.1	30.8	32.1	32.2	32.4	29.5	38.7	25.7	23.4
	2%	WB	18.7	20.0	20.8	23.2	24.9	25.8	25.8	25.6	25.3	30.0	22.3	20.1
		MCDB	21.1	22.4	23.8	26.7	29.6	31.2	31.3	31.6	29.6	32.6	24.4	22.3
	5%	WB	17.0	19.0	20.2	22.4	24.3	25.5	25.5	25.2	24.9	25.0	21.1	18.9
		MCDB	19.2	21.3	23.0	26.3	28.7	30.7	30.8	30.9	29.2	28.2	23.7	21.1
	10%	WB	15.0	17.7	19.5	21.7	23.7	25.1	25.1	24.9	24.5	23.2	19.9	17.2
		MCDB	17.7	20.0	22.3	25.6	27.7	30.1	30.3	30.8	28.6	26.5	22.7	18.8
Mean Daily Temperature Range	5% DB	MDBR	11.3	10.9	11.3	11.3	10.7	10.8	11.4	12.2	11.1	12.5	11.2	10.3
		MCDBR	14.6	12.1	12.1	12.4	11.9	11.8	12.9	13.6	12.8	16.0	12.0	12.6
		MCWBR	8.7	7.1	6.5	5.7	4.5	3.0	2.7	2.7	3.5	7.7	6.6	8.1
	5% WB	MCDBR	11.5	10.0	10.0	10.0	9.6	9.9	10.6	11.7	9.9	13.8	10.0	10.8
		MCWBR	9.1	7.3	6.6	5.2	4.2	3.2	2.8	2.8	3.2	10.0	7.0	8.7
Clear-Sky Solar Irradiance	taub	0.326	0.337	0.360	0.402	0.446	0.430	0.443	0.432	0.410	0.375	0.360	0.320	
	taud	2.495	2.472	2.416	2.318	2.241	2.333	2.331	2.349	2.361	2.445	2.422	2.523	
	Ebn at Noon	907	927	924	892	850	859	846	854	863	874	857	896	
	Edh at Noon	90	100	113	130	141	128	128	124	118	102	96	83	
All-Sky Solar Radiation	RadAvg	3.00	3.46	4.49	5.40	5.76	6.58	6.65	6.29	5.19	4.26	3.19	2.65	
	RadStd	0.32	0.62	0.41	0.48	0.49	0.46	0.54	0.33	0.47	0.60	0.37	0.34	

Historical Trends

		Heating		Cooling		Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (40 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+85

Nomenclature: See separate page