

OZONA, TX, USA

WMO: 720659

Lat: 30.735N

Lon: 101.203W

Elev: 2382

StdP: 13.47

Time Zone: -6.00 (NAC)

Period: 09-19

WBAN: 00239

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.0	26.5	4.9	7.7	38.8	9.7	9.9	38.5	26.7	47.9	24.7	48.8	3.8	30	0.522

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	24.3	100.1	68.0	99.1	68.0	97.0	68.2	73.6	85.1	72.8	84.9	72.0	84.6	11.5	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.7	128.0	77.6	70.1	120.9	76.9	68.4	114.1	76.4	39.0	86.7	38.0	84.7	37.2	84.4	78.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
24.2	21.0	19.2	DB	14.9	104.2	3.9	2.3	12.1	105.8	9.8	107.2	7.6	108.5	4.8	110.2	(4)
			WB	13.2	74.7	3.7	1.4	10.6	75.7	8.4	76.6	6.3	77.4	3.6	78.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	65.9	45.8	50.3	59.4	67.0	73.8	82.2	82.8	83.2	76.8	66.1	54.6	47.4	(6)
		DBStd	15.42	8.12	9.93	8.90	7.62	7.56	4.77	3.56	3.95	5.65	8.52	8.86	8.05	(7)
		HDD50	516	174	106	25	1	0	0	0	0	8	52	150		(8)
		HDD65	2279	595	416	215	67	20	0	0	2	92	325	547		(9)
		CDD50	6305	45	114	315	510	738	967	1017	1031	803	507	190	68	(10)
		CDD65	2593	1	4	40	126	293	517	552	566	355	126	13	0	(11)
		CDH74	30992	29	105	588	1570	3304	6355	6771	7040	3705	1324	156	45	(12)
		CDH80	15750	2	14	171	610	1534	3465	3735	3990	1769	430	24	6	(13)
(14)	Wind	WSAvg	9.1	7.6	8.9	9.8	10.7	10.9	11.2	9.5	8.3	8.1	8.1	8.2	7.5	(14)
(15)	Precipitation	PrecAvg	18.7	0.8	0.9	1.3	1.4	2.2	2.1	1.7	2.3	2.2	2.0	1.1	0.6	(15)
(16)		PrecMax	32.6	2.6	3.5	4.6	3.3	6.9	6.2	6.6	8.0	6.8	8.9	4.2	2.8	(16)
(17)		PrecMin	10.4	0.0	0.1	0.0	0.0	0.3	0.2	0.2	0.0	0.0	0.1	0.0	0.0	(17)
(18)		PrecStd	5.2	0.7	0.9	1.1	0.9	1.7	1.5	1.5	1.9	1.9	2.2	1.2	0.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	77.5	81.9	89.7	96.9	99.8	104.0	100.3	102.3	99.1	91.0	82.4	79.1		(19)
(20)		MCWB	54.2	56.6	59.1	61.5	65.4	68.2	67.4	69.2	66.8	63.4	61.4	54.6		(20)
(21)		DB	72.4	77.2	84.5	90.7	96.5	100.1	99.2	100.0	95.4	88.2	78.9	73.0		(21)
(22)		MCWB	53.3	55.7	57.9	60.7	64.9	67.8	67.9	69.1	67.5	65.0	60.3	53.8		(22)
(23)		DB	68.0	72.8	81.0	87.6	91.3	98.6	97.2	98.9	92.6	85.5	73.4	69.6		(23)
(24)		MCWB	50.8	54.1	57.7	61.4	65.0	68.0	68.7	69.0	67.2	64.7	57.8	53.2		(24)
(25)		DB	63.2	68.2	76.7	82.2	88.3	95.0	95.1	96.7	90.1	81.5	70.4	63.5		(25)
(26)		MCWB	49.4	54.1	56.2	60.3	64.7	68.4	68.9	69.1	66.8	63.8	58.0	52.6		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	60.8	63.4	65.8	69.5	73.2	74.0	75.3	74.5	73.9	71.1	67.7	62.6		(27)
(28)		MCDB	66.9	68.7	75.5	80.4	83.7	86.0	85.0	86.0	84.3	79.3	75.2	66.6		(28)
(29)		WB	57.0	61.8	64.2	67.7	71.8	72.9	73.8	73.3	72.1	69.7	65.6	60.0		(29)
(30)		MCDB	65.9	67.7	72.7	77.7	82.4	86.0	84.4	86.0	82.7	77.6	71.2	65.2		(30)
(31)		WB	53.4	60.1	63.0	66.3	70.7	72.1	72.7	72.2	71.1	68.7	63.2	56.9		(31)
(32)		MCDB	61.9	67.5	71.1	76.9	81.6	85.4	84.1	86.4	81.6	77.2	68.8	63.6		(32)
(33)		WB	50.7	56.9	61.2	64.8	69.6	71.2	71.8	71.3	70.2	67.3	61.1	53.6		(33)
(34)		MCDB	61.0	65.3	69.7	75.4	80.8	84.8	83.9	86.6	80.6	76.7	67.8	61.9		(34)
(35)	Mean Daily Temperature Range	MDBR	27.4	26.8	27.6	27.4	24.5	23.1	23.0	24.3	22.8	26.0	26.0	26.0		(35)
(36)		5% DB	36.4	35.7	33.4	31.9	29.2	27.0	25.7	26.8	27.8	30.1	30.6	35.9		(36)
(37)		MCWBR	19.2	19.5	14.9	13.2	10.3	7.7	7.9	7.7	9.6	12.2	15.7	19.2		(37)
(38)		5% WB	29.2	25.2	24.0	23.4	20.9	21.9	20.9	23.0	20.2	19.5	22.7	24.0		(38)
(39)		MCWBR	17.9	17.2	12.4	12.0	8.5	7.0	6.7	7.1	7.0	9.3	14.1	16.7		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.276	0.284	0.304	0.339	0.359	0.375	0.390	0.370	0.356	0.320	0.296	0.278		(40)
(41)		taud	2.601	2.584	2.536	2.443	2.447	2.443	2.445	2.509	2.476	2.577	2.571	2.596		(41)
(42)		Ebn at Noon	308	314	312	302	294	288	283	289	290	297	297	301		(42)
(43)		Edh at Noon	25	28	32	36	36	36	36	34	33	28	26	24		(43)
(44)	All-Sky Solar Radiation	RadAvg	1067	1313	1678	2007	2097	2288	2225	2071	1712	1396	1119	960		(44)
(45)		RadStd	116	163	130	153	181	142	154	107	125	192	138	111		(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Regional (16 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+209	+162

Nomenclature: See separate page