

OZONA, TX, USA

WMO: 720659

Lat: 30.735N

Lon: 101.203W

Elev: 726

StdP: 92.90

Time Zone: -6.00 (NAC)

Period: 09-19

WBAN: 00239

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.1	-3.0	-15.0	1.1	3.8	-12.4	1.4	3.6	11.9	8.8	11.0	9.4	1.7	30	0.522

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.5	37.8	20.0	37.3	20.0	36.1	20.1	23.1	29.5	22.7	29.4	22.2	29.2	5.2	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.0	18.3	25.3	21.1	17.3	24.9	20.2	16.3	24.7	72.8	30.4	70.6	29.3	68.7	29.1	25.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.8	9.4	8.6	DB	-9.5	40.1	2.2	1.3	-11.1	41.0	-12.3	41.8	-13.6	42.5	-15.1	43.4	
			WB	-10.4	23.7	2.1	0.8	-11.9	24.3	-13.1	24.8	-14.3	25.2	-15.8	25.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.8	7.7	10.2	15.2	19.4	23.2	27.9	28.2	28.5	24.9	18.9	12.6	8.5
	DBStd	8.56	4.51	5.52	4.95	4.23	4.20	2.65	1.98	2.20	3.14	4.73	4.92	4.47
	HDD10.0	287	97	59	14	1	0	0	0	0	0	4	29	83
	HDD18.3	1266	331	231	119	37	11	0	0	0	1	51	181	304
	CDD10.0	3503	25	63	175	283	410	537	565	573	446	282	106	38
	CDD18.3	1441	1	2	22	70	163	287	307	314	197	70	7	0
	CDH23.3	17218	16	58	327	872	1836	3531	3762	3911	2058	736	87	25
	CDH26.7	8750	1	8	95	339	852	1925	2075	2217	983	239	13	3
Wind	WSAvg	4.1	3.4	4.0	4.4	4.8	4.9	5.0	4.3	3.7	3.6	3.6	3.7	3.4
Precipitation	PrecAvg	475	20	24	34	36	55	53	43	58	55	52	27	15
	PrecMax	827	67	89	117	85	174	157	168	203	172	226	106	71
	PrecMin	264	1	2	0	1	7	5	5	1	0	2	0	1
	PrecStd	131	19	23	27	24	44	38	38	49	49	55	31	17
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.3	27.7	32.1	36.0	37.7	40.0	38.0	39.1	37.3	32.8	28.0	26.2
		MCWB	12.4	13.7	15.1	16.4	18.5	20.1	19.7	20.7	19.4	17.4	16.3	12.6
	2%	DB	22.5	25.1	29.1	32.6	35.9	37.8	37.3	37.8	35.2	31.2	26.1	22.8
		MCWB	11.8	13.2	14.4	15.9	18.3	19.9	19.9	20.6	19.7	18.3	15.7	12.1
	5%	DB	20.0	22.7	27.2	30.9	33.0	37.0	36.2	37.2	33.7	29.7	23.0	20.9
		MCWB	10.5	12.3	14.3	16.4	18.3	20.0	20.4	20.6	19.6	18.1	14.3	11.8
	10%	DB	17.3	20.1	24.9	27.9	31.3	35.0	35.1	35.9	32.3	27.5	21.3	17.5
		MCWB	9.6	12.3	13.5	15.7	18.2	20.2	20.5	20.6	19.3	17.7	14.5	11.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.0	17.4	18.8	20.8	22.9	23.3	24.0	23.6	23.3	21.7	19.8	17.0
		MCDB	19.4	20.4	24.2	26.9	28.7	30.0	29.5	30.0	29.1	26.3	24.0	19.2
	2%	WB	13.9	16.5	17.9	19.8	22.1	22.7	23.2	22.9	22.3	20.9	18.7	15.5
		MCDB	18.9	19.8	22.6	25.4	28.0	30.0	29.1	30.0	28.2	25.4	21.8	18.5
	5%	WB	11.9	15.6	17.2	19.1	21.5	22.3	22.6	22.4	21.7	20.4	17.3	13.8
		MCDB	16.6	19.7	21.7	24.9	27.5	29.7	28.9	30.2	27.6	25.1	20.5	17.5
	10%	WB	10.4	13.9	16.2	18.2	20.9	21.8	22.1	21.9	21.2	19.6	16.1	12.0
		MCDB	16.1	18.5	20.9	24.1	27.1	29.3	28.8	30.3	27.0	24.8	19.9	16.6
Mean Daily Temperature Range	5% DB	MDBR	15.2	14.9	15.4	15.2	13.6	12.8	12.8	13.5	12.7	14.5	14.4	14.5
		MCDBR	20.2	19.8	18.6	17.7	16.2	15.0	14.3	14.9	15.5	16.7	17.0	19.9
		MCWBR	10.6	10.8	8.3	7.3	5.7	4.3	4.4	4.3	5.3	6.8	8.7	10.7
	5% WB	MCDBR	16.2	14.0	13.3	13.0	11.6	12.2	11.6	12.8	11.2	10.8	12.6	13.3
		MCWBR	10.0	9.5	6.9	6.7	4.7	3.9	3.7	3.9	3.9	5.2	7.8	9.3
Clear-Sky Solar Irradiance	taub	0.276	0.284	0.304	0.339	0.359	0.375	0.390	0.370	0.356	0.320	0.296	0.278	
	taud	2.601	2.584	2.536	2.443	2.447	2.443	2.445	2.509	2.476	2.577	2.571	2.596	
	Ebn at Noon	970	989	983	952	928	908	892	911	915	935	936	950	
	Edh at Noon	79	89	100	114	114	114	114	106	105	89	81	76	
All-Sky Solar Radiation	RadAvg	3.36	4.14	5.29	6.33	6.61	7.21	7.01	6.53	5.40	4.40	3.53	3.03	
	RadStd	0.37	0.52	0.41	0.48	0.57	0.45	0.49	0.34	0.40	0.60	0.43	0.35	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (16 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+116	+90

Nomenclature: See separate page