

WEST GEORGIA, GA, USA

WMO: 720674

Lat: 33.633N

Lon: 85.150W

Elev: 354

StdP: 97.14

Time Zone: -5.00 (NAE)

Period: 10-19

WBAN: 00249

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.2	-3.7	-22.9	0.5	8.9	-17.0	0.9	3.4	8.3	3.1	7.5	2.6	2.6	330	0.351

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.4	33.9	23.5	32.8	23.3	32.1	23.1	25.7	30.2	25.1	29.5	24.5	29.1	2.1	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.8	20.7	27.3	23.9	19.6	26.8	23.1	18.6	26.1	81.5	30.5	78.6	29.0	76.0	29.3	27.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.1	5.7	5.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			-9.2	26.3	2.0	0.8	-10.7	26.9	-11.9	27.4	-13.0	27.8	-14.5	28.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.7	5.7	8.7	12.2	16.5	20.6	24.5	26.0	25.6	23.0	17.1	11.2	8.4		
	DBStd	8.03	5.44	5.50	4.80	3.71	3.44	2.10	1.78	1.98	2.86	4.17	4.36	5.02		
	HDD10.0	406	154	84	33	2	0	0	0	0	0	3	36	93		
	HDD18.3	1553	391	270	194	76	21	0	0	0	3	73	216	309		
	CDD10.0	2844	22	49	102	199	330	435	496	483	391	222	72	44		
	CDD18.3	951	0	2	6	22	93	185	238	225	144	33	2	1		
	CDH23.3	8352	0	5	61	273	839	1588	2151	1921	1214	286	15	0		
	CDH26.7	3221	0	0	6	36	246	638	936	806	491	62	2	0		
(14) Wind	WSAvg	1.7	2.2	2.3	2.4	2.0	1.4	1.2	1.1	1.1	1.1	1.6	1.8	2.0		
(15) Precipitation	PrecAvg	1302	127	131	144	104	94	108	133	92	96	79	112	105		
	PrecMax	1667	229	211	249	182	300	213	386	182	276	251	252	196		
	PrecMin	742	57	56	42	42	16	37	31	20	15	20	27	64		
	PrecStd	244	44	47	58	42	63	46	84	41	66	55	59	33		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.0	24.1	27.4	29.3	32.1	35.1	35.1	35.1	34.0	31.0	25.3	22.4		
		MCWB	15.9	17.9	17.1	18.5	21.4	23.4	24.0	24.0	21.8	21.6	15.9	18.6		
	2%	DB	18.4	21.7	25.2	27.6	30.7	33.0	33.7	33.3	32.8	28.0	22.5	20.3		
		MCWB	13.6	16.2	16.4	18.0	21.0	23.4	24.3	23.6	21.8	19.5	14.8	17.2		
	5%	DB	16.3	19.3	22.8	26.4	29.4	32.2	32.6	32.3	31.6	26.4	20.6	18.8		
		MCWB	13.4	15.2	15.5	17.6	20.7	23.3	24.2	23.2	21.8	18.9	15.4	16.2		
	10%	DB	14.5	17.6	20.8	25.0	27.8	30.3	31.4	31.1	29.9	24.8	19.0	17.1		
		MCWB	11.6	14.2	14.5	16.9	20.2	22.9	24.0	23.3	22.0	17.9	14.2	13.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.4	18.9	19.0	21.5	23.3	25.9	26.7	26.5	24.2	23.0	20.4	20.7		
		MCDB	19.3	21.7	23.5	25.6	27.5	30.9	31.9	31.2	28.9	26.6	21.3	21.3		
	2%	WB	16.1	17.5	18.0	20.2	22.5	25.2	25.7	25.6	23.7	22.2	19.0	18.8		
		MCDB	17.6	19.9	21.7	24.5	27.3	30.1	30.4	29.7	28.4	26.2	20.4	19.8		
	5%	WB	14.4	16.7	17.3	19.2	21.9	24.4	25.1	25.0	23.2	21.0	17.1	16.3		
		MCDB	15.8	18.8	20.7	23.8	27.1	29.5	29.8	28.9	27.7	23.7	18.9	17.6		
	10%	WB	11.9	15.4	16.1	18.2	21.3	23.7	24.6	24.4	22.6	19.8	15.3	14.2		
		MCDB	13.5	17.2	19.8	22.7	26.1	28.5	29.4	28.5	27.3	22.9	17.1	16.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.7	10.7	11.8	13.4	12.1	10.8	10.4	10.3	11.6	12.5	12.0	9.8		
		MCDBR	12.7	12.5	14.7	15.1	14.0	13.1	11.9	12.3	14.4	14.3	12.7	10.7		
	5% WB	MCWBR	9.0	8.0	7.1	6.7	5.5	4.5	3.9	3.9	4.8	6.2	7.8	7.9		
		MCWBR	10.4	10.5	11.7	12.3	11.7	11.0	10.7	10.1	11.3	10.1	10.6	9.7		
(40) Clear-Sky Solar Irradiance	taub		0.313	0.316	0.350	0.387	0.455	0.480	0.528	0.528	0.422	0.365	0.336	0.315		
		taud	2.524	2.509	2.436	2.315	2.160	2.138	2.016	2.004	2.298	2.447	2.468	2.532		
	Ebn at Noon		905	938	926	901	839	814	773	765	841	870	866	880		
		Edh at Noon	83	93	109	128	152	155	174	173	124	98	87	78		
(44) All-Sky Solar Radiation	RadAvg		2.66	3.20	4.31	5.49	6.03	6.14	5.90	5.44	4.73	4.00	2.98	2.26		
	RadStd		0.17	0.41	0.38	0.36	0.51	0.49	0.42	0.32	0.46	0.52	0.32	0.23		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (43 neighbors)	+0.48	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+156	+111

Nomenclature: See separate page