

NW FLORIDA BEACHES, FL, USA

WMO: 720735

Lat: 30.349N

Lon: 85.788W

Elev: 17

StdP: 101.12

Time Zone: -6.00 (NAC)

Period: 10-19

WBAN: 73805

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.7	0.4	-9.5	1.7	3.5	-6.6	2.2	3.9	10.5	14.6	9.3	12.0	2.2	340	0.380

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.8	34.4	24.8	33.5	24.8	32.7	24.8	27.0	30.9	26.6	30.6	26.2	30.3	3.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.1	21.6	28.7	25.6	20.9	28.5	25.1	20.2	28.3	85.0	31.0	82.7	30.4	81.2	30.3	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.6	7.7	6.9	DB	-4.4	36.0	2.1	1.3	-5.9	37.0	-7.2	37.7	-8.3	38.4	-9.8	39.3	(4)
			WB	-5.7	28.1	2.3	0.6	-7.3	28.6	-8.7	28.9	-9.9	29.3	-11.6	29.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	20.5	11.2	14.3	16.4	20.0	23.5	27.1	27.8	27.8	26.4	21.3	15.7	13.7	(6)
		DBStd	6.82	5.30	4.76	4.17	2.89	2.78	1.47	1.30	1.35	2.00	3.72	4.42	5.04	(7)
		HDD10.0	95	48	16	4	0	0	0	0	0	0	6	21		(8)
		HDD18.3	737	229	126	86	18	3	0	0	0	17	102	158		(9)
		CDD10.0	3910	84	135	204	298	420	512	551	553	491	349	177	136	(10)
		CDD18.3	1509	7	11	27	66	164	262	292	295	241	107	23	14	(11)
		CDH23.3	14046	7	34	124	459	1558	2604	3014	2984	2129	943	155	35	(12)
(13)	Wind	CDH26.7	5402	0	1	9	58	563	1088	1276	1217	892	283	16	0	(13)
		WSAvg	2.7	3.1	3.2	3.3	3.1	2.7	2.5	2.2	2.1	2.2	2.6	2.8	3.0	(14)
		PrecAvg	1417	116	113	136	97	73	133	158	167	144	85	87	107	(15)
		PrecMax	1844	416	275	261	267	223	279	272	317	655	198	257	240	(16)
		PrecMin	1004	39	26	3	21	5	19	77	80	11	12	4	34	(17)
		PrecStd	264	82	67	71	65	55	64	54	64	129	53	56	42	(18)
		DB	24.4	26.1	27.7	29.6	34.0	35.4	35.3	35.3	35.2	33.0	28.4	25.8		(19)
(20)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	MCWB	20.1	19.8	19.4	21.5	22.4	24.3	25.4	25.4	24.1	23.2	22.1	21.9		(20)
		DB	23.0	24.4	26.2	28.2	32.3	33.8	33.9	33.9	33.6	31.0	26.6	24.4		(21)
		MCWB	19.9	19.2	19.4	20.7	22.6	24.9	25.3	25.3	24.3	21.7	21.5	20.8		(22)
		DB	21.6	22.9	24.7	27.2	31.0	32.8	32.9	33.0	32.6	29.6	25.2	23.2		(23)
		MCWB	19.1	18.9	18.9	20.3	22.2	24.7	25.3	25.5	24.1	21.5	19.8	20.8		(24)
		DB	20.0	21.5	23.4	26.1	29.9	31.7	32.1	32.0	31.4	28.2	23.6	22.0		(25)
		MCWB	17.5	18.7	18.4	20.1	22.1	24.6	25.4	25.5	24.1	21.2	19.1	19.8		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	21.8	21.7	22.3	24.3	25.2	26.9	27.6	27.9	26.9	25.7	24.8	23.5		(27)
		MCDB	23.0	23.8	24.6	27.2	30.3	31.4	31.4	31.6	30.0	28.6	26.4	24.5		(28)
		WB	20.6	20.9	21.5	23.3	24.6	26.3	26.9	27.3	26.1	25.0	23.1	22.6		(29)
		MCDB	22.1	22.7	23.6	25.7	29.2	30.8	31.0	30.9	29.9	27.8	24.7	23.5		(30)
		WB	19.6	20.2	20.7	22.6	24.0	25.8	26.5	26.8	25.6	23.9	21.7	21.3		(31)
		MCDB	21.1	22.1	22.8	25.1	28.3	30.2	30.8	30.5	29.7	26.9	23.8	22.6		(32)
		WB	18.1	19.2	19.8	21.7	23.5	25.4	26.0	26.3	25.1	22.9	20.2	19.9		(33)
(34)	Mean Daily Temperature Range	MCDB	19.8	21.2	22.3	24.5	27.7	29.8	30.3	30.1	29.3	26.4	23.1	21.4		(34)
		MDBR	11.5	10.9	11.7	11.4	11.9	9.2	8.8	8.6	10.0	12.8	13.1	10.9		(35)
		5% DB	9.8	10.5	11.7	12.0	12.9	10.7	10.1	10.1	11.4	13.2	13.1	10.2		(36)
		MCWBR	7.0	6.7	6.2	5.8	5.2	3.9	3.7	3.9	4.1	5.7	7.7	7.5		(37)
		5% WB	8.2	9.1	8.9	8.9	10.4	9.2	9.0	8.5	9.5	9.7	10.3	8.4		(38)
		MCWBR	6.8	7.0	6.1	5.7	4.7	3.9	3.8	3.7	3.9	5.6	7.5	7.2		(39)
		taub	0.333	0.347	0.366	0.394	0.437	0.467	0.501	0.495	0.436	0.383	0.354	0.342		(40)
(41)	Clear-Sky Solar Irradiance	taud	2.536	2.498	2.445	2.372	2.284	2.256	2.178	2.189	2.331	2.460	2.479	2.522		(41)
		Ebn at Noon	901	918	919	900	858	828	798	799	838	866	867	871		(42)
		Edh at Noon	87	98	110	123	135	138	149	146	122	101	91	84		(43)
		RadAvg	3.13	3.76	5.03	6.05	6.64	6.16	5.83	5.43	5.07	4.52	3.53	2.77		(44)
(45)	All-Sky Solar Radiation	RadStd	0.22	0.47	0.38	0.48	0.42	0.48	0.37	0.41	0.32	0.41	0.29	0.28		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (35 neighbors)	+0.48	N/A	N/A	N/A	N/A	N/A	N/A	-100	+167	+104

Nomenclature: See separate page