

PICKENS COUNTY AP, SC, USA

WMO: 720744

Lat: 34.817N

Lon: 82.700W

Elev: 1014

StdP: 14.17

Time Zone: -5.00 (NAE)

Period: 10-19

WBAN: 00271

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.8	23.1	3.1	6.7	30.6	8.1	8.6	33.0	20.0	48.6	18.1	47.9	1.7	70	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.0	94.9	74.8	92.7	75.0	90.6	75.2	84.0	85.2	78.8	87.0	77.4	86.5	5.5	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
83.7	183.1	85.0	76.9	145.5	81.2	75.1	136.7	80.2	49.1	84.9	43.1	88.6	41.5	86.4	93.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.9	13.5	11.4	DB	11.5	98.0	5.2	4.2	7.8	101.0	4.7	103.4	1.8	105.7	-2.0	108.8	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.0	41.1	46.6	52.0	60.6	68.8	75.7	78.9	77.4	73.0	61.1	49.8	45.5
	DBStd	14.87	9.24	9.27	8.82	6.92	6.40	3.97	3.63	3.64	5.26	7.60	7.51	8.31
	HDD50	841	299	161	85	6	0	0	0	0	0	6	93	191
	HDD65	3110	740	518	408	165	43	0	0	0	7	166	458	605
	CDD50	4839	24	65	149	323	583	771	897	850	689	350	86	52
	CDD65	1633	0	2	6	33	161	321	432	385	246	45	1	1
	CDH74	15580	1	10	142	467	1712	3013	4151	3333	2199	533	18	1
	CDH80	6634	0	0	26	75	619	1311	2058	1453	953	138	1	0
Wind	WSAvg	3.9	4.1	5.0	5.1	5.4	3.8	3.4	3.3	3.0	3.3	3.8	3.2	3.8
Precipitation	PrecAvg	56.5	4.9	5.0	5.7	4.4	3.8	5.1	5.1	5.6	4.7	3.7	3.6	5.3
	PrecMax	69.4	8.8	8.7	10.4	10.2	8.5	10.4	10.1	14.9	15.7	8.4	6.2	9.8
	PrecMin	39.8	1.9	2.8	1.8	2.0	1.3	0.9	2.7	1.5	0.7	0.0	1.6	3.0
	PrecStd	9.8	2.0	1.6	2.1	2.0	1.8	2.4	2.3	3.1	3.1	2.4	1.3	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.9	75.4	83.9	84.9	93.2	96.0	99.1	97.2	94.6	89.5	76.0	71.4
		MCWB	56.9	62.3	62.8	66.0	71.2	73.9	77.2	72.9	71.7	73.8	59.6	59.6
	2%	DB	64.4	71.3	78.6	82.1	89.9	93.0	95.2	92.6	91.7	83.5	71.8	67.1
		MCWB	55.6	58.5	60.6	65.3	70.4	74.0	76.3	76.1	72.0	67.5	58.5	62.3
	5%	DB	60.9	67.2	73.4	79.4	86.6	90.3	93.0	90.4	89.3	79.7	67.9	63.8
		MCWB	53.1	56.7	58.4	63.1	70.6	74.6	76.7	76.3	72.6	65.4	57.2	58.6
	10%	DB	56.5	63.2	69.5	76.6	83.5	87.8	90.4	88.1	86.0	76.2	64.3	60.2
		MCWB	50.6	55.6	56.7	61.1	69.9	74.0	77.1	75.8	71.9	64.4	56.7	54.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	63.3	66.3	66.1	70.4	76.8	81.4	89.1	87.9	77.9	76.0	67.1	67.2
		MCDB	65.0	71.8	75.5	77.9	85.3	91.4	90.4	89.8	84.5	82.5	71.5	68.5
	2%	WB	59.2	63.7	64.0	68.4	74.3	77.9	84.4	84.1	76.4	73.1	64.1	63.9
		MCDB	63.0	66.9	72.2	76.5	82.0	87.8	85.7	85.3	84.1	78.3	67.1	64.6
	5%	WB	55.0	60.2	62.0	66.9	72.5	76.3	79.3	78.4	75.0	70.6	61.9	60.0
		MCDB	57.3	64.8	70.1	74.9	81.0	85.8	88.1	84.8	82.8	75.6	64.1	62.7
	10%	WB	52.1	56.7	59.3	65.1	71.1	75.0	77.7	77.0	73.4	67.6	58.5	56.0
		MCDB	54.7	60.9	66.4	72.1	80.0	84.1	87.3	85.3	80.7	72.6	62.3	58.6
Mean Daily Temperature Range	5% DB	MDBR	22.2	22.9	24.8	25.6	24.8	22.7	22.0	20.3	22.4	26.2	25.0	20.6
		MCDBR	28.7	27.2	31.4	29.6	29.8	26.8	26.3	24.3	28.1	29.8	29.7	23.9
		MCWBR	18.8	17.1	15.9	13.4	12.2	10.5	8.8	8.5	10.1	14.8	17.8	15.9
	5% WB	MCDBR	18.6	21.3	24.9	23.4	23.1	23.3	23.4	20.3	21.4	21.6	19.0	16.2
		MCWBR	15.0	15.4	14.3	13.0	11.3	11.0	9.8	8.7	9.3	11.9	14.2	13.3
Clear-Sky Solar Irradiance	taub	0.310	0.319	0.355	0.393	0.455	0.479	0.523	0.517	0.415	0.378	0.334	0.307	
	taud	2.512	2.483	2.411	2.305	2.162	2.133	2.035	2.036	2.304	2.388	2.471	2.551	
	Ebn at Noon	285	295	291	283	266	258	246	245	267	269	273	280	
	Edh at Noon	26	30	35	41	48	49	54	53	39	33	27	24	
All-Sky Solar Radiation	RadAvg	841	1038	1378	1720	1900	2000	1880	1740	1498	1247	936	722	
	RadStd	50	120	92	122	143	143	123	85	134	139	88	70	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (46 neighbors)	+0.99	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+297	+202

Nomenclature: See separate page