

COURTLAND 2 WSW, AL, USA

WMO: 720774

Lat: 34.6602N

Lon: 87.3462W

Elev: 175

StdP: 99.24

Time Zone: -6.00 (NAC)

Period: 06-19

WBAN: 63868

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -8.0	(c) -5.6	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 10.0	(k) 11.2	(l) 9.0	(m) 10.9	(n) 1.9	(o) 350	(p) 0.393

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 10.0	(c) 34.5	(d) N/A	(e) 33.3	(f) N/A	(g) 32.3	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 3.2	(p) 260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 8.4	(b) 7.3	(c) 6.3	(e) -11.3	(f) 36.1	(g) 2.6	(h) 1.9	(i) -13.2	(j) 37.5	(k) -14.8	(l) 38.6	(m) -16.2	(n) 39.7	(o) -18.2	(p) 41.0		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.2	4.6	7.2	11.5	16.0	20.8	25.0	26.2	26.0	22.8	16.5	10.1	7.3
	DBStd	8.77	6.08	5.92	5.37	4.28	3.63	2.19	2.08	2.25	3.27	4.63	4.80	5.43
	HDD10.0	541	190	116	48	6	0	0	0	0	0	4	56	121
	HDD18.3	1763	427	315	217	93	21	0	0	0	6	91	250	343
	CDD10.0	2808	21	36	95	187	334	451	502	495	384	207	59	37
	CDD18.3	988	0	2	6	24	97	201	244	237	139	35	3	1
	CDH23.3	9221	0	4	54	227	854	1949	2345	2221	1216	336	14	1
CDH26.7	3676	0	0	6	30	265	829	1008	981	468	86	2	0	
Wind	WSAvg	2.5	3.0	3.1	3.1	3.0	2.5	2.2	2.0	1.8	1.8	2.2	2.4	2.8
Precipitation	PrecAvg	1444	148	140	139	125	115	110	125	102	93	80	111	155
	PrecMax	1936	284	274	258	287	314	309	204	182	241	236	208	423
	PrecMin	880	70	77	33	38	12	30	54	15	10	0	46	54
	PrecStd	238	53	56	49	58	72	60	43	41	57	53	36	78
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.9	24.0	27.5	29.1	32.3	35.1	35.7	36.9	34.5	31.4	25.2	22.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	18.8	21.3	24.8	27.6	30.8	33.4	34.0	34.7	32.9	29.0	22.5	20.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	16.8	19.5	22.6	26.2	29.6	32.4	32.8	33.0	31.3	27.0	20.6	18.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Mean Daily Temperature Range	5% DB	MDBR	10.3	10.9	11.8	12.3	11.2	11.1	10.0	10.5	11.5	12.6	12.5	10.0
		MCDBR	11.6	12.9	14.2	14.1	13.0	12.7	11.6	12.5	13.3	14.6	14.2	11.2
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.319	0.326	0.365	0.400	0.442	0.470	0.512	0.524	0.429	0.375	0.339	0.318	
	taud	2.488	2.468	2.383	2.280	2.206	2.158	2.066	2.021	2.275	2.409	2.453	2.510	
	Ebn at Noon	888	921	907	887	849	822	785	767	830	853	855	867	
	Edh at Noon	85	96	114	132	144	151	165	170	126	101	87	79	
All-Sky Solar Radiation	RadAvg	2.46	2.98	4.13	5.33	5.88	6.25	5.97	5.53	4.80	3.85	2.81	2.10	
	RadStd	0.19	0.37	0.38	0.36	0.45	0.49	0.33	0.31	0.42	0.50	0.29	0.20	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (29 neighbors)		+0.42	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+133	+95

Nomenclature: See separate page