

STANTON, MN, USA

WMO: 722003

Lat: 44.476N

Lon: 93.016W

Elev: 280

StdP: 98.00

Time Zone: -6.00 (NAC)

Period: 05-19

WBAN: 54930

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -24.8	(c) -22.1	(d) -28.9	(e) 0.3	(f) -24.3	(g) -26.3	(h) 0.4	(i) -21.8	(j) 11.8	(k) -7.4	(l) 10.8	(m) -7.9	(n) 2.0	(o) 210	(p) 0.545

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.3	32.0	23.2	30.2	22.0	28.8	21.1	24.8	30.1	23.6	28.4	22.5	27.1	4.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.0	18.3	28.7	21.9	17.2	27.2	20.9	16.1	25.8	76.8	30.3	71.8	28.7	67.5	27.0	29.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 10.6	(b) 9.0	(c) 8.1	(e) -29.0	(f) 34.8	(g) 3.5	(h) 2.0	(i) -31.5	(j) 36.3	(k) -33.6	(l) 37.4	(m) -35.6	(n) 38.5	(o) -38.1	(p) 40.0		
(a) 10.6	(b) 9.0	(c) 8.1	(e) -29.1	(f) 26.4	(g) 3.3	(h) 1.2	(i) -31.5	(j) 27.3	(k) -33.5	(l) 28.0	(m) -35.3	(n) 28.6	(o) -37.8	(p) 29.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.8	-8.7	-7.5	0.7	7.8	15.2	20.2	22.3	20.6	17.0	9.6	1.5	-6.0		
	DBStd	12.33	7.55	6.92	7.18	5.55	4.99	3.36	3.02	3.10	4.58	5.40	5.92	6.59		
	HDD10.0	2316	580	491	299	105	9	0	0	0	3	73	260	495		
	HDD18.3	4198	838	724	548	317	124	18	4	12	78	277	504	753		
	CDD10.0	1517	0	0	10	39	171	306	381	330	213	62	6	0		
	CDD18.3	358	0	0	1	1	28	73	126	83	39	7	0	0		
	CDH23.3	3273	0	0	4	20	295	623	1200	709	356	64	1	0		
	CDH26.7	940	0	0	0	2	96	177	378	181	92	14	0	0		
(14) Wind	WSAvg	3.4	3.7	3.7	3.8	4.3	3.9	3.1	2.5	2.2	2.9	3.4	3.9	3.5		
(15) Precipitation	PrecAvg	871	23	19	53	75	105	130	113	126	88	62	42	29		
	PrecMax	1044	75	46	97	147	194	218	213	262	285	155	133	80		
	PrecMin	584	5	2	9	19	40	69	34	42	22	13	4	7		
	PrecStd	115	18	12	24	35	45	43	51	50	61	39	32	17		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.2	12.3	23.2	26.2	32.8	33.5	34.1	32.3	31.8	28.7	20.0	10.1		
		MCWB	3.3	9.3	16.2	14.6	19.6	23.4	25.9	24.0	22.2	17.7	13.8	7.8		
	2%	DB	4.0	5.6	17.6	22.6	29.2	30.6	32.1	30.2	29.3	25.0	15.8	6.2		
		MCWB	2.0	3.2	13.0	13.4	18.8	21.4	24.6	22.7	21.4	16.5	10.8	4.2		
	5%	DB	2.5	3.5	14.0	20.1	26.7	28.7	30.2	28.7	27.3	22.1	12.7	4.0		
		MCWB	1.2	1.5	10.3	11.7	17.3	20.0	23.0	21.9	19.9	15.3	8.5	2.4		
	10%	DB	1.2	1.7	10.2	17.4	24.0	26.9	28.7	27.3	25.2	18.5	10.1	2.5		
		MCWB	0.1	0.2	7.1	10.4	16.1	19.0	21.7	20.8	19.1	12.7	6.6	1.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.8	9.1	17.1	16.3	22.4	25.1	27.1	25.2	24.2	21.2	14.4	8.8		
		MCDB	5.8	12.5	22.4	22.0	29.6	30.9	31.6	30.6	29.6	25.1	18.8	10.3		
	2%	WB	2.3	3.7	13.8	14.8	20.5	23.1	25.4	24.0	22.5	18.2	11.6	4.5		
		MCDB	3.8	5.4	16.4	20.8	26.5	28.2	30.8	28.6	26.9	23.5	15.0	5.9		
	5%	WB	1.3	1.6	10.0	13.2	18.9	21.6	24.1	22.9	21.2	15.3	8.8	2.5		
		MCDB	2.4	3.3	13.9	18.4	23.8	26.6	29.0	27.1	25.7	20.5	12.1	3.8		
	10%	WB	0.2	0.4	7.2	11.4	17.5	20.5	22.8	21.9	19.9	13.5	6.9	1.3		
		MCDB	1.0	1.6	10.2	16.7	22.4	25.1	27.5	26.0	24.4	17.9	9.9	2.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.8	9.5	9.2	10.8	11.6	10.5	11.3	11.3	12.0	11.1	8.9	7.8		
		MCDBR	8.5	9.3	13.5	15.8	14.6	12.7	12.0	12.2	13.6	14.9	12.7	8.5		
		MCWBR	7.3	7.5	8.6	8.7	6.5	5.7	6.0	6.1	6.8	7.6	8.4	7.1		
		MCDBR	8.1	8.7	12.4	13.0	11.2	10.5	11.0	10.7	11.7	11.4	11.7	7.8		
	5% WB	MCWBR	7.1	7.3	8.3	8.2	5.7	6.0	6.3	5.9	6.7	7.1	8.3	6.6		
(40) Clear-Sky Solar Irradiance	taub		0.267	0.292	0.320	0.374	0.403	0.405	0.403	0.403	0.374	0.324	0.291	0.268		
	taud		2.420	2.335	2.384	2.293	2.265	2.303	2.320	2.320	2.370	2.501	2.503	2.440		
	Ebn at Noon		867	899	917	887	868	866	862	849	846	854	832	828		
	Edh at Noon		72	94	104	124	132	128	124	120	105	80	67	64		
(44) All-Sky Solar Radiation	RadAvg		1.74	2.82	3.73	4.56	5.32	5.95	6.31	5.28	4.14	2.66	1.71	1.23		
	RadStd		0.20	0.31	0.36	0.49	0.43	0.48	0.24	0.36	0.30	0.35	0.17	0.12		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (56 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page