

KEY WEST INTL, FL, USA

WMO: 722010

Lat: 24.5537N

Lon: 81.7879W

Elev: 16

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 12836

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	55.0	57.8	41.8	39.1	58.9	45.5	45.0	60.9	25.5	65.6	23.8	64.7	10.0	20	0.438

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.3	90.7	79.3	89.9	79.3	89.1	79.1	81.3	87.5	80.5	87.0	80.2	86.8	9.1	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.4	152.7	85.0	78.8	149.6	84.9	78.2	146.7	84.8	44.7	87.9	44.2	87.2	43.6	86.8	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.7	19.4	18.0	50.2	93.0	3.8	2.9	47.5	95.0	45.3	96.7	43.2	98.3	40.5	100.4		
			DB	WB	44.5	82.1	4.0	0.9	41.6	82.8	39.3	83.3	37.1	83.8	34.2	84.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	78.3	69.6	71.6	73.7	77.3	80.7	83.5	84.9	85.0	83.7	80.9	75.9	72.5
	DBStd	6.56	5.98	5.55	4.74	3.27	2.54	2.07	2.00	2.07	2.07	3.18	4.11	5.44
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	63	30	15	6	0	0	0	0	0	0	0	1	11
	CDD50	10328	608	604	734	818	950	1005	1082	1084	1011	956	778	698
	CDD65	4916	172	199	275	368	485	555	617	619	561	491	329	245
	CDH74	48703	562	804	1422	2690	4913	6825	8057	8197	6978	5080	2057	1118
Wind	WSAvg	9.7	10.5	10.1	10.6	10.8	9.8	8.9	8.4	8.2	8.4	10.0	10.5	10.2
	PrecAvg	40.0	2.0	1.6	1.7	1.9	3.4	4.9	3.5	5.4	6.2	4.8	2.4	2.0
Precipitation	PrecMax	62.9	17.6	4.9	9.7	10.6	12.9	14.4	11.7	13.5	18.5	21.6	27.7	11.2
	PrecMin	20.0	0.0	0.1	0.0	0.0	0.6	0.3	0.4	2.2	1.7	0.7	0.0	0.0
	PrecStd	9.3	3.0	1.2	1.7	1.9	2.8	3.5	2.2	2.7	3.0	3.9	4.2	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	81.4	82.5	83.9	85.9	88.3	90.4	91.7	92.0	90.7	89.0	86.1	83.0
		MCWB	74.6	74.9	76.1	76.5	78.0	79.2	79.4	79.3	79.2	79.3	77.2	76.2
	2%	DB	79.9	81.1	82.5	84.4	87.1	89.1	90.5	90.8	89.5	87.5	84.2	81.6
		MCWB	73.4	74.1	75.0	75.8	77.2	79.0	79.3	79.3	79.4	78.4	76.2	75.3
	5%	DB	78.6	79.9	81.2	83.3	86.0	88.2	89.6	90.0	88.6	86.5	82.7	80.4
		MCWB	72.6	73.3	74.0	75.2	76.7	78.7	79.2	79.4	79.1	77.9	75.3	74.5
	10%	DB	77.2	78.6	79.9	82.2	85.0	87.4	88.7	89.1	87.8	85.4	81.4	79.2
		MCWB	71.8	72.6	73.0	74.4	76.2	78.4	78.9	79.2	78.7	77.3	74.6	73.8
	0.4%	WB	76.3	76.3	78.2	78.9	80.3	81.4	81.6	82.0	82.1	81.2	79.0	78.1
		MCDB	79.2	80.6	81.5	83.4	84.9	86.8	88.6	88.5	86.9	86.2	83.1	80.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	75.0	75.3	76.5	77.7	79.0	80.5	80.8	81.0	81.1	80.1	77.8	76.9
		MCDB	78.5	79.5	80.4	82.4	84.5	86.4	87.9	88.2	86.8	85.4	82.4	80.1
	5%	WB	73.7	74.4	75.5	76.6	78.2	80.1	80.3	80.4	80.3	79.2	76.7	75.8
		MCDB	77.3	78.5	79.7	81.6	83.9	86.2	87.5	87.6	86.4	84.8	81.5	79.2
	10%	WB	72.6	73.4	74.5	75.7	77.4	79.4	79.8	80.0	79.8	78.4	75.7	74.8
		MCDB	76.4	77.4	78.8	80.8	83.4	85.8	87.1	87.3	86.1	83.9	80.4	78.3
Mean Daily Temperature Range	5% DB	MDBR	9.3	9.2	9.1	8.4	8.0	7.8	7.9	8.3	8.1	7.5	7.8	8.1
		MCDBR	8.7	8.5	8.9	8.3	8.4	8.3	8.1	8.6	8.5	7.7	7.7	7.6
		MCWBR	5.6	4.9	5.1	4.8	4.3	4.3	4.1	4.1	4.1	3.9	4.2	4.5
	5% WB	MCDBR	8.5	8.2	8.7	7.9	7.8	7.7	7.8	8.3	8.0	7.3	7.5	7.0
		MCWBR	6.3	5.3	5.7	5.4	4.6	4.6	4.4	4.4	4.3	4.1	4.6	5.0
Clear-Sky Solar Irradiance	taub		0.363	0.377	0.383	0.400	0.424	0.439	0.450	0.433	0.417	0.409	0.377	0.371
	taud		2.549	2.514	2.476	2.407	2.395	2.421	2.394	2.463	2.478	2.485	2.522	2.549
	Ebn at Noon		285	288	291	286	277	271	267	273	276	274	277	277
	Edh at Noon		29	32	35	38	39	37	38	36	35	33	30	28
All-Sky Solar Radiation	RadAvg		1235	1544	1900	2143	2171	2016	2055	1951	1713	1539	1336	1174
	RadStd		97	113	82	92	186	158	98	70	92	103	73	103

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) N/A	(e) +1.60	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) -20	(l) N/A	(m) N/A
Regional (16 neighbors)	+0.61	+1.51	N/A	N/A	N/A	N/A	N/A	-27	+196	+162

Nomenclature: See separate page