

HERNANDO COUNTY AP, FL, USA

WMO: 722014

Lat: 28.474N

Lon: 82.454W

Elev: 77

StdP: 14.66

Time Zone: -5.00 (NAE)

Period: 99-19

WBAN: 12818

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.9	34.2	18.8	14.2	42.0	24.3	18.5	44.2	22.5	59.8	19.9	61.7	1.2	0	0.355

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	17.0	93.1	76.7	91.8	76.5	90.7	76.3	80.2	87.7	79.3	87.3	78.5	86.5	7.5	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.4	147.6	83.6	77.1	141.7	82.9	76.3	137.8	82.3	43.6	87.1	42.7	87.3	42.0	86.9	87.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.7	16.5	14.4	DB	24.1	96.0	4.0	1.6	21.2	97.1	18.9	98.1	16.7	99.0	13.8	100.2	
			WB	22.5	81.7	3.8	1.5	19.8	82.8	17.6	83.7	15.4	84.5	12.7	85.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	70.9	56.7	61.0	64.5	69.8	75.4	80.1	81.2	81.7	80.0	73.4	65.3	61.0
	DBStd	10.65	9.45	8.68	7.47	5.73	4.08	2.26	1.91	2.04	2.74	6.33	7.44	9.35
	HDD50	86	44	16	4	0	0	0	0	0	0	0	2	20
	HDD65	863	284	162	104	24	1	0	0	0	0	14	87	187
	CDD50	7709	253	322	452	594	787	904	967	983	899	727	460	361
	CDD65	3011	28	49	87	168	323	454	502	518	449	276	94	63
	CDH74	27102	203	389	791	1709	3284	4144	4535	4806	3857	2305	694	385
	CDH80	10477	19	63	153	504	1365	1832	1935	2077	1602	765	117	45
(14) Wind	WSAvg	5.8	6.1	6.3	6.7	6.5	6.2	5.4	4.5	4.7	5.3	5.9	5.9	6.1
(15) Precipitation	PrecAvg	51.4	2.9	2.6	3.4	2.4	3.0	7.7	8.6	8.1	6.5	2.8	1.7	2.2
	PrecMax	67.2	6.4	8.1	7.7	5.6	13.9	19.1	15.3	13.7	15.6	6.7	7.1	9.9
	PrecMin	37.8	0.7	0.2	0.2	0.2	0.4	0.9	4.0	5.0	2.1	0.0	0.0	0.3
	PrecStd	7.6	1.5	1.9	2.2	1.3	2.9	4.0	2.8	2.0	3.3	1.6	1.4	2.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.2	85.0	86.0	90.2	93.2	94.4	94.0	94.3	93.2	91.1	86.3	83.5
		MCWB	68.8	69.8	69.2	71.7	72.8	76.0	77.5	78.1	76.8	76.0	73.0	71.9
	2%	DB	79.2	81.9	83.7	87.5	90.9	92.4	92.3	92.8	91.3	88.6	83.2	81.2
		MCWB	67.3	68.4	68.1	70.7	72.5	75.8	77.3	78.0	76.3	75.0	71.0	70.2
	5%	DB	75.9	79.2	81.6	85.1	89.4	90.8	90.8	91.2	90.1	86.6	81.0	78.7
		MCWB	65.4	67.1	67.3	69.0	72.1	75.8	77.3	77.8	76.2	73.8	69.0	68.6
	10%	DB	72.3	75.5	79.2	82.8	87.5	89.3	89.5	90.0	88.4	84.4	78.6	75.3
		MCWB	64.3	64.7	65.8	68.6	72.0	75.9	77.5	77.8	76.1	72.4	67.2	67.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.4	72.2	73.8	75.9	77.7	80.2	81.5	81.4	80.3	78.5	75.4	74.0
		MCDB	78.3	80.3	80.2	84.1	87.5	88.2	87.5	88.9	87.2	85.4	82.9	79.9
	2%	WB	69.7	70.6	71.9	74.0	76.3	78.9	80.1	80.2	79.0	77.3	73.5	72.4
		MCDB	75.4	78.0	78.6	82.4	85.5	87.4	87.2	88.3	86.7	84.6	79.1	78.0
	5%	WB	67.9	69.2	70.3	72.5	75.2	78.0	79.1	79.3	78.2	76.3	71.7	70.7
		MCDB	73.4	76.3	77.1	81.2	84.1	86.5	86.7	87.7	86.0	83.3	77.0	75.9
	10%	WB	65.8	67.4	68.6	70.9	74.1	77.2	78.3	78.5	77.5	75.1	69.8	68.9
		MCDB	71.0	73.5	75.5	79.5	82.9	85.5	86.1	86.5	85.4	81.5	75.7	73.8
(35) Mean Daily Temperature Range	5% DB	MDBR	24.8	24.2	24.8	25.0	23.7	18.4	16.9	17.0	17.8	21.6	23.8	23.2
		MCDBR	25.0	25.1	25.8	26.1	25.7	21.1	19.2	19.0	19.6	20.6	23.0	21.7
		MCWBR	13.9	12.9	12.0	11.3	9.9	7.8	7.3	7.0	7.2	8.6	11.8	11.6
	5% WB	MCDBR	20.6	21.1	21.0	22.2	21.7	17.9	16.7	17.1	16.8	17.3	18.4	18.7
		MCWBR	13.0	12.1	11.7	11.4	9.9	7.7	7.6	7.2	7.0	7.8	10.6	11.8
(40) Clear-Sky Solar Irradiance	taub		0.341	0.353	0.366	0.388	0.425	0.454	0.480	0.462	0.420	0.388	0.353	0.339
	taud		2.514	2.487	2.441	2.351	2.304	2.300	2.229	2.294	2.386	2.451	2.498	2.544
	Ebn at Noon		286	291	293	288	276	266	259	263	272	275	279	281
	Edh at Noon		29	32	36	40	42	42	45	42	37	33	29	27
(44) All-Sky Solar Radiation	RadAvg		1098	1315	1677	2019	2139	1912	1802	1748	1597	1470	1198	1013
	RadStd		75	88	144	112	127	152	112	109	104	96	66	84

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (38 neighbors)	+0.76	N/A	N/A	N/A	N/A	N/A	N/A	-9	-88	+297	+211

Nomenclature: See separate page