

HERNANDO COUNTY AP, FL, USA

WMO: 722014

Lat: 28.474N

Lon: 82.454W

Elev: 24

StdP: 101.04

Time Zone: -5.00 (NAE)

Period: 99-19

WBAN: 12818

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -1.2	(c) 1.2	(d) -7.3	(e) 2.0	(f) 5.6	(g) -4.3	(h) 2.6	(i) 6.8	(j) 10.0	(k) 15.5	(l) 8.9	(m) 16.5	(n) 0.5	(o) 0	(p) 0.355

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 9.4	(c) 34.0	(d) 24.8	(e) 33.2	(f) 24.7	(g) 32.6	(h) 24.6	(i) 26.8	(j) 31.0	(k) 26.3	(l) 30.7	(m) 25.8	(n) 30.3	(o) 3.4	(p) 280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.8	21.1	28.7	25.1	20.2	28.3	24.6	19.7	27.9	83.4	30.6	81.4	30.7	79.9	30.5	30.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max					
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
8.3	7.4	6.4	DB	-4.4	35.5	2.2	0.9	-6.0	36.2	-7.3	36.7	-8.5	37.2	-10.1	37.9	
			WB	-5.3	27.6	2.1	0.8	-6.8	28.2	-8.0	28.7	-9.2	29.2	-10.7	29.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	21.6	13.7	16.1	18.0	21.0	24.1	26.7	27.3	27.6	26.6	23.0	18.5	16.1
	DBStd	5.92	5.25	4.82	4.15	3.18	2.27	1.26	1.06	1.13	1.52	3.52	4.13	5.19
	HDD10.0	48	24	9	2	0	0	0	0	0	0	0	1	11
	HDD18.3	479	158	90	58	13	1	0	0	0	0	8	48	104
	CDD10.0	4283	141	179	251	330	437	502	537	546	499	404	256	201
	CDD18.3	1673	16	27	48	93	179	252	279	288	249	153	52	35
	CDH23.3	15057	113	216	439	949	1824	2302	2519	2670	2143	1281	386	214
	CDH26.7	5821	11	35	85	280	758	1018	1075	1154	890	425	65	25
(14) Wind	WSAvg	2.6	2.7	2.8	3.0	2.9	2.8	2.4	2.0	2.1	2.4	2.7	2.6	2.7
(15) Precipitation	PrecAvg	1306	74	67	87	62	76	195	219	205	165	71	43	56
	PrecMax	1708	162	205	196	143	354	485	388	347	396	170	180	252
	PrecMin	961	18	6	4	4	10	23	101	128	53	1	0	7
	PrecStd	194	37	48	55	33	74	102	71	51	84	40	35	61
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.9	29.4	30.0	32.3	34.0	34.7	34.5	34.6	34.0	32.8	30.1	28.6
		MCWB	20.5	21.0	20.6	22.1	22.7	24.4	25.3	25.6	24.9	24.5	22.8	22.2
	2%	DB	26.2	27.7	28.7	30.9	32.7	33.6	33.5	33.8	33.0	31.5	28.4	27.3
		MCWB	19.6	20.2	20.1	21.5	22.5	24.3	25.2	25.5	24.6	23.9	21.7	21.2
	5%	DB	24.4	26.2	27.6	29.5	31.9	32.7	32.7	32.9	32.3	30.4	27.2	25.9
		MCWB	18.5	19.5	19.6	20.6	22.3	24.3	25.2	25.4	24.6	23.2	20.6	20.3
	10%	DB	22.4	24.1	26.2	28.2	30.9	31.9	31.9	32.2	31.4	29.1	25.9	24.0
		MCWB	17.9	18.2	18.8	20.4	22.2	24.4	25.3	25.4	24.5	22.4	19.6	19.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.9	22.3	23.2	24.4	25.4	26.8	27.5	27.4	26.8	25.8	24.1	23.3
		MCDB	25.7	26.8	26.8	28.9	30.8	31.2	30.8	31.6	30.7	29.7	28.3	26.6
	2%	WB	20.9	21.4	22.2	23.3	24.6	26.0	26.7	26.8	26.1	25.2	23.0	22.4
		MCDB	24.1	25.6	25.9	28.0	29.7	30.8	30.7	31.3	30.4	29.2	26.2	25.6
	5%	WB	19.9	20.7	21.3	22.5	24.0	25.6	26.2	26.3	25.7	24.6	22.1	21.5
		MCDB	23.0	24.6	25.0	27.3	29.0	30.3	30.4	30.9	30.0	28.5	25.0	24.4
	10%	WB	18.8	19.7	20.3	21.6	23.4	25.1	25.7	25.8	25.3	23.9	21.0	20.5
		MCDB	21.7	23.1	24.2	26.4	28.3	29.7	30.0	30.3	29.7	27.5	24.3	23.2
(35) Mean Daily Temperature Range	5% DB	MDBR	13.8	13.4	13.8	13.9	13.2	10.2	9.4	9.4	9.9	12.0	13.2	12.9
		MCDBR	13.9	13.9	14.3	14.5	14.3	11.7	10.6	10.5	10.9	11.4	12.8	12.0
		MCWBR	7.7	7.2	6.6	6.3	5.5	4.3	4.0	3.9	4.0	4.8	6.6	6.4
	5% WB	MCDBR	11.5	11.7	11.7	12.3	12.1	10.0	9.3	9.5	9.3	9.6	10.2	10.4
		MCWBR	7.2	6.7	6.5	6.3	5.5	4.3	4.2	4.0	3.9	4.3	5.9	6.6
(40) Clear-Sky Solar Irradiance	taub		0.341	0.353	0.366	0.388	0.425	0.454	0.480	0.462	0.420	0.388	0.353	0.339
	taud		2.514	2.487	2.441	2.351	2.304	2.300	2.229	2.294	2.386	2.451	2.498	2.544
	Ebn at Noon		901	918	923	908	870	840	816	830	858	868	880	887
	Edh at Noon		91	101	112	126	133	132	142	132	117	103	91	85
(44) All-Sky Solar Radiation	RadAvg		3.46	4.15	5.29	6.36	6.74	6.03	5.68	5.51	5.04	4.63	3.78	3.19
	RadStd		0.24	0.28	0.45	0.35	0.40	0.48	0.35	0.34	0.33	0.30	0.21	0.27

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (38 neighbors)		+0.42	N/A	N/A	N/A	N/A	N/A	-5	-49	+165	+117

Nomenclature: See separate page