

MIAMI EXECUTIVE, FL, USA

WMO: 722029

Lat: 25.648N

Lon: 80.433W

Elev: 10

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 12888

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	45.6	49.6	33.9	28.6	54.4	38.3	34.1	55.5	24.3	68.8	21.0	69.6	7.0	350	0.381

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	14.6	92.8	78.0	91.4	77.9	90.5	77.7	80.4	87.9	79.9	87.5	79.3	87.0	9.6	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.9	150.1	83.2	77.9	144.9	83.1	77.2	141.6	82.9	43.8	88.1	43.2	87.0	42.6	86.9	87.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.5	18.6	17.1	38.5	96.4	4.8	2.9	35.1	98.5	32.3	100.2	29.6	101.8	26.2	103.9		
(5)			36.1	82.6	4.6	1.7	32.8	83.9	30.1	84.9	27.5	85.9	24.1	87.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	76.1	66.7	69.2	71.3	75.2	78.9	81.9	82.9	83.1	81.9	79.0	73.0	69.5
	DBStd	7.27	6.97	6.24	5.52	4.11	3.06	2.37	2.04	2.04	2.04	3.58	4.81	6.75
	HDD50	3	2	0	0	0	0	0	0	0	0	0	0	1
	HDD65	162	67	32	16	1	0	0	0	0	0	0	6	40
	CDD50	9520	519	539	659	755	896	956	1018	1027	958	898	689	606
	CDD65	4207	120	151	210	307	431	506	553	562	508	434	245	180
	CDH74	38209	596	885	1401	2432	3991	5191	6113	6204	5109	3790	1531	966
	CDH80	13054	49	138	290	671	1374	2033	2544	2559	1846	1165	270	115
Wind	WSAvg	7.8	8.5	8.3	9.1	9.0	8.4	6.7	6.2	6.2	6.6	8.2	8.4	8.1
Precipitation	PrecAvg	62.9	2.0	2.1	2.3	2.8	6.2	10.9	6.8	9.5	9.4	6.7	2.5	1.5
	PrecMax	83.7	8.1	7.8	8.8	12.9	16.2	24.0	14.3	27.3	21.6	17.2	9.8	8.1
	PrecMin	37.2	0.2	0.0	0.1	0.0	0.2	2.1	1.4	3.5	2.7	0.9	0.1	0.1
	PrecStd	12.4	1.8	1.9	1.8	2.6	3.8	5.4	3.1	4.7	4.2	4.3	2.0	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	83.3	85.9	88.3	90.3	92.4	94.3	94.4	94.1	92.6	91.2	87.5	85.0
		MCWB	72.2	72.5	73.5	74.2	75.3	78.3	78.4	78.5	77.9	77.5	75.6	74.7
	2%	DB	81.4	83.6	85.8	88.0	90.3	91.9	92.2	92.5	90.9	89.1	84.9	82.4
		MCWB	71.2	72.2	72.9	73.5	75.1	77.8	78.2	78.5	78.1	77.1	74.6	73.2
	5%	DB	79.6	81.7	83.2	85.9	88.4	90.5	90.9	91.1	89.9	87.8	82.9	81.2
		MCWB	70.1	71.3	71.7	72.8	74.6	77.6	78.1	78.3	78.1	76.5	73.1	72.3
	10%	DB	77.7	79.7	81.2	83.9	86.9	88.9	89.9	90.1	88.3	86.0	81.3	79.4
		MCWB	68.9	69.9	70.3	71.8	74.1	77.2	78.1	78.3	77.7	75.6	71.7	71.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.9	75.4	77.8	77.5	78.4	81.0	80.9	81.4	81.1	80.1	77.9	76.4
		MCDB	80.1	81.1	83.7	85.8	86.8	89.5	88.9	88.4	87.6	86.0	83.3	81.2
	2%	WB	73.3	74.1	75.1	75.8	77.3	79.8	80.1	80.4	80.1	78.9	76.4	75.3
		MCDB	78.4	79.8	81.9	83.3	85.5	88.0	88.3	87.9	86.8	85.4	81.8	80.3
	5%	WB	72.1	73.0	73.6	74.8	76.5	78.8	79.3	79.8	79.4	78.1	75.4	74.2
		MCDB	77.1	78.8	79.9	82.1	84.4	86.7	87.7	87.6	86.1	84.6	80.7	78.9
	10%	WB	70.6	71.6	72.3	73.6	75.7	78.2	78.6	79.1	78.6	77.3	74.2	73.1
		MCDB	75.7	77.7	78.6	80.8	83.5	85.9	86.7	86.9	85.1	83.6	79.1	77.5
Mean Daily Temperature Range	5% DB	MDBR	18.3	18.3	18.5	17.5	16.3	14.9	14.8	14.6	13.7	14.1	15.9	16.5
		MCDBR	17.3	18.0	19.2	19.1	18.3	16.6	15.6	15.6	15.1	15.1	15.2	15.5
		MCWBR	8.8	8.3	8.4	7.7	6.9	6.1	5.7	5.6	5.5	5.6	6.8	7.7
	5% WB	MCDBR	15.1	15.8	17.1	16.5	15.8	15.1	14.6	14.5	13.6	13.3	13.1	13.3
		MCWBR	8.7	8.0	8.7	7.4	6.5	6.3	6.0	5.9	5.8	5.7	6.5	7.4
Clear-Sky Solar Irradiance	taub	0.364	0.377	0.388	0.399	0.427	0.458	0.464	0.454	0.432	0.416	0.382	0.373	
	taud	2.527	2.499	2.456	2.413	2.379	2.351	2.327	2.382	2.438	2.451	2.496	2.517	
	Ebn at Noon	283	286	288	286	276	266	264	267	271	270	274	274	
	Edh at Noon	30	32	36	38	39	40	41	39	36	34	30	29	
All-Sky Solar Radiation	RadAvg	1181	1424	1742	1965	1966	1780	1832	1770	1560	1443	1244	1097	
	RadStd	75	78	78	90	155	154	75	93	78	99	56	81	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.74	N/A	N/A	N/A	N/A	N/A	-2	-36	+263
(47) Regional (29 neighbors)		+0.68	+1.58	N/A	N/A	N/A	N/A	-31	+232	+193

Nomenclature: See separate page