

MIAMI EXECUTIVE, FL, USA

WMO: 722029

Lat: 25.648N

Lon: 80.433W

Elev: 3

StdP: 101.29

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 12888

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.6	9.8	1.1	4.1	12.4	3.5	4.9	13.1	10.9	20.4	9.4	20.9	3.1	350	0.381

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.1	33.8	25.6	33.0	25.5	32.5	25.4	26.9	31.0	26.6	30.8	26.3	30.5	4.3	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.1	21.4	28.4	25.5	20.7	28.4	25.1	20.2	28.3	84.1	31.2	82.5	30.6	81.3	30.5	30.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.2	8.3	7.6	DB	3.6	35.8	2.7	1.6	1.7	37.0	0.2	37.9	-1.3	38.8	-3.2	40.0
			WB	2.3	28.1	2.6	1.0	0.4	28.8	-1.1	29.4	-2.5	29.9	-4.4	30.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	24.5	19.3	20.7	21.8	24.0	26.1	27.7	28.3	28.4	27.7	26.1	22.8	20.9	(6)
(7)		DBStd	4.04	3.87	3.47	3.07	2.29	1.70	1.32	1.13	1.13	1.13	1.99	2.67	3.75	(7)
(8)		HDD10.0	2	1	0	0	0	0	0	0	0	0	0	0	1	(8)
(9)		HDD18.3	90	37	18	9	1	0	0	0	0	0	0	3	22	(9)
(10)		CDD10.0	5289	288	299	366	419	498	531	566	571	532	499	383	337	(10)
(11)		CDD18.3	2337	67	84	117	171	239	281	307	312	282	241	136	100	(11)
(12)		CDH23.3	21227	331	492	778	1351	2217	2884	3396	3447	2838	2106	851	537	(12)
(13)	CDH26.7	7252	27	77	161	373	763	1129	1413	1422	1026	647	150	64	(13)	
(14)	Wind	WSAvg	3.5	3.8	3.7	4.1	4.0	3.8	3.0	2.8	2.8	3.0	3.7	3.7	3.6	(14)
(15)	Precipitation	PrecAvg	1597	50	53	58	70	157	276	172	242	239	169	64	38	(15)
(16)		PrecMax	2127	205	199	224	327	411	609	362	694	548	436	248	205	(16)
(17)		PrecMin	945	5	0	2	1	5	54	36	90	69	24	2	2	(17)
(18)		PrecStd	314	46	48	45	65	96	137	79	120	106	108	52	37	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.5	29.9	31.3	32.4	33.5	34.6	34.7	34.5	33.7	32.9	30.8	29.5	(19)
(20)		MCWB	22.3	22.5	23.1	23.4	24.1	25.7	25.8	25.8	25.5	25.3	24.2	23.7	(20)	
(21)		2%	DB	27.4	28.6	29.9	31.1	32.4	33.3	33.5	33.6	32.7	31.7	29.4	28.0	(21)
(22)		MCWB	21.8	22.4	22.7	23.0	23.9	25.5	25.7	25.8	25.6	25.0	23.6	22.9	(22)	
(23)		5%	DB	26.5	27.6	28.4	29.9	31.3	32.5	32.7	32.8	32.2	31.0	28.3	27.4	(23)
(24)		MCWB	21.1	21.8	22.0	22.7	23.6	25.3	25.6	25.7	25.6	24.7	22.8	22.4	(24)	
(25)		10%	DB	25.4	26.5	27.3	28.8	30.5	31.6	32.2	32.3	31.3	30.0	27.4	26.3	(25)
(26)		MCWB	20.5	21.0	21.3	22.1	23.4	25.1	25.6	25.7	25.4	24.2	22.0	21.7	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.8	24.1	25.5	25.3	25.8	27.2	27.2	27.5	27.3	26.7	25.5	24.7	(27)
(28)		MADB	26.7	27.3	28.7	29.9	30.5	31.9	31.6	31.3	30.9	30.0	28.5	27.3	(28)	
(29)		2%	WB	22.9	23.4	23.9	24.3	25.2	26.6	26.7	26.9	26.7	26.0	24.7	24.1	(29)
(30)		MADB	25.8	26.6	27.7	28.5	29.7	31.1	31.3	31.1	30.4	29.7	27.7	26.8	(30)	
(31)		5%	WB	22.3	22.8	23.1	23.8	24.7	26.0	26.3	26.5	26.3	25.6	24.1	23.5	(31)
(32)		MADB	25.0	26.0	26.6	27.8	29.1	30.4	30.9	30.9	30.1	29.2	27.0	26.0	(32)	
(33)		10%	WB	21.5	22.0	22.4	23.1	24.3	25.6	25.9	26.2	25.9	25.2	23.4	22.8	(33)
(34)		MADB	24.3	25.4	25.9	27.1	28.6	29.9	30.4	30.5	29.5	28.7	26.2	25.3	(34)	
(35)	Mean Daily Temperature Range	MDBR	10.1	10.2	10.3	9.7	9.1	8.3	8.2	8.1	7.6	7.8	8.9	9.2	(35)	
(36)		5% DB	MADB	9.6	10.0	10.7	10.6	10.2	9.2	8.7	8.7	8.4	8.4	8.4	8.6	(36)
(37)		MCWBR	4.9	4.6	4.7	4.3	3.8	3.4	3.2	3.1	3.1	3.1	3.8	4.3	(37)	
(38)		5% WB	MADB	8.4	8.8	9.5	9.2	8.8	8.4	8.1	8.1	7.6	7.4	7.3	7.4	(38)
(39)		MCWBR	4.8	4.4	4.8	4.1	3.6	3.5	3.3	3.3	3.2	3.2	3.6	4.1	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.364	0.377	0.388	0.399	0.427	0.458	0.464	0.454	0.432	0.416	0.382	0.373	(40)	
(41)		taud	2.527	2.499	2.456	2.413	2.379	2.351	2.327	2.382	2.438	2.451	2.496	2.517	(41)	
(42)		Ebn at Noon	891	903	909	902	870	837	832	841	855	851	863	864	(42)	
(43)		Edh at Noon	93	102	112	119	123	126	129	122	113	106	95	91	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.72	4.49	5.49	6.20	6.20	5.61	5.78	5.58	4.92	4.55	3.92	3.46	(44)	
(45)		RadStd	0.24	0.24	0.24	0.28	0.49	0.49	0.24	0.29	0.25	0.31	0.18	0.26	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.41	N/A	N/A	N/A	N/A	N/A	-1	-20	+146	+133	(46)
(47)	Regional (29 neighbors)	+0.38	+0.88	N/A	N/A	N/A	N/A	N/A	-17	+129	+107	(47)

Nomenclature: See separate page