

PALM BEACH INTL, FL, USA

WMO: 722030

Lat: 26.685N

Lon: 80.099W

Elev: 6

StdP: 101.26

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 12844

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.0	9.2	-1.5	3.3	10.6	1.6	4.2	12.2	11.1	21.7	10.3	21.6	3.8	320	0.415

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.9	33.2	25.4	32.5	25.4	31.9	25.4	26.8	31.0	26.4	30.7	26.1	30.3	5.0	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.6	20.9	28.7	25.2	20.4	28.6	24.9	20.0	28.5	83.4	31.0	81.8	30.6	80.7	30.3	29.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.7	8.7	8.1	3.3	34.7	1.9	0.9	2.0	35.3	0.8	35.8	-0.2	36.3	-1.6	36.9		
			1.0	27.6	2.3	0.5	-0.6	28.0	-2.0	28.3	-3.2	28.6	-4.9	29.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.4	19.0	20.4	21.7	23.9	26.0	27.6	28.4	28.5	27.8	26.0	22.8	20.8
	DBStd	4.24	4.17	3.83	3.36	2.40	1.61	1.34	1.21	1.15	1.11	2.25	2.97	4.02
	HDD10.0	3	2	1	0	0	0	0	0	0	0	0	0	1
	HDD18.3	115	45	24	13	1	0	0	0	0	0	1	6	26
	CDD10.0	5271	281	291	363	418	497	528	571	574	534	497	383	336
	CDD18.3	2341	65	81	117	169	238	278	313	316	284	239	138	103
	CDH23.3	21172	243	366	631	1134	2104	2881	3583	3631	3049	2223	846	479
	CDH26.7	6643	12	38	104	217	564	1021	1463	1477	1065	553	97	32
Wind	WSAvg	4.1	4.2	4.3	4.7	4.7	4.3	3.5	3.3	3.3	3.6	4.3	4.3	4.2
Precipitation	PrecAvg	1530	78	68	89	85	137	207	148	176	219	154	102	61
	PrecMax	2101	284	221	426	320	399	510	337	497	714	476	372	187
	PrecMin	959	3	4	9	1	10	43	31	44	45	14	6	2
	PrecStd	280	77	50	81	71	104	106	71	81	123	112	86	47
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.0	29.5	31.0	31.7	32.9	34.0	34.1	34.1	32.9	31.8	29.9	28.7
		MCWB	22.1	21.8	22.7	23.1	23.7	25.8	25.5	25.8	25.4	24.8	23.9	23.4
	2%	DB	26.7	27.8	29.1	30.0	31.3	32.6	33.0	33.0	32.0	30.8	28.7	27.5
		MCWB	21.6	22.0	22.6	22.6	23.7	25.4	25.6	25.7	25.5	24.7	23.5	22.7
	5%	DB	25.7	26.8	27.7	28.9	30.4	31.7	32.3	32.4	31.4	30.1	27.8	26.7
		MCWB	21.0	21.5	22.0	22.3	23.5	25.2	25.6	25.7	25.3	24.4	22.7	22.0
	10%	DB	24.7	25.7	26.5	27.9	29.5	30.8	31.6	31.7	30.7	29.4	26.9	25.8
		MCWB	20.5	20.9	21.1	21.8	23.3	24.9	25.5	25.7	25.2	24.0	22.0	21.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.7	24.1	25.2	24.7	25.8	26.9	27.0	27.2	26.9	26.6	25.2	24.3
		MCDB	26.0	26.6	28.1	28.8	29.8	31.3	31.3	31.5	30.7	29.3	27.7	26.9
	2%	WB	22.8	23.0	23.8	24.0	25.2	26.3	26.6	26.8	26.5	25.8	24.5	23.7
		MCDB	25.3	25.7	27.0	27.8	28.9	30.6	31.1	31.2	30.3	28.9	27.2	26.2
	5%	WB	21.9	22.4	23.0	23.4	24.7	25.8	26.2	26.4	26.1	25.4	23.9	23.0
		MCDB	24.6	25.3	26.3	27.1	28.3	30.0	30.7	30.8	29.8	28.7	26.7	25.6
	10%	WB	21.2	21.8	22.2	22.8	24.2	25.5	25.8	26.1	25.7	25.0	23.1	22.4
		MCDB	24.1	24.7	25.6	26.5	27.8	29.6	30.1	30.3	29.4	28.2	26.0	25.1
Mean Daily Temperature Range	5% DB	MDBR	8.8	8.6	8.3	7.6	7.2	6.8	6.9	6.9	6.4	6.3	7.4	7.7
		MCDBR	7.8	8.3	8.7	8.4	8.3	7.7	7.4	7.4	6.9	6.5	6.8	6.8
		MCWBR	4.3	3.8	4.0	3.5	3.3	3.1	2.9	2.8	2.7	2.7	3.3	3.6
	5% WB	MCDBR	7.1	7.4	8.1	7.5	7.4	7.2	7.0	6.9	6.5	6.0	6.0	6.2
		MCWBR	4.5	4.0	4.4	3.5	3.3	3.3	3.1	3.0	2.9	2.8	3.3	3.8
Clear-Sky Solar Irradiance	taub	0.359	0.367	0.384	0.400	0.431	0.460	0.473	0.463	0.431	0.412	0.379	0.367	
	taud	2.522	2.516	2.453	2.391	2.344	2.327	2.280	2.334	2.427	2.441	2.485	2.518	
	Ebn at Noon	891	911	911	899	866	835	823	832	853	852	861	865	
	Edh at Noon	92	100	112	122	128	129	135	127	113	106	95	89	
All-Sky Solar Radiation	RadAvg	3.54	4.34	5.30	6.11	6.23	5.76	5.80	5.59	4.91	4.49	3.77	3.26	
	RadStd	0.24	0.27	0.31	0.28	0.52	0.53	0.33	0.32	0.26	0.32	0.20	0.23	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.40	+0.86	N/A	N/A	N/A	N/A	N/A	-27	+134	+107
(47)	Regional (27 neighbors)	+0.39	+0.85	N/A	N/A	N/A	N/A	N/A	-21	+138	+112

Nomenclature: See separate page