

MIAMI NORTH PERRY, FL, USA

WMO: 722037

Lat: 25.999N

Lon: 80.241W

Elev: 9

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 99-19

WBAN: 92809

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	46.4	50.5	30.6	24.8	54.4	35.7	30.7	57.5	23.6	68.4	20.9	68.7	8.0	340	0.390

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.9	92.9	77.7	91.5	77.6	90.5	77.4	80.3	87.8	79.6	87.0	79.1	86.4	10.6	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.0	150.3	82.7	77.7	143.9	82.8	77.1	141.0	82.7	43.6	86.8	42.9	86.3	42.4	86.5	84.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.6	18.8	17.2	DB	40.2	97.3	3.5	4.4	37.7	100.5	35.7	103.1	33.7	105.5	31.2	108.7	(4)
(5)			WB	35.8	81.6	3.7	1.2	33.1	82.4	31.0	83.1	28.9	83.8	26.2	84.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	76.9	67.1	70.0	72.4	76.1	79.6	82.6	83.8	84.1	82.8	79.8	73.9	70.7		
	DBStd	7.30	7.11	6.19	5.44	3.95	2.72	2.65	2.24	1.97	2.35	3.83	5.16	6.58		
	HDD50	3	2	0	0	0	0	0	0	0	0	0	0	1		
	HDD65	140	64	27	11	1	0	0	0	0	0	0	6	31		
	CDD50	9837	533	560	695	782	919	977	1047	1057	984	923	718	642		
	CDD65	4502	131	168	241	333	454	527	582	592	534	459	274	207		
	CDH74	41841	574	861	1454	2442	4161	5635	6722	6927	5791	4372	1833	1069		
	CDH80	14097	38	120	293	591	1273	2149	2813	2895	2161	1309	346	109		
(14) Wind	WSAvg	8.1	8.5	8.4	9.4	9.4	9.0	7.0	6.3	6.4	7.0	8.6	8.6	8.4		
(15) Precipitation	PrecAvg	59.6	2.1	2.4	2.6	3.2	4.6	9.1	6.1	7.0	9.8	6.9	3.0	2.2		
	PrecMax	74.4	8.1	5.4	6.4	6.6	11.1	16.1	9.9	11.7	16.7	13.6	9.6	7.0		
	PrecMin	49.4	0.5	0.0	0.3	0.7	0.0	2.9	2.9	3.0	5.3	1.7	0.5	0.5		
	PrecStd	7.2	1.6	1.7	1.5	1.7	2.6	4.3	2.0	2.4	3.3	3.9	2.5	1.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.9	85.7	88.7	90.2	91.8	94.2	94.2	94.1	93.7	91.4	89.9	84.6		
		MCWB	71.8	71.2	72.7	73.1	74.5	77.5	77.7	78.2	78.0	76.9	75.2	74.3		
	2%	DB	81.1	83.1	85.8	87.7	89.7	91.7	92.3	92.4	91.1	89.3	86.0	82.5		
		MCWB	70.7	71.2	71.9	72.9	74.3	77.4	77.8	78.2	77.8	77.0	74.8	72.8		
	5%	DB	79.4	81.4	83.2	85.3	88.0	90.3	91.0	91.2	90.0	87.9	83.6	81.2		
		MCWB	69.5	70.3	71.3	72.0	74.1	77.1	77.7	78.2	77.7	76.2	73.1	71.8		
	10%	DB	77.5	79.4	81.2	83.5	86.2	88.7	90.0	90.1	88.4	86.1	81.7	79.5		
		MCWB	68.4	69.2	70.2	71.4	73.5	76.7	77.7	78.1	77.4	75.3	71.6	70.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.9	74.1	75.6	76.4	78.1	80.2	80.5	81.4	81.3	80.0	78.3	76.0		
		MCDB	79.3	80.8	83.2	84.3	86.3	88.2	88.3	88.2	90.1	85.8	84.2	81.5		
	2%	WB	72.7	73.1	74.4	75.4	76.9	79.2	79.7	80.3	80.1	78.7	76.4	75.0		
		MCDB	78.1	79.3	81.3	82.5	84.6	87.1	87.7	87.5	87.4	84.7	82.8	80.2		
	5%	WB	71.5	72.1	73.2	74.5	76.0	78.4	79.1	79.6	79.3	78.0	75.3	73.8		
		MCDB	77.0	78.3	79.7	81.5	83.7	86.2	87.1	87.1	85.7	84.3	81.4	78.7		
	10%	WB	70.4	71.0	72.0	73.4	75.3	77.8	78.4	79.0	78.5	77.2	74.1	72.8		
		MCDB	75.8	77.2	79.0	80.3	82.9	85.6	86.3	86.5	85.0	83.6	79.9	77.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	16.7	15.9	15.7	14.7	13.6	12.9	13.0	12.9	12.2	12.3	14.4	14.5		
		MCDBR	15.4	15.6	16.6	16.3	15.3	14.2	13.9	13.9	13.2	13.2	14.2	13.5		
	5% WB	MCWBR	7.6	6.6	6.6	6.3	5.4	5.1	5.0	4.9	4.4	4.8	5.9	6.6		
		MCWBR	13.9	14.2	14.7	14.1	13.7	13.2	13.1	13.0	12.1	11.6	12.4	11.7		
(40) Clear-Sky Solar Irradiance	taub		0.364	0.372	0.386	0.401	0.428	0.463	0.468	0.460	0.435	0.415	0.381	0.373		
	taud		2.521	2.515	2.462	2.404	2.371	2.330	2.310	2.358	2.429	2.453	2.496	2.513		
	Ebn at Noon		282	288	289	285	276	264	263	265	270	270	273	273		
	Edh at Noon		30	32	35	38	39	41	42	40	36	33	30	29		
(44) All-Sky Solar Radiation	RadAvg		1160	1409	1721	1956	1971	1799	1840	1772	1561	1439	1230	1074		
(45)	RadStd		76	83	86	92	163	161	87	95	79	102	59	78		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.92	+2.05	N/A	+1.08	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)		+0.68	+1.55	N/A	N/A	N/A	N/A	N/A	-38	+234	+184

Nomenclature: See separate page