

FORT LAUDERDALE EXECUTIVE, FL, USA

WMO: 722039

Lat: 26.197N

Lon: 80.171W

Elev: 4

StdP: 101.27

Time Zone: -5.00 (NAE)

Period: 98-19

WBAN: 12885

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.9	10.2	-1.7	3.3	13.6	1.3	4.1	13.8	10.3	23.0	9.1	23.1	2.7	300	0.388

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.9	33.5	25.1	32.8	25.2	32.3	25.1	26.8	30.4	26.4	30.2	26.1	29.9	4.7	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.0	21.4	28.2	25.4	20.6	28.1	25.1	20.2	28.1	83.4	30.1	81.9	29.8	80.6	30.1	30.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.1	8.3	7.6	4.5	35.2	1.7	0.9	3.3	35.8	2.3	36.3	1.3	36.8	0.0	37.4
			1.7	27.7	2.1	1.0	0.2	28.4	-1.0	29.0	-2.2	29.6	-3.7	30.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.9	19.6	21.1	22.3	24.4	26.3	27.9	28.7	28.8	28.1	26.4	23.1	21.4	
	DBStd	4.07	4.10	3.56	3.18	2.30	1.69	1.42	1.23	1.17	1.24	2.10	2.79	3.76	
	HDD10.0	2	1	0	0	0	0	0	0	0	0	0	0	1	
	HDD18.3	85	37	16	8	1	0	0	0	0	0	1	3	19	
	CDD10.0	5423	297	312	381	433	506	537	579	584	542	507	393	352	
	CDD18.3	2466	76	94	131	183	247	287	321	326	292	249	147	113	
	CDH23.3	22708	313	459	752	1329	2263	3049	3728	3831	3179	2352	907	546	
	CDH26.7	7377	21	60	139	303	657	1115	1539	1600	1152	632	118	42	
Wind	WSAvg	3.6	3.6	3.7	4.1	4.3	4.1	3.3	3.0	3.1	3.2	3.9	3.7	3.6	
Precipitation	PrecAvg	1510	58	64	71	85	120	217	165	182	232	180	77	59	
	PrecMax	1970	192	156	190	186	306	453	272	361	407	317	267	158	
	PrecMin	1159	0	6	0	6	0	64	69	60	113	49	4	10	
	PrecStd	212	45	43	54	53	73	116	62	73	76	102	68	41	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.5	30.1	31.6	32.3	33.4	34.0	34.2	34.2	33.5	32.4	30.3	28.9	
		MCWB	21.6	21.6	22.3	22.9	23.4	25.1	25.2	25.4	25.1	24.8	24.0	23.4	
	2%	DB	27.2	28.3	29.6	30.8	32.0	32.9	33.1	33.3	32.5	31.3	28.9	27.7	
		MCWB	21.4	21.7	21.6	22.6	23.4	25.1	25.3	25.5	25.2	24.6	23.6	22.5	
	5%	DB	26.2	27.3	28.0	29.5	31.0	32.1	32.5	32.7	31.9	30.5	27.9	27.1	
		MCWB	20.7	21.3	21.5	22.2	23.4	25.0	25.3	25.5	25.2	24.3	22.6	22.0	
	10%	DB	25.2	26.2	27.1	28.4	29.9	31.2	32.0	32.2	31.2	29.6	27.2	26.2	
		MCWB	20.2	20.7	21.0	21.7	23.0	24.7	25.3	25.6	25.1	24.0	22.0	21.5	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.5	24.1	24.4	25.4	25.8	26.8	27.0	27.2	27.1	26.8	25.3	24.4
			MCDB	26.0	26.3	28.5	29.0	29.0	30.9	30.6	30.8	30.4	29.5	27.9	26.9
		2%	WB	22.7	23.0	23.4	24.2	25.1	26.1	26.6	26.8	26.6	25.8	24.6	23.8
			MCDB	25.4	26.1	27.1	27.9	28.9	30.2	30.4	30.6	30.0	28.8	27.4	26.3
5%		WB	21.9	22.4	22.8	23.6	24.6	25.7	26.1	26.4	26.1	25.4	24.0	23.2	
		MCDB	24.9	25.6	26.4	27.3	28.5	29.8	30.1	30.4	29.6	28.7	26.9	25.8	
10%		WB	21.2	21.7	22.1	23.0	24.1	25.4	25.8	26.1	25.7	25.0	23.3	22.7	
		MCDB	24.3	25.0	25.8	26.8	28.1	29.5	29.8	30.1	29.3	28.4	26.3	25.3	
Mean Daily Temperature Range	5% DB	MDBR	8.7	8.3	8.3	7.7	7.2	6.8	6.9	6.9	6.5	6.4	7.3	7.5	
		MCDBR	7.9	8.1	8.7	8.7	8.4	7.7	7.5	7.4	7.1	6.9	6.8	6.7	
		MCWBR	4.0	3.4	3.6	3.6	3.2	2.8	2.6	2.6	2.4	2.6	3.0	3.5	
	5% WB	MCDBR	7.2	7.1	7.9	7.6	7.2	7.1	7.0	7.0	6.7	6.1	6.3	6.1	
		MCWBR	4.3	3.4	3.7	3.4	3.1	2.9	2.8	2.8	2.7	2.6	3.1	3.7	
Clear-Sky Solar Irradiance	taub	0.364	0.371	0.386	0.403	0.429	0.465	0.471	0.464	0.436	0.415	0.381	0.373		
	taud	2.518	2.513	2.455	2.394	2.360	2.315	2.294	2.337	2.417	2.443	2.490	2.510		
	Ebn at Noon	888	908	909	897	867	830	825	832	849	850	861	861		
	Edh at Noon	93	100	112	122	126	131	133	127	115	106	95	91		
All-Sky Solar Radiation	RadAvg	3.62	4.41	5.38	6.14	6.21	5.69	5.80	5.58	4.91	4.52	3.85	3.35		
	RadStd	0.24	0.27	0.28	0.29	0.52	0.52	0.29	0.30	0.25	0.32	0.19	0.24		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.51	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+187	+181
(47)	Regional (28 neighbors)	+0.40	+0.89	N/A	N/A	N/A	N/A	N/A	-21	+137	+109

Nomenclature: See separate page