

SOUTH LAFOURCHE, LA, USA

WMO: 722041

Lat: 29.445N

Lon: 90.261W

Elev: 0

StdP: 101.32

Time Zone: -6.00 (NAC)

Period: 05-19

WBAN: 12993

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.1	2.0	-5.6	2.4	4.1	-2.9	3.0	6.3	10.7	11.4	9.4	11.4	2.3	10	0.374

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.9	34.1	25.9	33.0	25.8	32.6	25.7	28.1	31.1	27.4	30.5	26.9	30.3	2.8	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.5	23.3	29.3	26.8	22.4	29.0	26.1	21.5	28.7	90.2	30.0	86.3	30.7	84.1	31.3	31.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.0	8.0	7.1	-2.7	35.9	2.2	1.1	-4.3	36.6	-5.6	37.2	-6.8	37.8	-8.4	38.6		
(5)			-6.5	28.9	9.7	1.6	-13.5	30.0	-19.2	30.9	-24.7	31.8	-31.7	32.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	20.8	12.1	14.5	17.4	20.5	24.1	27.2	27.6	27.9	26.5	21.7	16.4	13.9		
	DBStd	6.72	5.27	5.02	4.47	3.42	2.69	1.61	1.35	1.84	2.04	4.07	4.68	5.08		
	HDD10.0	82	38	14	4	0	0	0	0	0	0	0	6	20		
	HDD18.3	682	202	126	71	19	1	0	0	0	0	17	91	156		
	CDD10.0	4041	104	141	233	316	438	515	546	553	496	363	196	140		
	CDD18.3	1600	10	19	43	84	181	265	288	295	246	122	31	17		
	CDH23.3	15668	23	62	196	584	1696	3004	3098	3287	2448	1049	163	56		
(13)	CDH26.7	5834	0	2	9	67	504	1306	1308	1426	927	272	13	1		
(14)	Wind	WSAvg	2.8	3.5	3.6	3.4	3.4	2.7	2.2	1.8	1.9	2.6	2.8	3.4		
(15) Precipitation	PrecAvg	1616	136	103	113	88	111	169	205	183	160	123	104	120		
	PrecMax	2316	464	246	286	374	318	416	303	434	523	368	386	365		
	PrecMin	1156	2	16	4	1	0	52	73	62	42	15	8	39		
	PrecStd	305	120	67	64	82	87	84	67	99	117	87	90	88		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.2	27.0	27.7	29.2	32.5	34.9	34.9	35.3	34.5	32.4	28.0	26.5		
		MCWB	21.7	21.8	21.8	22.9	23.9	26.7	26.2	26.3	25.4	25.0	22.4	22.4		
	2%	DB	23.8	25.3	26.8	28.0	31.3	33.1	33.4	34.3	32.9	30.9	26.7	25.1		
		MCWB	20.5	21.0	21.5	22.5	23.8	25.6	26.0	26.3	25.4	24.2	21.6	21.6		
	5%	DB	22.3	23.8	25.7	27.5	30.4	32.7	32.7	33.0	32.2	29.7	25.4	23.1		
		MCWB	19.4	20.3	21.1	22.1	23.7	25.5	26.0	26.2	25.2	23.5	20.7	20.2		
	10%	DB	20.6	22.5	24.2	26.5	29.6	32.1	32.2	32.5	31.3	28.0	23.7	21.8		
		MCWB	18.2	19.7	20.3	21.4	23.5	25.3	25.9	26.2	24.9	22.5	19.8	19.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.7	22.9	23.6	24.9	25.7	30.4	28.7	28.8	27.5	27.0	24.1	23.7		
		MCDB	24.7	25.8	25.9	27.1	29.3	32.8	31.3	31.5	30.5	29.8	26.4	25.8		
	2%	WB	21.4	21.8	22.8	24.1	25.2	28.6	27.5	27.9	26.8	25.8	22.9	22.0		
		MCDB	23.1	24.4	25.4	27.0	29.1	31.4	30.7	31.1	30.3	28.6	25.2	24.3		
	5%	WB	20.2	21.0	22.0	23.4	24.7	27.0	27.0	27.4	26.3	25.1	21.8	21.1		
		MCDB	21.6	23.2	24.7	26.3	28.6	30.1	30.5	30.6	30.1	28.0	24.2	22.9		
	10%	WB	18.3	20.0	21.2	22.8	24.2	26.1	26.5	27.0	25.8	24.1	20.8	19.9		
		MCDB	20.3	22.2	23.6	25.6	28.1	30.0	30.2	30.4	29.5	27.3	23.4	21.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.1	9.9	10.3	10.1	9.7	9.4	8.7	8.9	9.0	10.7	11.4	9.5		
		MCDBR	10.7	9.6	9.5	9.9	9.9	10.2	9.6	9.5	9.7	10.1	11.0	10.0		
		MCWBR	7.7	6.4	5.7	5.4	4.2	4.4	4.1	3.7	4.1	5.1	6.8	7.3		
	5% WB	MCDBR	9.0	8.4	8.5	8.3	8.5	9.0	8.6	8.7	8.4	8.5	10.5	9.3		
		MCWBR	7.2	6.3	5.8	5.3	4.0	4.6	4.4	4.1	4.0	5.1	7.6	7.3		
(40) Clear-Sky Solar Irradiance	taub		0.346	0.362	0.377	0.422	0.446	0.465	0.500	0.500	0.444	0.388	0.362	0.351		
	taud		2.520	2.494	2.435	2.310	2.281	2.274	2.201	2.197	2.321	2.469	2.481	2.521		
	Ebn at Noon		891	905	911	876	851	830	799	797	833	865	863	867		
	Edh at Noon		89	99	112	131	136	136	146	145	124	101	92	86		
(44) All-Sky Solar Radiation	RadAvg		3.07	3.65	4.92	5.91	6.49	6.08	5.63	5.31	5.13	4.61	3.52	2.75		
	RadStd		0.25	0.46	0.43	0.52	0.32	0.49	0.41	0.48	0.41	0.46	0.32	0.24		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (21 neighbors)	+0.42	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+141	+96

Nomenclature: See separate page