

POMPAÑO BEACH, FL, USA

WMO: 722049

Lat: 26.250N

Lon: 80.108W

Elev: 21

StdP: 14.68

Time Zone: -5.00 (NAE)

Period: 98-19

WBAN: 92805

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	46.4	50.6	28.8	22.8	57.4	34.1	28.8	57.5	24.5	69.2	22.5	69.1	9.4	330	0.428

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.6	91.1	78.0	90.2	78.2	89.3	78.3	80.6	87.3	80.1	86.9	79.5	86.4	12.0	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.1	151.0	84.0	78.3	146.9	84.0	77.3	142.3	83.8	44.1	87.5	43.4	86.6	42.8	86.2	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.2	19.4	18.0	40.1	96.0	3.2	4.3	37.8	99.1	36.0	101.6	34.2	103.9	31.9	107.0		
			35.1	81.8	3.6	1.1	32.6	82.5	30.5	83.1	28.5	83.7	25.9	84.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	76.8	67.4	70.0	72.1	75.8	79.1	82.1	83.5	83.8	82.5	79.5	74.0	70.8	(6)
(7)		DBStd	7.25	7.47	6.51	5.59	3.99	2.75	2.52	2.31	1.96	2.39	3.87	5.18	6.95	(7)
(8)		HDD50	3	2	0	0	0	0	0	0	0	0	0	0	1	(8)
(9)		HDD65	153	66	30	15	1	0	0	0	0	0	1	7	33	(9)
(10)		CDD50	9768	542	561	685	774	901	964	1039	1047	976	913	719	647	(10)
(11)		CDD65	4443	142	170	235	325	436	514	574	582	526	449	276	214	(11)
(12)		CDH74	41376	509	747	1210	2191	3912	5650	6866	7082	5957	4384	1790	1078	(12)
(13)		CDH80	12745	19	66	163	369	914	1969	2812	2924	2141	1102	199	67	(13)
(14)	Wind	WSAvg	9.4	10.0	9.8	10.7	10.7	10.0	8.2	7.7	7.8	8.0	10.3	10.3	10.0	(14)
(15)	Precipitation	PrecAvg	59.0	2.4	2.4	3.0	3.2	5.0	8.6	6.6	7.4	8.6	6.4	3.0	2.3	(15)
(16)		PrecMax	77.1	7.9	6.1	7.6	7.0	11.8	18.0	10.5	14.7	15.8	11.4	10.3	6.1	(16)
(17)		PrecMin	46.4	0.2	0.3	0.1	0.2	0.2	3.1	3.0	3.0	4.8	1.4	0.2	0.6	(17)
(18)		PrecStd	8.2	1.9	1.6	2.1	2.0	2.9	4.4	2.3	2.8	2.7	3.7	2.6	1.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.2	84.8	87.8	88.8	90.6	92.5	92.9	92.0	92.6	89.7	85.6	83.7	(19)
(20)			MCWB	72.4	71.3	72.7	73.1	74.1	78.0	77.5	78.4	77.6	77.0	75.8	74.4	(20)
(21)		2%	DB	80.0	81.9	83.6	85.4	87.3	90.2	90.5	90.5	90.0	87.6	83.7	81.5	(21)
(22)			MCWB	71.3	72.2	72.9	73.4	75.1	78.2	78.4	78.7	78.1	77.0	74.9	73.1	(22)
(23)		5%	DB	78.7	80.1	81.6	83.7	85.7	88.7	89.8	89.9	88.5	86.1	82.1	80.5	(23)
(24)			MCWB	70.5	71.2	72.0	73.0	74.9	78.0	78.5	78.7	78.0	76.2	73.6	72.5	(24)
(25)		10%	DB	77.0	78.6	79.8	81.9	84.3	87.6	88.5	88.8	87.6	84.6	81.0	79.1	(25)
(26)			MCWB	69.5	70.4	70.6	71.6	74.2	77.5	78.1	78.5	77.8	75.7	72.7	71.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.0	75.4	77.7	77.4	78.5	81.1	81.1	81.3	81.3	80.3	79.0	76.5	(27)
(28)			MCDWB	79.0	80.3	82.5	83.6	84.6	88.8	88.5	88.0	87.3	84.8	82.3	80.2	(28)
(29)		2%	WB	73.5	74.2	75.2	76.0	77.4	80.0	80.2	80.4	80.4	79.1	76.9	75.4	(29)
(30)			MCDWB	77.9	79.2	80.7	81.9	83.5	87.2	87.8	87.4	86.5	83.9	81.8	79.4	(30)
(31)		5%	WB	72.3	73.1	73.9	75.0	76.5	79.1	79.5	80.0	79.6	78.2	75.6	74.4	(31)
(32)			MCDWB	76.8	78.1	79.4	80.9	82.7	86.0	87.2	87.2	85.8	83.5	80.6	78.7	(32)
(33)		10%	WB	70.9	72.0	72.6	73.8	75.8	78.3	78.8	79.3	78.7	77.5	74.4	73.3	(33)
(34)			MCDWB	75.6	76.9	78.2	80.1	82.0	85.1	86.4	86.7	85.0	83.1	79.7	78.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	14.1	13.3	13.1	11.9	10.9	10.4	10.6	10.6	10.1	9.9	11.8	12.2	(35)
(36)			MCDBR	11.8	12.5	13.6	13.5	12.3	11.8	11.4	11.4	11.0	10.5	10.6	10.2	(36)
(37)			MCWBR	6.9	6.1	6.8	6.7	5.6	5.2	5.5	5.2	4.6	4.8	5.4	5.6	(37)
(38)		5% WB	MCDWB	11.1	10.9	12.8	11.9	11.0	10.9	10.5	10.5	10.2	9.7	9.4	9.4	(38)
(39)			MCWBR	7.5	6.0	7.2	6.9	5.7	5.5	5.7	5.6	4.9	5.2	5.5	5.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.363	0.372	0.387	0.404	0.430	0.465	0.471	0.465	0.436	0.416	0.381	0.372	(40)	
(41)		taud	2.518	2.510	2.452	2.393	2.359	2.316	2.294	2.336	2.418	2.441	2.490	2.511	(41)	
(42)		Ebn at Noon	282	288	288	284	275	264	262	264	270	270	273	273	(42)	
(43)		Edh at Noon	30	32	36	39	40	42	42	40	36	34	30	29	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1145	1398	1707	1950	1977	1817	1847	1778	1562	1436	1219	1059	(44)	
(45)		RadStd	77	87	92	93	167	166	94	97	81	103	62	76	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.06	+2.79	+3.06	+0.83	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (26 neighbors)	+0.68	+1.55	N/A	N/A	N/A	N/A	N/A	-38	+234	+184

Nomenclature: See separate page