

OCALA, FL, USA

WMO: 722055

Lat: 29.167N

Lon: 82.233W

Elev: 27

StdP: 101.01

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 12861

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.3	1.1	-8.6	1.8	4.8	-6.3	2.2	6.5	9.1	20.1	8.3	19.2	0.8	0	0.327

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.6	34.0	24.2	33.0	24.3	32.5	24.2	26.4	31.0	25.8	30.5	25.5	30.3	3.1	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.2	20.4	28.2	24.6	19.7	27.9	24.1	19.0	27.5	81.9	30.9	79.9	30.8	78.0	30.5	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.0	6.9	5.6	-5.3	36.2	1.9	0.9	-6.7	36.8	-7.8	37.4	-8.9	37.8	-10.3	38.5		
			-6.1	27.0	1.8	0.8	-7.4	27.6	-8.4	28.1	-9.5	28.5	-10.8	29.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.1	13.4	15.3	17.3	20.3	24.2	26.6	27.2	27.2	26.2	22.6	17.6	14.9	
	DBStd	6.13	5.29	4.92	4.25	3.35	2.27	1.64	1.10	1.11	1.61	3.72	4.08	5.03	
	HDD10.0	60	28	12	4	0	0	0	0	0	0	0	2	14	
	HDD18.3	562	167	106	69	19	1	0	0	0	0	12	59	128	
	CDD10.0	4114	132	161	231	310	441	497	534	533	487	391	231	167	
	CDD18.3	1573	13	21	37	79	182	247	276	275	237	145	38	22	
	CDH23.3	13742	86	172	362	786	1848	2173	2420	2419	1961	1104	281	129	
CDH26.7	5283	5	26	64	217	788	962	1022	1019	789	341	41	9		
Wind	WSAvg	2.1	2.4	2.5	2.6	2.4	2.2	2.0	1.7	1.7	2.0	2.0	2.1	2.2	
Precipitation	PrecAvg	1267	70	69	102	63	65	202	169	161	168	98	43	63	
	PrecMax	1673	212	246	214	171	200	312	274	270	490	206	113	231	
	PrecMin	783	7	11	0	22	7	35	102	84	37	16	9	9	
	PrecStd	222	50	60	62	37	46	67	41	47	107	54	28	59	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.4	28.9	30.1	32.1	34.1	36.1	34.2	34.2	33.7	32.5	29.1	27.7	
		MCWB	19.9	20.8	21.1	21.0	22.1	24.2	25.1	25.1	24.0	24.4	22.5	21.0	
	2%	DB	26.0	27.4	28.2	30.4	32.9	34.0	33.5	33.3	32.7	31.3	27.8	26.6	
		MCWB	19.0	19.7	19.7	20.7	22.1	23.9	25.0	25.1	24.2	23.7	20.9	20.2	
	5%	DB	23.9	26.0	27.3	29.0	32.3	32.8	32.6	32.6	32.2	30.0	26.7	24.9	
		MCWB	18.1	18.8	18.7	20.1	21.7	24.1	25.0	25.1	24.2	23.2	19.9	19.4	
	10%	DB	22.3	23.4	25.9	27.7	31.1	32.0	32.0	32.0	31.2	28.7	25.0	22.7	
		MCWB	17.6	17.3	17.8	19.3	21.6	24.0	25.0	25.1	24.1	22.4	18.9	18.5	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.4	21.9	22.7	23.1	24.8	26.6	26.9	27.3	26.4	25.7	23.6	22.8
			MCDB	25.0	26.5	26.6	27.9	30.4	31.8	31.2	30.9	30.7	29.9	27.5	25.4
		2%	WB	20.3	20.9	21.3	22.3	24.0	25.7	26.2	26.4	25.7	25.0	22.5	21.4
			MCDB	23.9	25.5	25.9	27.6	29.6	31.0	30.9	30.8	30.2	29.0	26.1	24.4
5%		WB	19.3	20.0	20.4	21.5	23.3	25.2	25.7	25.8	25.2	24.3	21.3	20.5	
		MCDB	22.5	24.3	24.9	26.9	28.9	30.3	30.6	30.4	29.8	28.1	24.7	23.5	
10%		WB	18.2	18.9	19.4	20.7	22.7	24.6	25.3	25.5	24.7	23.6	20.3	19.4	
		MCDB	21.3	22.6	23.7	25.8	28.3	29.6	30.3	30.2	29.2	27.0	23.8	22.4	
Mean Daily Temperature Range	5% DB	MDBR	13.4	13.4	13.7	13.9	13.2	10.4	9.7	9.6	9.8	11.2	12.8	12.4	
		MCDBR	13.5	13.9	14.8	14.4	14.6	12.2	10.8	10.8	11.1	10.9	12.9	12.3	
		MCWBR	8.1	7.1	7.1	6.2	5.3	4.3	4.2	4.1	4.3	4.7	7.2	7.1	
	5% WB	MCDBR	11.3	12.0	11.9	12.3	12.0	10.3	9.7	9.5	9.4	9.1	10.9	10.6	
		MCWBR	7.3	6.8	6.7	6.0	4.8	4.2	4.2	4.0	3.9	4.2	6.7	7.1	
Clear-Sky Solar Irradiance	taub	0.336	0.350	0.365	0.387	0.426	0.456	0.493	0.470	0.422	0.391	0.352	0.339		
	taud	2.519	2.484	2.441	2.360	2.301	2.288	2.182	2.264	2.384	2.437	2.494	2.530		
	Ebn at Noon	904	919	923	908	869	838	805	823	855	862	877	882		
	Edh at Noon	89	100	111	125	133	134	148	136	117	104	91	85		
All-Sky Solar Radiation	RadAvg	3.35	3.98	5.13	6.16	6.50	5.83	5.59	5.36	4.87	4.44	3.64	3.06		
	RadStd	0.23	0.34	0.43	0.37	0.41	0.43	0.39	0.36	0.36	0.33	0.20	0.26		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
Regional (44 neighbors)	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	-6	-52	+159	+115

Nomenclature: See separate page