

ORLANDO SANFORD, FL, USA

WMO: 722057

Lat: 28.780N

Lon: 81.244W

Elev: 17

StdP: 101.12

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 12854

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.9	5.2	-7.0	2.1	7.8	-3.8	2.8	9.2	10.6	16.1	9.3	17.2	3.4	300	0.369

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.2	34.7	24.4	33.8	24.4	33.0	24.3	26.2	31.1	25.8	30.6	25.6	30.3	3.7	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.1	20.2	27.7	24.7	19.7	27.5	24.2	19.2	27.4	81.2	31.2	79.5	30.7	78.1	30.3	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.9	8.0	7.2	-0.4	36.2	1.9	1.0	-1.8	36.9	-2.9	37.5	-4.0	38.1	-5.4	38.8
			-2.5	27.0	1.9	0.6	-3.9	27.4	-5.0	27.8	-6.1	28.1	-7.5	28.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	22.7	15.4	17.3	19.3	22.3	25.3	27.5	28.4	28.3	27.2	24.1	19.9	17.4	
	DBStd	5.50	4.65	4.39	3.83	2.88	2.20	1.61	1.30	1.24	1.36	2.94	3.60	4.52	
	HDD10.0	19	11	4	1	0	0	0	0	0	0	0	0	4	
	HDD18.3	321	112	65	37	6	0	0	0	0	0	3	26	73	
	CDD10.0	4661	179	208	288	368	474	525	569	515	436	297	233		
	CDD18.3	1921	22	36	66	124	216	275	311	310	265	181	73	43	
	CDH23.3	16587	126	227	473	958	1898	2514	3107	3079	2308	1290	391	216	
CDH26.7	6196	9	34	102	285	775	1064	1329	1267	860	380	66	25		
Wind	WSAvg	3.2	3.4	3.4	3.7	3.6	3.4	3.0	2.7	2.7	2.9	3.1	3.2	3.1	
Precipitation	PrecAvg	1314	50	51	79	54	92	203	184	192	186	98	50	54	
	PrecMax	1664	146	94	225	116	465	435	299	462	388	281	181	235	
	PrecMin	984	0	10	0	29	24	127	53	65	100	18	3	10	
	PrecStd	211	37	30	72	23	99	80	65	104	93	69	40	52	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.8	29.3	31.1	32.5	34.9	36.1	35.9	35.3	34.0	32.5	30.2	28.6	
		MCWB	20.4	20.9	21.2	21.5	22.2	24.2	24.8	24.9	24.6	24.4	22.7	22.0	
	2%	DB	26.3	27.7	29.0	31.0	33.3	34.2	34.4	34.2	32.8	31.3	28.5	27.4	
		MCWB	19.2	20.1	20.2	21.2	22.1	24.3	24.7	25.0	24.3	23.9	21.9	20.9	
	5%	DB	24.8	26.3	27.7	29.6	32.2	33.0	33.6	33.3	32.2	30.1	27.2	26.0	
		MCWB	18.6	19.1	19.5	20.6	22.0	24.0	24.8	25.0	24.3	23.1	20.9	20.3	
	10%	DB	22.9	24.4	26.3	28.2	31.0	32.1	32.5	32.4	31.2	28.9	25.9	24.1	
		MCWB	18.0	18.3	18.7	20.0	21.9	24.1	24.8	25.0	24.2	22.5	19.9	19.5	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.8	22.5	23.0	23.8	24.7	26.3	26.7	26.8	26.5	25.7	24.2	23.1
			MCDB	25.6	26.2	27.3	28.6	29.9	31.5	31.9	31.7	30.6	29.6	27.4	26.6
		2%	WB	20.7	21.3	21.8	22.9	24.1	25.6	26.1	26.2	25.8	25.1	23.2	22.2
			MCDB	24.3	25.3	26.1	27.7	29.2	30.9	31.3	31.1	30.0	28.9	26.3	25.4
5%		WB	19.8	20.5	21.0	22.2	23.6	25.2	25.7	25.8	25.4	24.5	22.3	21.3	
		MCDB	23.3	24.5	25.5	27.1	28.6	30.4	30.7	30.5	29.6	28.1	25.4	24.3	
10%		WB	18.8	19.5	20.1	21.4	23.0	24.8	25.4	25.5	25.0	24.0	21.3	20.4	
		MCDB	22.1	23.4	24.5	26.2	28.0	29.6	30.2	30.1	29.0	27.3	24.4	23.3	
Mean Daily Temperature Range	5% DB	MDBR	11.2	11.3	11.6	11.4	10.9	9.3	9.2	8.8	8.4	9.2	10.2	10.5	
		MCDBR	11.7	12.0	12.3	12.1	12.2	10.6	10.0	9.7	9.4	9.3	10.3	10.6	
		MCWBR	6.0	5.4	5.0	4.3	3.6	3.2	3.1	2.9	3.0	3.4	4.8	5.1	
	5% WB	MCDBR	10.5	10.6	10.7	10.9	10.3	9.3	9.2	8.8	8.2	8.1	8.9	9.4	
		MCWBR	6.1	5.5	5.2	4.5	3.7	3.3	3.2	3.1	3.0	3.2	4.8	5.4	
Clear-Sky Solar Irradiance	taub	0.339	0.353	0.376	0.394	0.427	0.457	0.480	0.470	0.423	0.397	0.358	0.347		
	taud	2.525	2.496	2.424	2.353	2.306	2.293	2.226	2.269	2.396	2.436	2.497	2.524		
	Ebn at Noon	902	917	913	902	868	837	816	823	855	858	872	875		
	Edh at Noon	89	100	114	126	132	133	142	135	116	105	91	86		
All-Sky Solar Radiation	RadAvg	3.35	4.00	5.10	6.09	6.33	5.76	5.74	5.45	4.84	4.37	3.57	3.06		
	RadStd	0.25	0.29	0.39	0.32	0.43	0.53	0.33	0.36	0.31	0.31	0.20	0.24		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.42	N/A	N/A	N/A	+0.22	+0.56	-7	-73	+187	+141
(47)	Regional (43 neighbors)	+0.42	N/A	N/A	N/A	N/A	N/A	-6	-47	+150	+109

Nomenclature: See separate page