

JACKSONVILLE NAS, FL, USA

WMO: 722065

Lat: 30.233N

Lon: 81.667W

Elev: 6

StdP: 101.25

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 93837

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 1.3	(c) 3.3	(d) -9.9	(e) 1.6	(f) 5.6	(g) -7.1	(h) 2.1	(i) 6.9	(j) 11.1	(k) 11.5	(l) 10.1	(m) 12.2	(n) 4.3	(o) 320	(p) 0.418

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.4	35.6	24.8	34.4	24.6	33.4	24.4	26.8	31.1	26.3	30.8	25.8	30.3	4.0	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.9	21.2	28.5	25.2	20.3	28.2	24.7	19.7	28.1	83.8	30.8	81.5	30.9	79.6	30.3	32.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.7	8.4	7.6	-2.1	37.3	2.5	1.4	-3.9	38.3	-5.3	39.1	-6.7	39.9	-8.5	41.0
			-4.4	27.9	2.2	1.3	-6.0	28.9	-7.2	29.6	-8.4	30.4	-10.0	31.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	22.1	13.4	15.6	18.3	21.9	25.5	28.0	29.0	28.8	27.4	23.4	18.4	15.4
	DBStd	6.52	5.07	4.68	4.33	3.49	2.60	1.95	1.58	1.59	1.89	3.50	4.19	5.00
	HDD10.0	49	25	8	2	0	0	0	0	0	0	0	1	12
	HDD18.3	503	164	99	56	12	0	0	0	0	0	6	50	117
	CDD10.0	4469	132	164	259	356	480	539	588	584	521	415	253	179
	CDD18.3	1883	12	22	54	117	222	289	329	326	271	163	52	26
	CDH23.3	17664	43	103	306	776	1911	2937	3716	3664	2698	1174	239	96
	CDH26.7	6631	2	11	57	218	707	1208	1628	1532	937	287	36	9
Wind	WSAvg	3.7	3.7	3.8	4.1	4.1	4.0	3.6	3.4	3.4	3.7	3.8	3.8	3.5
Precipitation	PrecAvg	1177	73	74	93	59	82	142	155	166	165	61	52	65
	PrecMax	1834	189	180	236	226	278	318	343	453	405	209	188	202
	PrecMin	629	7	13	11	11	12	32	60	63	5	1	0	6
	PrecStd	269	43	44	66	41	66	66	62	85	105	47	39	48
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.7	28.0	30.2	32.4	35.0	37.6	36.9	36.6	34.5	32.3	29.6	27.9
		MCWB	19.9	20.0	20.3	21.3	22.6	25.1	25.1	25.4	24.2	24.2	22.2	21.6
	2%	DB	24.4	26.3	28.2	30.8	33.4	35.3	35.3	34.9	33.1	30.7	27.5	25.9
		MCWB	18.9	19.2	19.7	21.1	22.3	24.4	25.1	25.2	24.0	23.5	21.5	20.6
	5%	DB	22.7	24.3	26.7	29.1	32.1	33.7	34.1	33.7	32.1	29.5	26.1	24.1
		MCWB	17.9	18.1	18.9	20.3	22.0	24.3	24.9	25.1	24.2	22.8	20.6	19.8
	10%	DB	21.0	22.5	24.9	27.6	30.6	32.2	32.9	32.6	31.1	28.3	24.4	22.4
		MCWB	17.0	17.4	18.0	19.6	21.8	24.0	24.8	25.1	24.0	22.3	19.8	19.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.5	21.3	22.9	23.6	25.2	26.8	27.6	27.9	27.4	26.2	24.3	22.8
		MCDB	24.3	25.2	26.7	28.6	31.0	32.6	32.2	32.3	29.4	28.9	27.8	25.9
	2%	WB	20.1	20.5	21.2	22.7	24.4	25.9	26.7	26.8	26.4	25.4	23.0	21.6
		MCDB	23.1	24.5	25.3	27.5	29.5	31.7	31.6	31.5	29.2	28.6	25.8	24.6
	5%	WB	18.9	19.5	20.3	21.9	23.8	25.4	26.1	26.3	25.8	24.6	21.9	20.7
		MCDB	21.6	23.0	24.4	26.3	28.6	30.9	31.0	30.9	29.0	27.7	24.4	23.3
	10%	WB	17.8	18.4	19.5	21.2	23.1	25.0	25.6	25.8	25.3	23.9	20.9	19.6
		MCDB	20.4	21.5	23.5	25.6	27.7	30.0	30.5	30.2	28.9	26.9	23.8	21.8
Mean Daily Temperature Range	5% DB	MDBR	9.9	9.8	10.0	9.8	9.2	8.4	8.4	7.7	7.1	7.9	9.1	9.1
		MCDBR	10.6	10.8	11.3	10.9	11.0	10.6	9.6	9.2	8.5	8.2	9.3	9.4
		MCWBR	6.2	5.2	4.9	4.1	3.7	3.4	3.1	3.0	2.9	3.3	4.6	5.1
	5% WB	MCDBR	9.2	9.5	9.8	9.2	9.2	9.3	8.6	8.1	7.1	6.7	7.6	8.4
		MCWBR	6.0	5.6	5.1	4.5	3.7	3.3	3.3	3.1	3.0	3.1	4.5	5.3
Clear-Sky Solar Irradiance	taub	0.337	0.349	0.372	0.394	0.436	0.478	0.505	0.490	0.428	0.400	0.360	0.345	
	taud	2.529	2.502	2.445	2.369	2.290	2.235	2.163	2.212	2.381	2.426	2.487	2.531	
	Ebn at Noon	896	916	914	900	859	819	795	804	846	848	861	868	
	Edh at Noon	87	98	110	123	134	141	151	143	116	104	91	84	
All-Sky Solar Radiation	RadAvg	3.13	3.75	4.89	5.97	6.38	5.92	5.87	5.48	4.75	4.21	3.41	2.83	
	RadStd	0.22	0.42	0.44	0.38	0.39	0.40	0.38	0.36	0.39	0.36	0.20	0.24	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.58	+1.10	N/A	N/A	N/A	N/A	-77	+178	+159
(47) Regional (33 neighbors)		+0.43	N/A	N/A	N/A	N/A	N/A	-11	-65	+166

Nomenclature: See separate page