

MAYPORT NAF, FL, USA

WMO: 722066

Lat: 30.400N

Lon: 81.417W

Elev: 16

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 03853

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	34.6	38.7	17.0	13.0	40.1	22.2	16.7	44.3	24.5	53.4	21.9	53.2	6.8	310	0.409

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.8	93.4	77.0	91.3	77.2	89.6	77.1	80.4	87.9	79.7	87.2	78.7	86.0	8.5	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.6	148.5	84.4	77.4	142.8	83.6	76.7	139.2	83.1	43.9	88.3	43.0	87.1	42.2	86.2	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
22.9	19.5	17.4	DB	25.3	97.0	13.0	2.1	15.9	98.4	8.3	99.7	1.0	100.8	-8.4	102.3
			WB	21.9	81.8	11.3	2.0	13.8	83.2	7.2	84.3	0.9	85.4	-7.3	86.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	70.4	55.3	58.7	63.2	69.4	75.9	80.9	82.5	82.4	80.0	73.2	64.0	58.7	(6)
	DBStd	11.45	8.38	8.36	7.48	5.49	4.47	3.21	2.60	2.34	3.15	7.11	7.45	8.05	(7)
	HDD50	100	45	20	7	0	0	0	0	0	0	5	3	20	(8)
	HDD65	1011	313	204	121	23	2	0	0	0	0	19	106	223	(9)
	CDD50	7551	210	264	416	581	803	927	1008	1006	899	724	423	290	(10)
	CDD65	2986	13	28	65	155	339	477	543	541	449	272	76	28	(11)
	CDH74	25959	35	109	267	733	2469	4586	5779	5720	4203	1729	251	78	(12)
	CDH80	8290	1	11	41	123	654	1639	2251	2049	1200	290	27	4	(13)
(14) Wind	WSAvg	8.3	7.6	7.9	8.8	9.0	9.0	8.2	7.3	7.7	8.9	9.1	8.4	7.6	(14)
(15) Precipitation	PrecAvg	44.2	2.6	3.7	3.1	2.2	2.4	5.1	5.4	5.3	6.3	3.3	1.9	2.5	(15)
	PrecMax	75.9	7.9	10.0	8.9	7.5	11.9	12.8	16.3	11.3	21.1	11.0	5.4	8.1	(16)
	PrecMin	27.8	0.2	0.2	0.5	0.4	0.2	0.6	1.3	1.9	1.0	0.2	0.1	0.4	(17)
	PrecStd	12.3	1.9	2.5	2.4	1.7	2.3	3.3	3.3	2.5	4.5	2.5	1.3	2.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.2	81.7	84.6	87.2	92.8	96.2	97.1	95.4	91.9	88.0	83.1	80.3	(19)
		MCWB	68.0	68.1	67.3	69.3	73.2	77.0	77.4	78.2	76.5	75.6	72.8	70.8	(20)
	2%	DB	73.5	77.5	80.1	83.3	88.8	92.9	93.1	92.1	88.9	84.9	79.8	76.0	(21)
		MCWB	65.4	66.7	66.9	69.4	72.6	76.7	77.4	78.2	76.7	74.6	70.8	68.3	(22)
	5%	DB	70.4	73.7	76.8	80.7	85.6	90.0	91.0	90.0	87.4	83.0	76.7	72.8	(23)
		MCWB	63.7	64.5	65.6	68.8	72.9	76.6	77.6	78.2	76.5	73.4	69.6	66.9	(24)
	10%	DB	67.3	70.4	73.7	78.4	83.4	87.6	89.2	88.1	85.8	81.3	74.3	69.7	(25)
		MCWB	62.1	63.8	64.4	68.1	72.6	76.0	77.6	77.9	75.8	72.5	68.1	65.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.2	71.2	71.5	74.2	77.6	80.4	81.7	82.1	80.7	78.4	75.9	72.2	(27)
		MCDB	74.5	76.6	77.6	79.8	85.3	88.6	89.7	89.9	85.4	84.7	80.0	77.3	(28)
	2%	WB	67.7	68.8	69.3	72.8	76.3	79.2	80.2	80.5	79.3	76.6	73.7	69.5	(29)
		MCDB	72.3	74.0	76.3	78.8	83.5	87.9	88.3	87.8	85.5	82.3	77.3	74.2	(30)
	5%	WB	65.4	66.8	67.8	71.4	75.2	78.1	79.3	79.7	78.3	75.5	71.4	67.8	(31)
		MCDB	69.3	71.9	74.2	77.0	82.0	86.5	87.2	87.0	84.4	80.9	75.1	71.7	(32)
	10%	WB	63.1	64.7	66.1	70.0	74.0	77.1	78.4	78.7	77.4	74.5	69.2	65.8	(33)
		MCDB	66.7	69.6	72.1	75.9	80.9	85.1	86.1	85.7	83.4	79.6	73.8	69.4	(34)
(35) Mean Daily Temperature Range	MDBR		15.7	16.0	15.6	15.2	14.3	13.7	13.8	12.4	11.1	12.4	14.3	14.6	(35)
	5% DB	MCDBR	18.3	19.1	19.3	17.6	17.4	17.0	16.3	15.0	13.1	12.4	14.9	17.3	(36)
		MCWBR	12.1	11.1	9.6	8.3	7.0	6.8	6.5	6.1	5.6	6.5	8.7	11.0	(37)
	5% WB	MCDBR	17.1	16.8	16.3	14.9	14.6	14.8	14.2	13.0	11.3	10.7	13.0	16.0	(38)
		MCWBR	12.6	11.4	9.2	8.5	6.9	6.7	6.4	6.2	5.7	6.5	8.6	11.1	(39)
(40) Clear-Sky Solar Irradiance	taub		0.340	0.350	0.372	0.398	0.438	0.482	0.506	0.490	0.428	0.403	0.362	0.348	(40)
	taud		2.536	2.512	2.460	2.376	2.302	2.238	2.178	2.226	2.396	2.432	2.497	2.537	(41)
	Ebn at Noon		283	290	290	284	272	259	252	255	268	268	272	274	(42)
	Edh at Noon		28	31	35	39	42	45	47	44	36	33	29	26	(43)
(44) All-Sky Solar Radiation	RadAvg		983	1181	1547	1898	2039	1915	1907	1771	1512	1329	1071	886	(44)
	RadStd		70	134	141	114	121	128	121	110	127	114	62	76	(45)

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (31 neighbors)	+0.81	+1.37	N/A	N/A	N/A	N/A	N/A	-25	-122	+297	+211

Nomenclature: See separate page