

MAYPORT NAF, FL, USA

WMO: 722066

Lat: 30.400N

Lon: 81.417W

Elev: 5

StdP: 101.27

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 03853

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 1.5	(c) 3.7	(d) -8.3	(e) 1.9	(f) 4.5	(g) -5.4	(h) 2.4	(i) 6.8	(j) 10.9	(k) 11.9	(l) 9.8	(m) 11.8	(n) 3.0	(o) 310	(p) 0.409

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 7.7	(c) 34.1	(d) 25.0	(e) 32.9	(f) 25.1	(g) 32.0	(h) 25.1	(i) 26.9	(j) 31.0	(k) 26.5	(l) 30.7	(m) 26.0	(n) 30.0	(o) 3.8	(p) 250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 25.9	(b) 21.2	(c) 29.1	(d) 25.2	(e) 20.4	(f) 28.7	(g) 24.8	(h) 19.9	(i) 28.4	(j) 84.3	(k) 31.3	(l) 82.1	(m) 30.6	(n) 80.2	(o) 30.1	(p) 30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.2	8.7	7.8	-3.7	36.1	7.2	1.2	-8.9	36.9	-13.2	37.6	-17.2	38.2	-22.5	39.1
			-5.6	27.6	6.3	1.1	-10.1	28.4	-13.8	29.1	-17.3	29.7	-21.8	30.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.3	13.0	14.8	17.3	20.8	24.4	27.2	28.1	28.0	26.6	22.9	17.8	14.8	(6)
	DBStd	6.36	4.65	4.65	4.16	3.05	2.48	1.79	1.45	1.30	1.75	3.95	4.14	4.47	(7)
	HDD10.0	56	25	11	4	0	0	0	0	0	0	3	2	11	(8)
	HDD18.3	562	174	113	67	13	1	0	0	0	0	11	59	124	(9)
	CDD10.0	4195	117	147	231	323	446	515	560	559	499	402	235	161	(10)
	CDD18.3	1659	7	16	36	86	188	265	302	301	249	151	42	16	(11)
	CDH23.3	14422	19	61	148	407	1372	2548	3211	3178	2335	961	139	43	(12)
CDH26.7	4606	1	6	23	68	363	911	1251	1138	667	161	15	2	(13)	
Wind	WSAvg	3.7	3.4	3.5	3.9	4.0	4.0	3.6	3.3	3.5	4.0	4.1	3.8	3.4	(14)
Precipitation	PrecAvg	1122	65	93	79	57	61	129	136	135	161	83	49	64	(15)
	PrecMax	1929	201	254	227	190	302	326	414	286	537	279	136	206	(16)
	PrecMin	705	4	6	12	11	5	14	34	48	26	4	3	9	(17)
	PrecStd	313	49	64	60	42	59	85	85	63	115	63	33	51	(18)
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.7	27.6	29.2	30.7	33.8	35.7	36.1	35.2	33.3	31.1	28.4	26.8	(19)
		MCWB	20.0	20.1	19.6	20.7	22.9	25.0	25.2	25.7	24.7	24.2	22.7	21.6	(20)
	2%	DB	23.1	25.3	26.7	28.5	31.6	33.8	34.0	33.4	31.6	29.4	26.5	24.4	(21)
		MCWB	18.6	19.3	19.4	20.8	22.6	24.8	25.2	25.7	24.8	23.6	21.6	20.2	(22)
	5%	DB	21.4	23.1	24.9	27.0	29.8	32.2	32.8	32.2	30.8	28.3	24.9	22.6	(23)
		MCWB	17.6	18.1	18.7	20.5	22.7	24.8	25.4	25.7	24.7	23.0	20.9	19.4	(24)
	10%	DB	19.6	21.3	23.2	25.8	28.6	30.9	31.8	31.2	29.9	27.4	23.5	21.0	(25)
		MCWB	16.7	17.7	18.0	20.1	22.6	24.4	25.3	25.5	24.3	22.5	20.1	18.5	(26)
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.2	21.8	21.9	23.5	25.4	26.9	27.6	27.8	27.0	25.8	24.4	22.3	(27)
		MCDB	23.6	24.8	25.4	26.5	29.6	31.5	32.1	32.2	29.7	29.3	26.7	25.2	(28)
	2%	WB	19.8	20.5	20.7	22.7	24.6	26.2	26.8	26.9	26.3	24.8	23.2	20.8	(29)
		MCDB	22.4	23.3	24.6	26.0	28.6	31.1	31.3	31.0	29.7	27.9	25.1	23.4	(30)
	5%	WB	18.6	19.3	19.9	21.9	24.0	25.6	26.3	26.5	25.7	24.2	21.9	19.9	(31)
		MCDB	20.7	22.2	23.4	25.0	27.8	30.3	30.7	30.6	29.1	27.2	23.9	22.1	(32)
	10%	WB	17.3	18.2	19.0	21.1	23.3	25.1	25.8	26.0	25.2	23.6	20.7	18.8	(33)
		MCDB	19.3	20.9	22.3	24.4	27.2	29.5	30.0	29.8	28.6	26.5	23.2	20.8	(34)
Mean Daily Temperature Range	5% DB	MDBR	8.7	8.9	8.7	8.4	7.9	7.6	7.7	6.9	6.2	6.9	7.9	8.1	(35)
		MCDBR	10.2	10.6	10.7	9.8	9.6	9.4	9.0	8.3	7.3	6.9	8.3	9.6	(36)
		MCWBR	6.7	6.2	5.3	4.6	3.9	3.8	3.6	3.4	3.1	3.6	4.8	6.1	(37)
	5% WB	MCDBR	9.5	9.3	9.1	8.3	8.1	8.2	7.9	7.2	6.3	6.0	7.2	8.9	(38)
		MCWBR	7.0	6.3	5.1	4.7	3.8	3.7	3.6	3.4	3.2	3.6	4.8	6.1	(39)
Clear-Sky Solar Irradiance	taub		0.340	0.350	0.372	0.398	0.438	0.482	0.506	0.490	0.428	0.403	0.362	0.348	(40)
	taud		2.536	2.512	2.460	2.376	2.302	2.238	2.178	2.226	2.396	2.432	2.497	2.537	(41)
	Ebn at Noon		893	914	913	896	857	815	794	804	846	845	859	865	(42)
	Edh at Noon		87	97	109	122	132	141	149	140	115	104	90	83	(43)
All-Sky Solar Radiation	RadAvg		3.10	3.72	4.88	5.98	6.43	6.04	6.01	5.58	4.77	4.19	3.38	2.79	(44)
	RadStd		0.22	0.42	0.44	0.36	0.38	0.40	0.38	0.35	0.40	0.36	0.20	0.24	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (31 neighbors)	+0.45	+0.76	N/A	N/A	N/A	N/A	-14	-68	+165	+117

Nomenclature: See separate page