

CECIL FIELD, FL, USA

WMO: 722067

Lat: 30.219N

Lon: 81.876W

Elev: 81

StdP: 14.65

Time Zone: -5.00 (NAE)

Period: 90-19

WBAN: 63823

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 30.3	(c) 34.0	(d) 16.3	(e) 12.6	(f) 40.8	(g) 22.2	(h) 16.8	(i) 43.4	(j) 21.0	(k) 57.2	(l) 19.4	(m) 60.3	(n) 3.8	(o) 320	(p) 0.363

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.3	96.6	76.9	94.2	76.5	92.3	76.1	79.7	90.1	78.8	88.9	78.0	87.8	7.6	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.2	142.2	82.8	76.3	137.5	82.3	75.3	133.1	81.7	43.1	89.8	42.2	89.0	41.4	88.0	85.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
19.0	16.9	15.0	DB	24.5	98.1	4.4	1.7	21.3	99.3	18.7	100.3	16.2	101.3	13.0	102.5	
			WB	21.4	82.3	3.5	1.8	18.9	83.6	16.8	84.6	14.9	85.6	12.4	86.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	69.4	55.8	58.8	62.6	67.4	75.0	80.3	82.5	81.2	78.2	71.0	62.6	56.9
	DBStd	11.54	8.55	8.68	8.24	6.50	4.68	4.09	2.59	2.60	3.50	5.83	8.53	8.94
	HDD50	117	40	23	12	0	0	0	0	0	0	0	6	36
	HDD65	1148	304	207	139	52	3	0	0	0	0	19	145	279
	CDD50	7200	219	269	402	523	774	908	1007	966	847	650	385	250
	CDD65	2757	18	32	65	125	313	458	542	501	397	204	75	27
	CDH74	25047	94	225	610	1190	3061	4401	5428	4662	3323	1441	452	160
	CDH80	10531	6	33	120	335	1236	2167	2715	2107	1332	378	86	16
(14) Wind	WSAvg	6.0	6.4	7.1	7.5	6.6	6.1	5.6	5.1	4.8	5.0	5.7	6.0	5.8
(15) Precipitation	PrecAvg	53.1	3.3	4.1	3.6	2.7	3.7	6.6	7.1	7.9	6.0	2.6	2.1	3.0
	PrecMax	79.0	7.6	12.6	8.8	10.6	11.3	13.3	13.3	17.0	14.4	8.5	7.0	7.4
	PrecMin	26.7	0.7	1.1	0.3	0.4	0.3	1.2	2.2	2.3	1.2	0.0	0.1	0.3
	PrecStd	9.3	1.9	2.4	2.3	2.0	2.5	2.8	3.0	3.8	3.5	2.1	1.6	2.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.5	83.4	86.7	90.2	93.7	99.5	99.3	96.7	94.1	89.0	85.9	82.2
		MCWB	68.7	68.5	69.0	72.2	73.1	76.8	78.1	76.4	75.9	73.6	73.6	70.9
	2%	DB	76.8	80.6	83.0	86.6	91.2	97.2	96.4	94.4	91.6	86.4	82.4	78.8
		MCWB	66.2	67.8	66.8	68.9	72.5	77.0	77.2	76.9	75.2	72.9	70.8	67.8
	5%	DB	73.1	76.6	80.9	83.8	89.3	93.8	94.0	92.2	89.9	84.1	79.4	74.8
		MCWB	64.3	64.7	65.8	68.3	72.0	76.0	77.0	76.8	75.0	72.0	69.0	65.3
	10%	DB	70.1	72.6	77.5	81.3	86.9	90.8	91.6	90.1	87.8	81.9	75.8	71.3
		MCWB	62.4	63.0	64.1	67.1	71.2	75.4	77.0	76.6	74.8	71.1	67.7	64.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.2	70.7	71.8	76.6	77.3	80.3	81.0	80.8	79.2	77.7	76.2	72.4
		MCDB	75.3	79.5	80.8	86.3	86.6	93.1	90.2	89.9	85.5	84.2	82.1	78.9
	2%	WB	68.4	69.0	70.1	72.7	75.9	78.7	79.8	79.4	78.0	76.3	73.4	70.4
		MCDB	74.6	77.0	79.2	79.5	85.2	90.9	90.3	88.7	85.6	82.2	78.0	75.0
	5%	WB	66.3	67.3	68.6	71.1	75.0	77.7	79.0	78.4	77.1	74.8	71.8	68.0
		MCDB	71.0	74.3	76.8	78.7	84.3	88.9	89.6	87.5	85.2	80.2	76.4	73.1
	10%	WB	64.4	65.3	66.8	69.4	73.8	76.8	78.1	77.5	76.3	73.1	69.7	65.3
		MCDB	68.7	70.6	73.6	77.2	83.2	87.2	88.4	86.5	84.2	78.7	74.6	70.5
(35) Mean Daily Temperature Range	5% DB	MDBR	22.0	22.2	23.8	24.3	23.0	20.9	20.3	18.6	18.1	19.3	21.2	21.4
		MCDBR	23.5	24.2	26.5	25.2	25.1	25.2	22.9	21.5	21.3	20.5	21.0	23.6
		MCWBR	15.0	13.4	13.1	11.8	10.2	8.4	8.0	7.9	8.9	10.4	11.7	14.0
	5% WB	MCDBR	19.3	21.2	22.2	20.3	21.5	21.8	20.7	18.9	17.8	16.7	18.2	19.4
		MCWBR	13.7	13.1	12.6	10.6	9.5	8.3	8.3	7.8	8.1	9.5	11.7	12.4
(40) Clear-Sky Solar Irradiance	taub		0.335	0.346	0.371	0.391	0.433	0.474	0.505	0.489	0.427	0.396	0.358	0.342
	taud		2.524	2.496	2.433	2.364	2.284	2.235	2.151	2.201	2.371	2.425	2.482	2.526
	Ebn at Noon		285	292	290	286	273	261	252	255	269	270	274	276
	Edh at Noon		28	31	36	39	43	45	49	46	37	33	29	27
(44) All-Sky Solar Radiation	RadAvg		999	1193	1556	1891	2027	1869	1852	1727	1511	1341	1090	898
	RadStd		70	133	138	122	125	127	122	114	123	115	64	77

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (33 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	-20	-117	+299	+211

Nomenclature: See separate page