

DESTIN EXECUTIVE, FL, USA

WMO: 722069

Lat: 30.400N

Lon: 86.472W

Elev: 22

StdP: 14.68

Time Zone: -6.00 (NAC)

Period: 97-19

WBAN: 53853

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	33.3	36.8	14.0	11.2	38.2	19.1	14.4	42.5	23.4	45.3	20.4	49.1	10.3	0	0.380

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.3	92.0	78.3	90.6	78.3	89.6	78.2	81.9	87.8	80.9	87.2	80.1	86.5	6.8	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.4	157.8	85.2	79.2	151.5	84.8	78.3	147.2	84.6	45.5	88.5	44.5	87.2	43.5	86.0	86.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.9	16.8	15.1	26.9	95.7	4.3	2.3	23.8	97.3	21.2	98.7	18.8	100.0	15.7	101.7
			22.9	83.0	3.6	1.5	20.3	84.1	18.2	84.9	16.1	85.7	13.5	86.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	69.7	53.7	56.7	61.7	68.4	75.9	81.4	83.2	83.1	80.2	71.9	62.4	56.4
	DBStd	12.25	8.90	7.79	6.84	5.04	4.17	2.62	2.63	2.72	3.69	6.45	7.34	8.38
	HDD50	134	63	26	6	0	0	0	0	0	0	6	33	
	HDD65	1207	359	244	141	26	1	0	0	0	20	130	286	
	CDD50	7308	179	215	369	552	804	943	1028	1025	905	679	378	231
	CDD65	2905	10	13	39	128	340	493	563	560	455	233	52	19
	CDH74	28741	15	11	45	369	2682	5579	6864	6710	4627	1632	193	14
	CDH80	10151	4	0	2	21	528	2009	2841	2797	1609	331	9	0
Wind	WSAvg	6.7	7.8	7.6	7.7	7.3	6.5	5.6	5.0	5.2	6.4	6.9	7.1	7.7
Precipitation	PrecAvg	57.4	3.7	4.6	4.6	5.0	3.2	5.1	6.6	6.8	5.9	3.2	4.1	5.2
	PrecMax	73.1	8.1	9.0	8.9	19.3	8.1	13.3	17.3	12.1	15.1	13.1	10.0	10.0
	PrecMin	36.9	0.9	1.6	0.3	0.7	0.1	2.2	1.7	3.3	0.9	0.3	0.6	1.5
	PrecStd	10.9	1.7	2.4	2.7	4.9	2.6	2.7	4.2	2.6	3.3	3.2	2.3	2.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.2	75.9	78.1	82.2	89.4	92.5	94.1	93.9	92.6	88.4	81.3	76.0
		MCWB	71.9	68.3	67.2	70.6	72.9	76.8	79.8	78.4	76.0	74.6	72.5	71.1
	2%	DB	71.3	72.5	74.9	79.6	85.9	90.2	91.6	91.7	90.3	85.9	78.7	73.6
		MCWB	67.4	67.3	67.3	70.5	74.8	77.8	79.4	79.0	76.3	74.4	71.1	69.7
	5%	DB	69.1	70.2	73.0	77.9	84.2	88.6	90.3	90.4	88.5	83.6	76.1	72.1
		MCWB	65.7	65.8	66.7	70.0	74.6	77.6	79.0	78.9	76.4	73.4	69.6	68.4
	10%	DB	66.6	67.8	71.6	76.0	82.7	87.5	88.9	89.3	87.4	81.6	73.7	70.0
		MCWB	63.3	63.7	66.0	69.0	74.0	77.2	78.5	78.8	76.2	72.5	67.3	66.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.7	70.9	72.5	77.4	80.6	83.2	83.1	82.9	81.4	79.2	75.9	72.8
		MCDB	75.5	73.1	74.7	78.5	82.8	85.9	89.2	89.5	86.6	83.9	79.2	75.3
	2%	WB	68.4	68.7	70.4	74.6	78.1	81.1	81.8	81.6	79.9	77.4	73.7	70.8
		MCDB	70.1	71.7	72.9	78.3	82.6	85.7	88.7	88.2	85.5	82.6	76.9	73.1
	5%	WB	66.5	66.9	68.8	72.8	76.8	80.0	80.7	80.7	78.6	76.0	71.2	69.3
		MCDB	68.3	69.1	71.6	76.2	82.1	85.5	87.7	87.4	84.8	81.5	75.0	71.4
	10%	WB	64.3	65.0	67.1	71.2	75.8	79.0	79.8	80.0	77.9	74.7	69.3	66.7
		MCDB	66.0	66.9	70.1	74.4	81.2	85.0	86.8	86.8	84.4	80.0	73.0	69.4
Mean Daily Temperature Range	5% DB	MDBR	15.2	14.3	14.0	13.0	12.3	11.3	11.3	11.6	12.7	15.1	16.1	14.9
		MCDBR	13.5	12.7	13.1	13.3	13.0	12.5	12.5	12.8	13.7	14.9	15.0	13.4
		MCWBR	11.4	9.9	8.6	7.7	6.6	5.8	5.5	5.7	5.9	7.1	10.3	11.2
	5% WB	MCDBR	12.3	11.6	10.7	10.1	10.6	10.8	11.9	11.6	11.7	12.3	12.7	12.7
		MCWBR	11.3	10.8	8.4	7.0	6.1	6.2	6.1	5.9	5.9	7.9	10.9	12.4
Clear-Sky Solar Irradiance	taub	0.335	0.349	0.370	0.398	0.437	0.466	0.503	0.496	0.438	0.386	0.357	0.342	
	taud	2.541	2.505	2.442	2.372	2.297	2.268	2.181	2.196	2.334	2.457	2.477	2.529	
	Ebn at Noon	285	291	290	284	272	263	252	253	266	274	274	276	
	Edh at Noon	27	31	35	39	42	43	47	46	39	32	29	27	
All-Sky Solar Radiation	RadAvg	991	1186	1604	1929	2141	2010	1892	1756	1639	1453	1122	873	
	RadStd	73	153	126	154	124	164	117	132	99	135	98	87	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+1.58	N/A	N/A	N/A	N/A	N/A	N/A	-284	+607	+387
Regional (37 neighbors)		+0.81	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+270	+164

Nomenclature: See separate page