

SAVANNAH HILTON HEAD INTL, GA, USA

WMO: 722070

Lat: 32.131N

Lon: 81.202W

Elev: 46

StdP: 14.67

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 03822

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.5	30.7	11.0	9.6	38.0	15.6	12.1	39.6	23.8	57.2	20.6	52.9	4.4	310	0.395

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.8	95.5	77.1	93.3	76.8	91.4	76.4	80.2	89.4	79.3	88.2	78.4	86.8	7.8	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.0	145.8	83.4	77.1	141.3	82.6	76.2	137.2	82.0	43.6	89.3	42.7	88.3	41.8	87.1	85.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.1	16.9	15.3	DB	22.0	99.2	3.5	2.3	19.5	100.9	17.4	102.2	15.5	103.5	13.0	105.2	
			WB	19.4	82.0	3.1	1.4	17.2	83.1	15.4	83.9	13.6	84.7	11.3	85.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	67.3	50.4	54.0	59.7	66.6	73.9	79.9	82.4	81.7	77.4	68.6	58.9	53.3
	DBStd	13.19	9.55	8.81	8.21	6.85	5.50	3.84	2.79	2.94	4.28	7.02	8.02	9.22
	HDD50	274	115	53	18	1	0	0	0	0	0	16	71	
	HDD65	1688	459	321	201	63	6	0	0	0	1	46	216	375
	CDD50	6588	127	164	320	499	740	897	1005	981	821	578	282	174
	CDD65	2528	6	12	38	112	281	447	540	516	372	159	32	13
	CDH74	22831	27	85	296	923	2446	4213	5523	5039	2975	1068	181	55
	CDH80	8981	1	8	46	233	888	1828	2517	2141	1057	245	15	2
Wind	WSAvg	6.6	7.0	7.3	7.8	7.5	6.8	6.2	5.7	5.7	6.3	6.1	6.0	6.4
Precipitation	PrecAvg	49.3	3.6	3.0	3.9	3.1	3.7	6.0	6.5	6.8	4.6	2.9	2.1	2.7
	PrecMax	73.2	9.0	7.9	9.0	10.6	8.7	14.4	20.1	17.0	12.2	19.8	5.3	5.8
	PrecMin	31.7	0.4	0.3	0.1	0.4	0.4	1.0	1.3	1.0	0.4	0.0	0.2	0.1
	PrecStd	9.4	2.2	1.7	2.4	2.1	2.1	3.3	3.7	3.7	2.9	3.5	1.5	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.4	81.1	84.5	88.6	94.9	97.7	98.0	97.3	93.6	88.5	82.1	78.7
		MCWB	66.1	66.5	65.9	69.2	72.8	76.6	77.5	79.2	75.0	75.0	70.3	68.0
	2%	DB	73.1	76.6	80.7	85.7	90.9	94.5	95.4	94.2	90.5	85.2	78.9	75.3
		MCWB	63.3	63.9	65.0	68.1	72.2	76.4	77.4	78.3	75.2	72.2	67.9	66.1
	5%	DB	69.2	72.7	77.3	82.7	88.0	91.9	93.2	91.9	88.3	82.7	75.8	71.6
		MCWB	61.8	61.7	63.3	67.2	71.9	75.9	77.5	77.6	74.8	71.0	65.6	65.2
	10%	DB	65.6	68.6	73.8	79.6	85.1	89.3	90.9	89.8	86.2	80.2	72.6	68.2
		MCWB	59.7	59.5	61.8	65.8	70.9	75.3	77.3	77.1	74.2	69.6	65.2	63.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.8	69.1	70.2	73.4	77.6	80.4	81.4	81.8	79.7	78.2	74.0	70.8
		MCDB	73.5	76.6	77.7	81.6	86.7	91.2	90.4	91.4	85.6	83.3	77.4	75.1
	2%	WB	66.1	66.7	68.2	71.5	75.9	78.8	80.2	80.2	78.2	76.2	71.2	68.5
		MCDB	70.6	73.5	75.4	80.3	84.4	88.7	89.7	89.1	84.4	81.2	74.8	72.3
	5%	WB	63.8	64.3	66.3	70.0	74.4	77.8	79.2	79.3	77.3	74.6	69.0	66.4
		MCDB	67.9	70.0	73.0	78.1	82.5	87.3	88.9	87.8	83.6	79.2	73.5	70.7
	10%	WB	60.8	61.9	64.4	68.4	73.1	76.9	78.3	78.4	76.4	72.8	66.7	63.9
		MCDB	64.9	66.9	70.8	76.0	80.9	85.6	87.3	86.4	82.4	77.3	71.2	68.1
Mean Daily Temperature Range	5% DB	MDBR	20.9	21.5	22.0	22.2	20.5	18.1	17.8	16.7	16.5	19.6	21.7	20.3
		MCDBR	23.3	24.5	24.7	23.7	23.2	21.5	20.2	19.4	18.9	20.1	22.9	21.6
		MCWBR	14.8	13.9	11.6	9.9	8.6	7.4	6.9	6.6	6.7	9.4	12.9	13.7
	5% WB	MCDBR	20.2	21.2	19.8	20.1	19.4	18.5	18.2	17.5	15.3	15.7	17.9	19.3
		MCWBR	15.0	13.9	11.2	10.1	8.3	7.3	7.0	6.7	6.3	8.2	12.1	13.8
Clear-Sky Solar Irradiance	taub	0.329	0.333	0.367	0.403	0.452	0.496	0.528	0.512	0.429	0.396	0.356	0.345	
	taud	2.525	2.515	2.440	2.331	2.227	2.156	2.080	2.126	2.356	2.415	2.479	2.504	
	Ebn at Noon	284	294	290	282	267	254	246	248	266	268	271	271	
	Edh at Noon	27	30	35	40	45	48	52	49	37	33	28	27	
All-Sky Solar Radiation	RadAvg	939	1140	1496	1882	2024	2008	1972	1786	1516	1321	1039	828	
	RadStd	51	115	134	124	122	152	124	111	127	140	69	68	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.06	+1.42	N/A	N/A	N/A	N/A	N/A	-149	+389	+272
(47)	Regional (35 neighbors)	+1.03	+1.42	N/A	N/A	N/A	N/A	N/A	-164	+347	+236

Nomenclature: See separate page