

CHICKASHA, OK, USA

WMO: 722071

Lat: 35.096N

Lon: 97.966W

Elev: 1150

StdP: 14.10

Time Zone: -6.00 (NAC)

Period: 05-19

WBAN: 53935

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.4	19.0	5.0	7.4	18.9	9.8	9.5	23.3	32.6	39.5	28.5	38.1	8.8	0	0.519

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.7	100.5	75.3	99.1	75.7	96.7	75.9	81.0	91.5	79.1	91.3	77.8	91.0	10.6	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.8	156.3	87.3	75.4	139.1	84.8	73.5	130.1	82.7	45.8	90.9	43.3	91.3	42.0	91.2	86.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.8	23.8	20.3	7.3	105.1	5.7	3.8	3.2	107.7	-0.1	109.9	-3.3	112.0	-7.4	114.8
			6.4	82.1	5.4	2.5	2.5	83.9	-0.7	85.4	-3.7	86.8	-7.6	88.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.8	40.0	43.3	53.0	60.5	69.7	79.7	83.6	82.5	74.3	62.2	51.3	40.6
	DBStd	17.67	9.71	10.98	10.21	8.77	8.10	5.10	4.92	5.70	6.80	9.46	9.05	9.54
	HDD50	1098	333	238	86	17	1	0	0	0	0	17	91	315
	HDD65	3350	775	610	385	184	47	0	0	0	10	166	418	755
	CDD50	5410	22	50	180	332	611	890	1041	1008	729	394	129	24
	CDD65	2191	0	2	15	50	192	441	576	543	288	78	6	0
	CDH74	25286	3	24	131	509	1856	5011	7371	6672	2880	761	66	2
	CDH80	12898	0	3	18	130	685	2549	4252	3783	1272	202	4	0
(14) Wind	WSAvg	9.1	9.4	10.2	10.6	10.7	9.1	8.9	7.6	7.5	7.7	8.7	9.3	9.1
(15) Precipitation	PrecAvg	34.8	1.4	1.6	2.5	3.5	4.4	4.5	3.0	3.2	3.3	3.0	1.9	1.8
	PrecMax	56.5	4.3	4.3	6.7	6.9	9.4	14.1	7.6	8.0	9.2	9.7	6.1	5.3
	PrecMin	22.2	0.1	0.0	0.0	0.4	1.2	0.8	0.2	0.0	0.8	0.6	0.0	0.1
	PrecStd	7.5	1.0	1.2	1.8	1.7	2.4	2.9	2.0	2.0	1.9	2.2	1.9	1.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.1	77.4	82.0	90.2	95.4	100.0	106.4	107.9	97.2	90.2	80.8	72.3
		MCWB	54.8	60.9	63.7	68.9	75.8	76.3	74.7	76.4	73.8	71.0	64.5	58.3
	2%	DB	67.8	72.5	77.4	82.3	90.6	97.1	101.6	101.6	94.7	85.8	75.1	66.2
		MCWB	54.8	58.1	62.5	66.0	75.0	76.9	74.5	75.3	74.2	70.7	62.0	55.5
	5%	DB	61.5	67.5	73.2	79.4	88.4	95.0	99.1	99.4	90.6	81.4	71.9	60.9
		MCWB	48.9	57.4	61.1	65.4	72.9	75.9	75.6	75.6	73.9	67.1	59.8	51.1
	10%	DB	56.9	61.4	70.4	76.7	82.4	91.4	96.8	96.6	88.4	78.6	68.0	56.5
		MCWB	46.9	52.1	59.5	63.8	71.2	76.0	76.2	75.3	72.5	65.5	58.8	48.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.3	64.3	68.6	72.9	82.7	84.0	83.4	80.5	79.1	75.0	68.1	63.8
		MCDB	68.0	70.9	76.5	82.9	89.6	94.1	95.0	94.7	90.1	84.0	76.0	68.8
	2%	WB	55.2	61.1	66.5	70.7	77.2	80.9	80.7	78.9	76.7	73.2	64.9	57.6
		MCDB	63.7	69.8	74.1	78.8	86.8	89.6	92.9	94.2	88.3	81.0	71.3	62.4
	5%	WB	51.4	57.7	64.2	68.4	74.7	78.5	79.0	77.9	75.2	71.0	62.5	53.5
		MCDB	60.0	65.2	71.0	75.8	84.2	89.9	91.6	93.4	86.0	78.2	68.7	58.9
	10%	WB	47.7	53.5	61.0	66.4	72.8	77.2	77.6	76.9	74.0	68.4	59.5	49.5
		MCDB	56.1	61.2	68.7	73.5	81.2	89.5	90.7	92.1	84.4	75.1	66.5	57.0
(35) Mean Daily Temperature Range	5% DB	MDBR	23.5	21.9	23.3	23.5	21.2	21.9	22.7	22.8	22.6	23.7	24.3	20.9
		MCDBR	31.9	30.3	27.1	27.3	25.4	24.5	25.9	26.4	25.3	25.8	28.2	29.0
	5% WB	MCWBR	20.0	19.1	16.1	15.3	12.3	9.4	8.0	8.2	10.0	13.4	17.0	18.9
		MCWBR	28.7	26.1	22.0	21.9	21.7	21.7	21.9	23.4	21.4	19.8	24.8	23.5
(40) Clear-Sky Solar Irradiance	taub		0.292	0.299	0.338	0.377	0.412	0.428	0.425	0.428	0.389	0.346	0.312	0.291
		taud	2.508	2.503	2.414	2.326	2.299	2.298	2.336	2.272	2.356	2.467	2.496	2.510
	Ebn at Noon		292	302	296	288	278	272	272	269	275	280	281	285
		Edh at Noon	26	29	35	40	42	42	40	42	36	30	26	24
(44) All-Sky Solar Radiation	RadAvg		907	1096	1445	1781	1918	2161	2180	1984	1647	1255	955	768
	RadStd		91	161	94	139	203	195	122	118	138	168	123	85

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (37 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page