

HENDERSON EXECUTIVE, NV, USA

WMO: 722096

Lat: 35.976N

Lon: 115.133W

Elev: 2458

StdP: 13.44

Time Zone: -8.00 (NAP)

Period: 05-19

WBAN: 53127

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	28.2	31.4	-4.4	4.8	56.3	-0.2	5.9	54.4	31.6	57.7	27.6	55.2	5.5	160	0.541

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.2	108.4	65.6	106.3	64.9	104.2	64.4	71.7	93.4	70.6	93.2	69.3	93.0	10.4	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.7	104.0	79.4	63.4	95.8	81.9	60.9	87.5	84.2	36.9	92.7	35.9	93.0	34.8	92.7	75.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.4	24.3	20.6	23.6	112.6	3.3	2.2	21.3	114.2	19.3	115.5	17.5	116.7	15.1	118.3
			18.7	73.4	2.6	1.3	16.8	74.4	15.2	75.1	13.8	75.8	11.9	76.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	68.4	47.1	51.5	59.3	66.3	74.5	87.2	91.9	89.7	81.9	68.1	56.3	45.6	(6)
	DBStd	17.28	5.72	6.88	7.10	7.38	7.98	6.47	4.67	4.47	6.52	6.90	7.27	5.78	(7)
	HDD50	374	120	61	9	1	0	0	0	0	1	25	157		(8)
	HDD65	2140	556	378	203	72	16	0	0	0	1	44	269	601	(9)
	CDD50	7079	29	104	297	489	761	1116	1298	1230	956	564	213	22	(10)
	CDD65	3370	0	1	27	111	312	666	833	765	507	141	7	0	(11)
	CDH74	50011	0	12	339	1312	4064	10465	13641	11919	6709	1442	108	0	(12)
	CDH80	31095	0	0	78	478	2092	6877	9385	7829	3857	491	8	0	(13)
(14) Wind	WSAvg	9.1	7.2	8.3	10.1	11.2	11.0	11.3	9.9	9.6	8.6	8.2	7.3	7.0	(14)
(15) Precipitation	PrecAvg	9.9	1.0	1.4	0.8	0.4	0.3	0.2	1.3	1.1	1.0	0.7	0.5	1.1	(15)
	PrecMax	13.9	3.7	4.1	4.1	1.5	1.2	0.8	3.2	2.8	3.1	2.1	1.8	4.2	(16)
	PrecMin	6.4	0.0	0.1	0.0	0.0	0.0	0.0	0.2	0.1	0.0	0.0	0.0	0.0	(17)
	PrecStd	2.5	1.1	1.1	0.9	0.4	0.3	0.2	0.9	0.7	0.7	0.6	0.4	1.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	68.2	75.8	87.1	94.0	101.3	110.8	112.2	108.3	104.1	93.1	81.1	67.5	(19)
		MCWB	47.7	51.3	55.3	57.8	60.2	65.3	66.7	66.1	64.5	60.1	54.1	49.5	(20)
	2%	DB	64.8	72.2	81.6	89.5	97.6	107.5	109.5	106.2	101.1	88.9	77.2	63.7	(21)
		MCWB	45.8	49.7	53.5	55.8	58.9	64.1	66.2	65.7	63.8	58.4	53.1	47.0	(22)
	5%	DB	61.9	69.0	77.6	85.5	94.9	105.2	107.2	104.4	99.0	85.5	74.0	60.5	(23)
		MCWB	44.8	48.4	51.5	54.7	57.8	62.5	65.7	65.3	63.2	57.4	51.3	45.2	(24)
	10%	DB	58.9	65.4	74.0	81.8	91.2	102.7	104.7	102.4	96.4	82.1	70.4	57.2	(25)
		MCWB	43.6	47.2	50.2	53.3	56.8	61.4	65.5	65.0	62.6	55.8	50.2	43.5	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.4	55.2	56.5	59.5	62.2	69.0	73.4	73.3	70.9	65.1	57.0	52.4	(27)
		MCDB	59.3	66.9	80.8	91.0	94.9	101.4	95.5	94.7	88.2	80.7	76.3	63.2	(28)
	2%	WB	49.2	51.6	54.6	57.3	60.3	66.7	71.9	71.6	68.8	62.4	54.2	50.1	(29)
		MCDB	59.5	65.9	77.8	84.9	92.8	101.7	94.7	92.3	92.0	80.0	74.0	59.3	(30)
	5%	WB	46.9	49.9	52.9	55.6	59.1	64.9	70.9	70.5	67.2	60.1	52.5	47.7	(31)
		MCDB	58.4	65.4	74.6	81.4	90.5	99.4	94.2	92.1	90.1	78.3	71.2	57.4	(32)
	10%	WB	45.0	48.1	51.1	54.1	57.7	63.0	69.7	69.3	65.6	58.2	50.7	45.0	(33)
		MCDB	56.2	64.2	71.5	79.0	88.1	97.4	93.8	91.9	87.7	77.1	68.3	55.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	21.1	21.8	23.3	24.2	24.2	25.7	23.2	23.5	24.7	23.6	22.6	19.4	(35)
		MCDBR	25.0	26.2	27.8	28.3	27.6	27.3	25.4	25.1	26.6	26.7	26.3	23.2	(36)
	5% WB	MCWBR	13.4	12.9	12.3	11.7	10.2	9.7	9.1	9.3	10.1	11.6	12.5	12.6	(37)
		MCWBR	20.3	22.9	25.7	25.9	25.9	25.0	21.0	21.4	22.5	21.4	24.1	18.8	(38)
(40) Clear-Sky Solar Irradiance	taub		0.262	0.266	0.280	0.301	0.318	0.315	0.353	0.344	0.311	0.288	0.265	0.261	(40)
		taud	2.625	2.628	2.564	2.482	2.456	2.476	2.453	2.468	2.545	2.597	2.632	2.633	(41)
	Ebn at Noon		305	314	316	312	305	305	292	294	301	302	301	298	(42)
		Edh at Noon	23	25	30	34	36	35	36	34	30	26	22	21	(43)
(44) All-Sky Solar Radiation	RadAvg		981	1286	1763	2209	2503	2710	2386	2219	1961	1479	1104	870	(44)
	RadStd		77	112	81	91	120	108	125	111	81	85	45	63	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (15 neighbors)		+0.79	N/A	-2.88	N/A	N/A	N/A	N/A	N/A	+286	N/A	

Nomenclature: See separate page