

CHANDLER, OK, USA

WMO: 722099

Lat: 35.724N

Lon: 96.820W

Elev: 984

StdP: 14.18

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 53936

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.4	19.0	4.5	7.2	18.6	9.4	9.2	25.2	26.2	49.1	24.2	46.0	7.2	0	0.465

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.2	101.7	75.1	98.7	76.2	94.9	77.0	80.9	91.8	79.7	90.9	78.4	89.8	9.7	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.6	154.1	87.4	77.0	145.7	86.1	75.3	137.4	84.4	45.6	91.2	44.1	90.2	42.7	90.8	84.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
23.1	19.9	17.9	4.4	103.8	7.0	5.7	-0.7	107.8	-4.8	111.1	-8.7	114.3	-13.8	118.4		
			DB													
			WB	3.7	82.5	6.8	1.5	-1.2	83.5	-5.2	84.4	-9.0	85.3	-13.9	86.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.9	40.6	43.1	53.8	61.3	69.5	78.3	82.7	81.7	74.5	63.0	51.6	42.1
	DBStd	17.33	10.82	11.60	10.49	8.97	7.78	6.60	5.03	5.94	6.70	9.28	9.36	10.08
	HDD50	1058	326	248	80	16	1	3	0	0	0	13	90	281
	HDD65	3250	758	616	371	170	47	9	0	0	8	149	410	712
	CDD50	5419	34	56	196	356	606	852	1012	983	735	416	138	35
	CDD65	2134	1	3	22	60	186	408	547	518	293	87	8	1
	CDH74	23253	6	28	188	604	1642	4395	6581	6052	2858	805	87	7
	CDH80	11217	0	3	36	160	566	2081	3597	3254	1273	236	11	0
Wind	WSAvg	7.6	8.1	8.4	9.6	9.7	7.6	6.9	6.0	5.9	6.0	7.1	8.1	7.8
Precipitation	PrecAvg	33.9	1.3	1.8	2.6	3.0	5.1	3.8	2.8	2.7	4.1	3.1	2.4	1.3
	PrecMax	52.6	5.0	6.2	6.6	8.2	9.6	10.7	8.0	9.3	9.0	11.5	5.6	3.9
	PrecMin	20.9	0.0	0.0	0.0	0.2	1.3	0.7	0.2	0.2	0.4	0.2	0.0	0.1
	PrecStd	7.8	1.1	1.5	1.5	1.6	2.2	2.6	2.0	2.1	2.6	2.6	1.8	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.1	78.8	84.1	90.2	93.0	99.9	107.8	108.8	99.6	90.2	81.4	73.0
		MCWB	56.2	60.9	63.7	67.9	73.7	76.4	75.9	75.4	74.9	71.6	64.8	61.0
	2%	DB	68.4	72.0	79.3	84.2	89.8	96.6	102.2	101.9	94.7	86.2	76.6	67.5
		MCWB	54.8	57.0	61.8	66.2	73.5	76.7	75.3	74.8	75.4	71.2	61.6	55.7
	5%	DB	63.3	66.1	74.6	80.9	86.3	92.9	98.7	98.7	90.7	81.9	72.0	62.8
		MCWB	52.9	54.9	60.4	65.1	71.9	75.6	76.3	76.4	74.1	67.0	59.8	52.9
	10%	DB	57.5	62.5	70.5	77.1	82.2	90.5	94.8	94.5	88.0	78.9	67.4	57.3
		MCWB	47.3	53.2	58.5	64.0	71.0	76.0	77.5	77.0	73.4	66.8	57.4	49.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	62.8	63.7	68.1	72.6	78.2	82.7	82.8	82.3	79.1	76.0	68.9	65.1
		MCDB	65.2	71.1	78.9	81.4	87.0	94.0	93.9	93.2	93.4	85.7	76.0	70.9
	2%	WB	58.1	60.7	65.5	70.6	75.9	80.3	80.8	80.4	77.5	73.9	65.0	60.2
		MCDB	65.2	67.6	74.1	78.8	84.7	90.9	91.5	92.0	90.4	81.6	71.3	63.8
	5%	WB	52.8	57.6	63.6	68.4	74.2	79.2	79.5	79.2	76.2	72.0	62.3	54.9
		MCDB	62.1	64.9	70.8	76.5	82.7	89.4	90.4	91.3	87.6	78.2	68.1	58.4
	10%	WB	49.2	52.7	61.1	66.5	72.7	77.7	78.3	77.9	74.8	69.8	59.5	51.5
		MCDB	56.9	61.0	68.4	74.6	80.6	87.5	89.8	90.1	84.3	75.2	65.7	56.3
Mean Daily Temperature Range	5% DB	MDBR	20.7	20.9	22.1	22.2	19.6	20.3	21.2	21.4	22.1	22.8	22.2	19.6
		MCDBR	28.9	28.6	26.4	26.6	23.1	23.6	26.4	26.5	25.1	25.4	27.6	26.5
		MCWBR	17.8	17.2	14.1	14.0	10.3	9.1	7.7	7.8	9.8	12.5	15.7	16.4
	5% WB	MCDBR	26.1	24.6	21.2	22.5	19.7	20.3	20.8	21.1	21.4	19.7	23.1	20.0
		MCWBR	18.1	17.5	12.2	13.7	10.4	10.0	8.9	8.9	9.0	11.3	16.5	16.2
Clear-Sky Solar Irradiance	taub	0.297	0.302	0.342	0.380	0.414	0.427	0.432	0.433	0.390	0.348	0.316	0.293	
	taud	2.503	2.506	2.420	2.327	2.301	2.297	2.324	2.265	2.373	2.479	2.506	2.525	
	Ebn at Noon	288	300	294	286	277	272	270	267	275	279	278	283	
	Edh at Noon	26	29	35	40	42	42	40	42	36	30	26	24	
All-Sky Solar Radiation	RadAvg	850	1039	1359	1689	1835	2106	2129	1930	1598	1208	898	718	
	RadStd	86	157	84	118	187	207	115	120	143	153	115	83	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (34 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page