

CHANDLER, OK, USA

WMO: 722099

Lat: 35.724N

Lon: 96.820W

Elev: 300

StdP: 97.77

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 53936

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.8	-7.2	-15.3	1.0	-7.5	-12.5	1.3	-3.8	11.7	9.5	10.8	7.8	3.2	0	0.465

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.8	38.7	23.9	37.0	24.5	35.0	25.0	27.1	33.2	26.5	32.7	25.8	32.1	4.4	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.9	22.0	30.8	25.0	20.8	30.1	24.0	19.6	29.1	88.1	32.9	84.7	32.3	81.4	32.7	29.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.3	8.9	8.0	-15.3	39.9	3.9	3.1	-18.1	42.1	-20.4	44.0	-22.6	45.7	-25.5	48.0		
(5)			-15.7	28.0	3.8	0.8	-18.4	28.6	-20.6	29.1	-22.8	29.6	-25.5	30.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.6	4.8	6.2	12.1	16.3	20.8	25.7	28.1	27.6	23.6	17.2	10.9	5.6
	DBStd	9.63	6.01	6.44	5.83	4.98	4.32	3.67	2.79	3.30	3.72	5.16	5.20	5.60
	HDD10.0	588	181	138	44	9	1	2	0	0	0	7	50	156
	HDD18.3	1806	421	342	206	94	26	5	0	0	4	83	228	396
	CDD10.0	3011	19	31	109	198	337	473	562	546	408	231	77	19
	CDD18.3	1186	1	2	12	33	103	227	304	288	163	48	4	1
	CDH23.3	12918	3	16	104	336	912	2442	3656	3362	1588	447	48	4
	CDH26.7	6232	0	2	20	89	314	1156	1998	1808	707	131	6	0
Wind	WSAvg	3.4	3.6	3.8	4.3	4.3	3.4	3.1	2.7	2.7	2.7	3.2	3.6	3.5
Precipitation	PrecAvg	861	33	45	66	76	129	97	72	69	105	80	61	34
	PrecMax	1337	128	158	168	209	245	271	203	237	229	292	142	99
	PrecMin	530	0	0	0	6	32	18	4	6	11	6	0	2
	PrecStd	198	29	37	38	41	57	66	50	54	67	65	45	24
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.8	26.0	28.9	32.3	33.9	37.7	42.1	42.7	37.6	32.4	27.4	22.8
		MCWB	13.4	16.1	17.6	20.0	23.2	24.7	24.4	24.1	23.9	22.0	18.2	16.1
	2%	DB	20.2	22.2	26.3	29.0	32.1	35.9	39.0	38.8	34.8	30.1	24.8	19.7
		MCWB	12.7	13.9	16.5	19.0	23.1	24.8	24.0	23.8	24.1	21.8	16.4	13.2
	5%	DB	17.4	19.0	23.7	27.2	30.2	33.9	37.0	37.0	32.6	27.7	22.2	17.1
		MCWB	11.6	12.7	15.8	18.4	22.2	24.2	24.6	24.7	23.4	19.5	15.4	11.6
	10%	DB	14.2	16.9	21.4	25.1	27.9	32.5	34.9	34.7	31.1	26.0	19.6	14.1
		MCWB	8.5	11.8	14.7	17.8	21.6	24.4	25.3	25.0	23.0	19.3	14.1	9.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.1	17.6	20.1	22.5	25.6	28.2	28.2	27.9	26.2	24.4	20.5	18.4
		MCDB	18.4	21.7	26.1	27.4	30.5	34.5	34.4	34.0	34.1	29.8	24.5	21.6
	2%	WB	14.5	15.9	18.6	21.4	24.4	26.9	27.1	26.9	25.3	23.3	18.3	15.7
		MCDB	18.4	19.8	23.4	26.0	29.3	32.7	33.1	33.3	32.4	27.6	21.9	17.7
	5%	WB	11.6	14.2	17.5	20.2	23.4	26.2	26.4	26.2	24.6	22.2	16.8	12.7
		MCDB	16.7	18.3	21.5	24.7	28.2	31.9	32.5	32.9	30.9	25.7	20.1	14.7
	10%	WB	9.6	11.5	16.2	19.2	22.6	25.4	25.7	25.5	23.8	21.0	15.3	10.8
		MCDB	13.8	16.1	20.2	23.6	27.0	30.8	32.1	32.3	29.1	24.0	18.7	13.5
Mean Daily Temperature Range	5% DB	MDBR	11.5	11.6	12.3	12.3	10.9	11.3	11.8	11.9	12.3	12.6	12.3	10.9
		MCDBR	16.0	15.9	14.7	14.8	12.8	13.1	14.6	14.7	13.9	14.1	15.3	14.7
		MCWBR	9.9	9.6	7.9	7.8	5.7	5.0	4.3	4.3	5.4	7.0	8.7	9.1
	5% WB	MCDBR	14.5	13.7	11.8	12.5	10.9	11.3	11.5	11.7	11.9	10.9	12.8	11.1
		MCWBR	10.1	9.7	6.8	7.6	5.8	5.6	4.9	5.0	5.0	6.3	9.1	9.0
Clear-Sky Solar Irradiance	taub	0.297	0.302	0.342	0.380	0.414	0.427	0.432	0.433	0.390	0.348	0.316	0.293	
	taud	2.503	2.506	2.420	2.327	2.301	2.297	2.324	2.265	2.373	2.479	2.506	2.525	
	Ebn at Noon	909	945	928	903	873	857	850	843	866	879	877	891	
	Edh at Noon	81	91	109	126	131	132	127	132	113	93	81	75	
All-Sky Solar Radiation	RadAvg	2.68	3.27	4.28	5.32	5.79	6.64	6.71	6.08	5.04	3.81	2.83	2.26	
	RadStd	0.27	0.50	0.27	0.37	0.59	0.65	0.36	0.38	0.45	0.48	0.36	0.26	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (34 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page