

TREASURE COAST INTL, FL, USA

WMO: 722103

Lat: 27.498N

Lon: 80.377W

Elev: 7

StdP: 101.24

Time Zone: -5.00 (NAE)

Period: 99-19

WBAN: 12895

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 3.4	(c) 5.9	(d) -2.9	(e) 3.0	(f) 7.5	(g) 0.4	(h) 3.9	(i) 10.0	(j) 9.7	(k) 21.6	(l) 8.6	(m) 22.2	(n) 2.0	(o) 310	(p) 0.357

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 8.5	(c) 33.1	(d) 25.2	(e) 32.4	(f) 25.3	(g) 31.9	(h) 25.4	(i) 26.9	(j) 30.8	(k) 26.5	(l) 30.6	(m) 26.2	(n) 30.2	(o) 4.3	(p) 110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.9	21.2	28.8	25.3	20.4	28.7	25.0	20.1	28.5	83.8	30.8	82.2	30.4	80.8	30.4	28.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.8	8.0	7.3	0.3	35.3	1.9	1.0	-1.1	36.0	-2.2	36.6	-3.3	37.2	-4.7	37.9
			-1.0	27.5	1.8	0.5	-2.4	27.9	-3.4	28.2	-4.5	28.5	-5.8	28.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	22.9	16.6	18.4	19.9	22.2	24.7	26.7	27.4	27.6	26.9	24.6	21.0	19.0		
	DBStd	4.76	4.48	4.10	3.70	2.76	1.93	1.22	1.04	0.91	1.13	2.66	3.37	4.34		
	HDD10.0	11	6	2	0	0	0	0	0	0	0	0	0	3		
	HDD18.3	232	87	46	29	5	0	0	0	0	0	2	16	47		
	CDD10.0	4728	210	236	306	364	455	502	540	546	506	453	329	281		
	CDD18.3	1908	32	47	76	119	197	252	282	288	256	197	95	67		
	CDH23.3	16754	165	277	466	897	1728	2435	2876	2948	2436	1658	559	310		
(14) Wind	WSAvg	3.1	3.0	3.1	3.5	3.7	3.6	2.9	2.5	2.5	2.6	3.2	3.0	3.0		
	PrecAvg	1360	58	81	81	66	108	156	149	164	208	153	81	55		
	PrecMax	2038	240	246	316	263	329	402	334	449	506	363	237	208		
	PrecMin	830	5	2	2	4	9	20	21	33	37	17	7	3		
	PrecStd	276	45	58	66	52	64	77	76	84	111	90	61	50		
	DB	28.0	29.8	31.1	31.8	33.5	34.0	34.1	34.1	33.0	31.9	29.8	29.0			
	MCWB	21.3	21.3	22.3	22.3	23.4	25.0	25.4	25.4	25.2	24.7	23.8	23.0			
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	26.6	27.9	29.0	30.0	31.7	32.6	32.9	32.8	32.0	30.6	28.3	27.4			
	2% MCWB	20.9	21.4	21.6	22.5	23.5	25.1	25.6	25.8	25.7	24.7	23.0	22.3			
	5% DB	25.2	26.4	27.3	28.6	30.2	31.8	32.2	32.2	31.2	29.6	27.3	26.3			
	5% MCWB	20.2	20.9	21.3	22.1	23.5	25.2	25.7	25.9	25.4	24.4	22.3	21.6			
	10% DB	23.8	25.0	26.0	27.5	29.1	31.0	31.4	31.4	30.5	28.8	26.3	25.1			
	10% MCWB	19.5	20.1	20.4	21.3	23.1	25.0	25.6	25.7	25.1	23.8	21.2	20.9			
	WB	22.8	23.0	24.1	24.7	25.6	26.9	27.4	27.4	27.0	26.6	24.9	24.0			
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% MCDB	25.9	26.5	27.4	29.2	29.7	31.1	31.1	31.4	30.5	29.4	27.9	26.9			
	2% WB	21.8	22.4	23.0	23.8	24.9	26.3	26.8	26.8	26.5	25.7	24.1	23.3			
	2% MCDB	24.8	25.9	26.6	27.9	29.2	30.6	30.8	31.0	30.3	28.7	26.9	26.2			
	5% WB	21.2	21.7	22.2	23.1	24.4	25.8	26.4	26.5	26.0	25.2	23.4	22.6			
	5% MCDB	24.1	25.1	26.0	27.0	28.5	29.9	30.6	30.7	29.7	28.4	26.2	25.4			
	10% WB	20.4	21.0	21.3	22.5	23.9	25.4	25.9	26.1	25.7	24.7	22.6	21.8			
	10% MCDB	23.3	24.2	24.8	26.2	27.9	29.5	30.0	30.2	29.2	27.7	25.4	24.3			
(35) Mean Daily Temperature Range	MDBR	11.4	11.0	10.9	10.4	9.2	8.6	8.7	8.5	7.7	8.0	9.5	9.9			
	5% DB MCDBR	11.0	11.2	11.5	11.2	10.9	9.8	9.5	9.2	8.5	8.0	8.9	9.4			
	5% WB MCWBR	6.3	5.8	5.6	5.3	4.6	4.1	3.8	3.8	3.6	3.6	4.7	5.3			
	5% DB MCDBR	9.9	9.9	10.3	9.9	9.4	8.8	8.7	8.4	7.7	6.9	7.9	8.5			
	5% WB MCWBR	6.2	5.4	5.6	5.0	4.3	4.0	3.9	3.8	3.6	3.4	4.5	5.2			
(40) Clear-Sky Solar Irradiance	taub	0.348	0.356	0.371	0.396	0.426	0.452	0.469	0.458	0.425	0.395	0.364	0.359			
	taud	2.531	2.527	2.470	2.378	2.338	2.339	2.286	2.340	2.426	2.476	2.510	2.522			
	Ebn at Noon	899	920	921	902	870	841	826	835	857	866	873	869			
	Edh at Noon	90	98	109	123	128	127	134	126	113	102	92	88			
(44) All-Sky Solar Radiation	RadAvg	3.46	4.27	5.21	6.08	6.24	5.86	5.78	5.59	4.92	4.42	3.65	3.15			
	RadStd	0.24	0.24	0.30	0.21	0.47	0.50	0.38	0.35	0.25	0.29	0.18	0.22			

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.51	N/A	+1.82	N/A	N/A	N/A	N/A	N/A	+165	+151
(47) Regional (31 neighbors)		+0.40	+0.78	N/A	N/A	N/A	N/A	-1	-28	+145	+113

Nomenclature: See separate page