

FORT MYERS PAGE FIELD, FL, USA

WMO: 722106

Lat: 26.585N

Lon: 81.861W

Elev: 15

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 12835

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	42.8	46.6	27.0	21.0	54.1	31.9	26.4	54.3	21.8	62.9	19.6	65.2	6.3	30	0.359

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	14.9	93.3	76.7	92.2	76.7	91.1	76.7	80.3	87.8	79.7	87.1	79.0	86.4	7.9	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.5	147.9	82.9	77.7	143.9	82.5	77.1	141.1	82.2	43.7	87.6	43.0	86.8	42.4	86.6	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.6	16.7	15.0	DB	35.8	96.1	3.5	1.5	33.3	97.1	31.3	98.0	29.3	98.9	26.8	99.9
			WB	32.2	81.6	4.1	1.4	29.2	82.6	26.8	83.4	24.5	84.2	21.5	85.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	75.2	64.3	67.2	70.1	74.5	79.2	82.1	82.9	83.2	82.0	77.9	71.3	67.5
	DBStd	8.17	7.28	6.97	5.82	4.14	2.98	2.32	2.04	1.88	2.19	4.36	5.45	7.10
	HDD50	6	4	1	0	0	0	0	0	0	0	0	0	1
	HDD65	266	105	56	25	2	0	0	0	0	0	2	15	61
	CDD50	9211	446	483	625	735	905	962	1019	1029	961	864	638	544
	CDD65	3996	82	118	185	287	440	512	554	564	511	401	203	139
	CDH74	35770	436	733	1313	2313	4221	5045	5693	5784	4838	3342	1297	755
	CDH80	13170	40	121	287	714	1738	2163	2385	2384	1859	1099	268	112
Wind	WSAvg	6.8	7.3	7.3	8.0	7.8	7.2	6.1	5.3	5.5	6.2	7.3	7.2	7.0
Precipitation	PrecAvg	54.7	2.0	2.1	2.8	1.7	3.4	9.8	8.8	9.8	8.3	2.9	1.8	1.6
	PrecMax	74.8	8.0	10.8	18.6	5.7	10.3	20.1	14.5	16.8	17.2	11.0	8.1	5.2
	PrecMin	32.8	0.0	0.0	0.0	0.0	0.2	2.0	2.3	4.0	1.9	0.0	0.0	0.0
	PrecStd	10.0	1.9	1.8	3.1	1.5	2.5	4.3	3.1	3.5	3.7	2.6	1.9	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	83.4	86.1	87.3	90.0	93.4	95.2	94.7	94.4	93.1	91.0	87.8	85.1
		MCWB	70.1	70.4	70.7	72.2	73.2	76.8	77.2	77.8	77.4	76.4	74.8	72.3
	2%	DB	81.1	83.4	85.1	88.0	91.4	93.1	92.8	92.8	91.4	89.2	85.2	82.9
		MCWB	69.2	70.5	70.1	71.8	73.3	76.2	77.5	77.8	77.3	75.8	73.3	71.6
	5%	DB	79.0	81.3	83.3	86.3	89.9	91.4	91.3	91.4	90.3	87.7	83.1	81.1
		MCWB	68.0	69.8	69.7	71.1	73.3	76.3	77.5	77.9	77.1	75.1	71.7	70.7
	10%	DB	76.3	79.1	81.3	84.4	88.2	89.8	90.0	90.1	88.8	86.0	81.2	78.8
		MCWB	67.1	68.2	69.0	70.3	73.1	76.4	77.6	77.8	76.9	74.3	70.1	69.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.9	74.5	76.4	76.9	78.5	80.5	81.2	81.2	80.9	79.8	77.3	75.5
		MCDB	78.1	80.8	81.6	84.0	86.7	89.0	88.5	88.7	87.7	84.9	83.2	80.8
	2%	WB	72.0	73.0	74.5	75.4	77.5	79.4	80.1	80.2	79.8	78.3	75.6	74.1
		MCDB	76.9	79.3	80.1	82.6	85.6	87.6	87.7	87.9	86.5	84.2	81.7	79.2
	5%	WB	70.3	71.6	73.0	74.3	76.5	78.5	79.3	79.5	78.9	77.4	74.3	72.7
		MCDB	75.8	78.0	78.9	81.7	84.5	86.4	87.0	87.2	85.7	83.6	80.0	77.9
	10%	WB	68.8	70.3	71.4	73.0	75.6	77.8	78.5	78.8	78.2	76.6	72.7	71.2
		MCDB	74.4	76.4	77.5	80.5	83.4	85.6	86.1	86.3	85.0	82.4	78.3	76.6
Mean Daily Temperature Range	5% DB	MDBR	19.4	19.8	19.8	19.4	18.8	16.1	15.2	14.9	14.3	15.8	18.3	18.2
		MCDBR	19.8	19.8	20.2	20.5	20.2	18.5	16.7	16.4	15.9	16.2	17.8	17.8
		MCWBR	9.5	8.8	8.0	7.6	6.5	5.9	5.6	5.2	5.1	5.5	7.4	8.0
		MCDBR	17.0	17.5	16.7	17.5	17.2	15.9	15.3	14.9	14.3	13.8	15.6	15.7
	5% WB	MCWBR	9.9	8.9	8.9	8.2	6.5	6.0	5.9	5.5	5.4	5.4	7.7	8.8
Clear-Sky Solar Irradiance	taub		0.350	0.365	0.378	0.392	0.420	0.444	0.460	0.449	0.421	0.400	0.363	0.353
	taud		2.515	2.482	2.432	2.370	2.348	2.356	2.303	2.363	2.422	2.450	2.497	2.530
	Ebn at Noon		286	289	291	288	278	269	265	268	273	274	279	279
	Edh at Noon		30	33	36	39	40	40	42	39	36	33	30	28
All-Sky Solar Radiation	RadAvg		1178	1441	1753	2036	2093	1883	1848	1787	1612	1504	1271	1088
	RadStd		83	86	112	86	140	167	122	89	101	86	68	76

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.59	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+266	N/A
Regional (34 neighbors)	+0.74	+1.57	N/A	N/A	N/A	N/A	-2	-45	+263	+200

Nomenclature: See separate page