

FORT MYERS PAGE FIELD, FL, USA

WMO: 722106

Lat: 26.585N

Lon: 81.861W

Elev: 5

StdP: 101.27

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 12835

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.0	8.1	-2.8	3.0	12.3	0.0	3.8	12.4	9.7	17.2	8.8	18.5	2.8	30	0.359

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.3	34.1	24.8	33.4	24.9	32.8	24.8	26.8	31.0	26.5	30.6	26.1	30.2	3.5	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.8	21.1	28.3	25.4	20.6	28.1	25.1	20.2	27.9	83.7	30.9	82.1	30.4	80.8	30.3	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.3	7.5	6.7	DB	2.1	35.6	1.9	0.8	0.7	36.2	-0.4	36.7	-1.5	37.1	-2.9	37.7	(4)
			WB	0.1	27.6	2.3	0.8	-1.5	28.1	-2.9	28.6	-4.2	29.0	-5.8	29.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.0	17.9	19.6	21.2	23.6	26.2	27.8	28.3	28.4	27.8	25.5	21.8	19.7
	DBStd	4.54	4.04	3.87	3.24	2.30	1.65	1.29	1.13	1.04	1.22	2.42	3.03	3.94
	HDD10.0	3	2	1	0	0	0	0	0	0	0	0	0	1
	HDD18.3	148	58	31	14	1	0	0	0	0	0	1	8	34
	CDD10.0	5117	248	268	347	408	503	534	566	572	534	480	354	302
	CDD18.3	2220	46	66	103	159	244	284	308	313	284	223	113	77
	CDH23.3	19872	242	407	729	1285	2345	2803	3163	3213	2688	1857	721	419
CDH26.7	7317	22	67	159	397	966	1202	1325	1324	1033	611	149	62	
Wind	WSAvg	3.1	3.3	3.3	3.6	3.5	3.2	2.7	2.4	2.5	2.8	3.3	3.2	3.1
Precipitation	PrecAvg	1390	51	54	72	42	86	249	224	248	212	73	45	41
	PrecMax	1901	202	275	472	144	262	510	369	427	437	280	205	133
	PrecMin	834	0	0	1	0	5	50	58	101	49	1	0	0
	PrecStd	255	47	46	79	39	64	110	78	89	94	65	48	38
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.5	30.1	30.7	32.2	34.1	35.1	34.8	34.7	34.0	32.8	31.0	29.5
		MCWB	21.2	21.3	21.5	22.3	22.9	24.9	25.1	25.4	25.2	24.7	23.8	22.4
	2%	DB	27.3	28.5	29.5	31.1	33.0	33.9	33.8	33.8	33.0	31.8	29.6	28.3
		MCWB	20.7	21.4	21.1	22.1	23.0	24.5	25.3	25.4	25.2	24.3	22.9	22.0
	5%	DB	26.1	27.4	28.5	30.1	32.2	33.0	33.0	33.0	32.4	30.9	28.4	27.3
		MCWB	20.0	21.0	21.0	21.7	23.0	24.6	25.3	25.5	25.1	23.9	22.1	21.5
	10%	DB	24.6	26.1	27.4	29.1	31.2	32.1	32.2	32.3	31.6	30.0	27.3	26.0
		MCWB	19.5	20.1	20.5	21.3	22.8	24.7	25.3	25.5	24.9	23.5	21.2	20.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.3	23.6	24.7	24.9	25.9	27.0	27.3	27.3	27.2	26.6	25.1	24.2
		MCDB	25.6	27.1	27.5	28.9	30.4	31.6	31.4	31.5	30.9	29.4	28.4	27.1
	2%	WB	22.2	22.8	23.6	24.1	25.3	26.4	26.7	26.8	26.5	25.7	24.2	23.4
		MCDB	24.9	26.3	26.7	28.1	29.8	30.9	31.0	31.0	30.3	29.0	27.6	26.2
	5%	WB	21.3	22.0	22.8	23.5	24.7	25.8	26.3	26.4	26.1	25.2	23.5	22.6
		MCDB	24.3	25.6	26.1	27.6	29.2	30.2	30.6	30.7	29.8	28.6	26.7	25.5
	10%	WB	20.5	21.3	21.9	22.8	24.2	25.5	25.8	26.0	25.7	24.8	22.6	21.8
		MCDB	23.5	24.7	25.3	27.0	28.6	29.8	30.1	30.1	29.4	28.0	25.7	24.8
Mean Daily Temperature Range	5% DB	MDBR	10.8	11.0	11.0	10.8	10.5	9.0	8.4	8.3	7.9	8.8	10.1	10.1
		MCDBR	11.0	11.0	11.2	11.4	11.2	10.3	9.3	9.1	8.8	9.0	9.9	9.9
		MCWBR	5.3	4.9	4.4	4.2	3.6	3.3	3.1	2.9	2.8	3.0	4.1	4.5
	5% WB	MCDBR	9.4	9.7	9.3	9.7	9.5	8.8	8.5	8.3	8.0	7.7	8.7	8.7
		MCWBR	5.5	4.9	4.9	4.5	3.6	3.3	3.3	3.1	3.0	3.0	4.3	4.9
Clear-Sky Solar Irradiance	taub	0.350	0.365	0.378	0.392	0.420	0.444	0.460	0.449	0.421	0.400	0.363	0.353	
	taud	2.515	2.482	2.432	2.370	2.348	2.356	2.303	2.363	2.422	2.450	2.497	2.530	
	Ebn at Noon	901	912	916	907	876	849	834	844	862	864	878	881	
	Edh at Noon	93	103	114	124	127	125	132	124	114	105	94	88	
All-Sky Solar Radiation	RadAvg	3.71	4.54	5.53	6.42	6.60	5.94	5.83	5.63	5.08	4.74	4.01	3.43	
	RadStd	0.26	0.27	0.35	0.27	0.44	0.53	0.39	0.28	0.32	0.27	0.21	0.24	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.33	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+148	N/A
Regional (34 neighbors)		+0.41	+0.87	N/A	N/A	N/A	N/A	-1	-25	+146	+111

Nomenclature: See separate page