

CHEROKEE COUNTY AP, GA, USA

WMO: 722109

Lat: 34.317N

Lon: 84.417W

Elev: 1221

StdP: 14.06

Time Zone: -5.00 (NAE)

Period: 04-19

WBAN: 00355

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.8	26.6	-7.8	3.8	40.5	-0.3	5.7	38.4	18.9	39.3	17.3	38.4	5.7	310	0.347

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.9	93.0	69.7	90.9	70.4	89.9	70.3	77.1	84.6	75.4	84.0	74.1	82.1	3.8	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
74.9	137.0	79.6	73.0	128.3	78.0	72.3	125.0	77.5	41.5	82.9	39.7	83.1	38.4	82.8	82.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.4	12.5	10.9	14.8	96.6	4.7	3.7	11.4	99.3	8.7	101.5	6.0	103.6	2.6	106.3		
			12.6	76.9	4.0	2.5	9.7	78.8	7.4	80.2	5.1	81.7	2.2	83.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.5	42.7	45.3	53.4	61.6	68.8	76.1	78.5	78.1	72.8	62.0	51.9	45.7
	DBStd	14.69	9.68	9.31	8.83	7.19	6.72	3.86	3.25	3.64	5.24	7.77	7.63	8.33
	HDD50	791	267	186	67	8	0	0	0	0	8	66	189	
	HDD65	2959	692	554	370	146	46	0	0	6	147	398	600	
	CDD50	4984	40	54	173	354	582	784	883	872	684	380	122	56
	CDD65	1679	0	2	11	43	163	335	418	407	241	54	4	1
	CDH74	14620	0	9	103	515	1492	2943	3701	3532	1896	409	20	0
	CDH80	5581	0	0	10	83	444	1180	1567	1520	689	88	0	0
Wind	WSAvg	3.6	5.1	5.0	5.0	4.5	3.1	2.2	2.1	2.2	2.7	3.1	3.8	4.4
Precipitation	PrecAvg	57.2	5.6	5.0	5.7	4.3	3.9	4.6	5.1	4.4	4.4	3.7	4.8	4.5
	PrecMax	65.5	10.0	8.9	10.5	10.1	8.7	8.3	11.9	7.6	11.4	8.4	9.0	8.4
	PrecMin	45.9	2.4	2.3	2.3	1.8	1.1	0.9	1.6	1.8	0.6	0.2	1.7	2.4
	PrecStd	5.9	1.9	1.9	2.4	2.0	1.7	1.9	2.6	1.9	2.6	2.4	1.8	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	69.9	74.7	81.3	85.9	90.3	94.9	95.5	98.6	93.3	88.1	77.1	72.0
		MCWB	56.2	62.8	61.0	61.2	68.2	70.2	70.2	68.5	67.0	68.4	58.3	58.8
	2%	DB	64.3	68.3	77.0	82.0	87.9	91.2	91.5	92.9	90.4	81.6	72.3	67.8
		MCWB	54.6	56.8	58.5	60.4	66.8	69.6	71.6	70.2	67.6	63.8	58.2	60.5
	5%	DB	62.1	64.1	72.8	80.7	84.5	90.0	90.4	90.5	87.9	79.0	68.5	63.3
		MCWB	54.2	54.7	56.1	59.5	65.2	69.7	71.8	71.1	67.9	62.9	57.0	56.7
	10%	DB	57.2	61.2	69.6	77.1	81.9	87.6	88.3	88.3	83.8	74.8	64.3	59.2
		MCWB	50.8	52.0	54.8	58.8	64.4	69.6	71.9	70.7	67.2	61.9	54.8	52.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.7	66.1	65.8	70.4	73.6	76.9	79.6	78.9	73.6	73.7	67.9	65.6
		MCDB	63.0	71.5	75.8	78.5	83.6	86.7	85.9	86.3	81.8	76.3	71.5	68.1
	2%	WB	58.0	63.0	63.0	67.0	71.8	74.9	77.6	76.5	72.3	70.2	64.0	62.0
		MCDB	62.7	65.8	69.9	75.2	80.4	84.4	84.8	84.0	80.2	76.1	66.8	64.8
	5%	WB	55.4	58.1	60.1	64.5	70.0	73.4	76.2	74.6	71.3	67.6	61.1	58.3
		MCDB	60.4	62.3	67.9	72.1	77.7	82.6	84.2	83.1	78.9	74.3	64.6	62.4
	10%	WB	52.8	54.1	57.6	62.0	68.5	72.3	74.7	73.2	70.2	65.4	57.9	54.0
		MCDB	56.6	58.8	65.6	69.5	76.9	80.9	82.5	81.3	77.6	72.6	63.4	57.4
Mean Daily Temperature Range	5% DB	MDBR	17.5	18.6	20.4	23.4	21.4	20.0	18.9	19.4	20.0	21.1	20.4	16.6
		MCDBR	21.4	23.4	25.9	27.8	25.1	23.8	22.0	23.3	25.0	24.4	24.7	20.0
		MCWBR	13.7	14.0	11.5	10.2	8.2	7.3	6.6	6.7	7.2	9.7	13.0	13.0
	5% WB	MCDBR	15.7	17.9	20.2	20.7	20.4	19.9	18.9	18.7	19.1	16.5	15.9	15.7
		MCWBR	12.5	13.6	12.1	10.5	8.3	7.8	7.5	7.2	7.1	8.8	12.7	13.2
Clear-Sky Solar Irradiance	taub	0.309	0.313	0.346	0.386	0.445	0.470	0.513	0.513	0.412	0.365	0.336	0.309	
	taud	2.533	2.520	2.450	2.328	2.191	2.158	2.057	2.044	2.309	2.441	2.468	2.551	
	Ebn at Noon	287	298	294	286	268	261	249	246	269	275	273	280	
	Edh at Noon	26	29	34	40	47	48	53	53	39	31	27	24	
All-Sky Solar Radiation	RadAvg	822	996	1346	1708	1892	1963	1862	1739	1496	1248	920	694	
	RadStd	56	128	109	110	150	148	139	99	146	153	102	73	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (39 neighbors)	+0.88	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+263	+182

Nomenclature: See separate page