

CHEROKEE COUNTY AP, GA, USA

WMO: 722109

Lat: 34.317N

Lon: 84.417W

Elev: 372

StdP: 96.93

Time Zone: -5.00 (NAE)

Period: 04-19

WBAN: 00355

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -6.2	(c) -3.0	(d) -22.1	(e) 0.5	(f) 4.7	(g) -17.9	(h) 0.8	(i) 3.6	(j) 8.4	(k) 4.1	(l) 7.7	(m) 3.6	(n) 2.6	(o) 310	(p) 0.347

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.5	33.9	20.9	32.7	21.4	32.1	21.3	25.0	29.2	24.1	28.9	23.4	27.8	1.7	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.8	19.6	26.4	22.8	18.3	25.6	22.4	17.9	25.3	78.5	28.3	74.5	28.4	71.4	28.2	27.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.9	5.6	4.9	-9.5	35.9	2.6	2.1	-11.4	37.4	-13.0	38.6	-14.4	39.8	-16.3	41.3		
			-10.8	25.0	2.2	1.4	-12.4	26.0	-13.7	26.8	-14.9	27.6	-16.6	28.6		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.4	5.9	7.4	11.9	16.4	20.4	24.5	25.8	25.6	22.7	16.7	11.0	7.6		
	DBStd	8.16	5.38	5.17	4.91	4.00	3.73	2.14	1.81	2.02	2.91	4.32	4.24	4.63		
	HDD10.0	439	148	103	37	4	0	0	0	0	0	4	37	105		
	HDD18.3	1644	384	308	206	81	26	0	0	0	3	82	221	333		
	CDD10.0	2769	22	30	96	197	323	436	491	484	380	211	68	31		
	CDD18.3	933	0	1	6	24	91	186	232	226	134	30	2	1		
	CDH23.3	8122	0	5	57	286	829	1635	2056	1962	1053	227	11	0		
	CDH26.7	3101	0	0	6	46	247	656	871	844	383	49	0	0		
(14) Wind	WSAvg	1.6	2.3	2.2	2.3	2.0	1.4	1.0	1.0	1.0	1.2	1.4	1.7	2.0		
(15) Precipitation	PrecAvg	1453	141	127	146	108	98	117	129	112	111	93	122	115		
	PrecMax	1664	255	227	267	257	222	211	302	192	290	214	229	214		
	PrecMin	1167	62	58	59	46	29	23	41	46	14	5	43	62		
	PrecStd	150	49	48	60	50	44	48	65	48	66	61	45	45		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.0	23.7	27.4	29.9	32.4	35.0	35.3	37.0	34.1	31.2	25.0	22.2		
		MCWB	13.4	17.1	16.1	16.2	20.1	21.2	21.2	20.3	19.4	20.2	14.6	14.9		
	2%	DB	17.9	20.2	25.0	27.8	31.0	32.9	33.0	33.8	32.4	27.5	22.4	19.9		
		MCWB	12.6	13.8	14.7	15.8	19.3	20.9	22.0	21.2	19.8	17.7	14.5	15.8		
	5%	DB	16.7	17.8	22.7	27.0	29.2	32.2	32.4	32.5	31.1	26.1	20.3	17.4		
		MCWB	12.4	12.6	13.4	15.3	18.5	21.0	22.1	21.7	19.9	17.2	13.9	13.7		
	10%	DB	14.0	16.2	20.9	25.0	27.7	30.9	31.3	31.3	28.8	23.8	17.9	15.1		
		MCWB	10.5	11.1	12.7	14.9	18.0	20.9	22.2	21.5	19.5	16.6	12.7	11.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.9	18.9	18.8	21.3	23.1	25.0	26.4	26.0	23.1	23.2	20.0	18.7		
		MCDB	17.2	21.9	24.3	25.8	28.7	30.4	30.0	30.2	27.7	24.6	21.9	20.1		
	2%	WB	14.4	17.2	17.2	19.4	22.1	23.8	25.3	24.7	22.4	21.2	17.8	16.7		
		MCDB	17.0	18.8	21.1	24.0	26.9	29.1	29.4	28.9	26.8	24.5	19.3	18.2		
	5%	WB	13.0	14.5	15.6	18.1	21.1	23.0	24.5	23.7	21.8	19.8	16.2	14.6		
		MCDB	15.8	16.9	19.9	22.3	25.4	28.1	29.0	28.4	26.1	23.5	18.1	16.9		
	10%	WB	11.6	12.3	14.2	16.7	20.3	22.4	23.7	22.9	21.2	18.6	14.4	12.2		
		MCDB	13.7	14.9	18.7	20.8	24.9	27.2	28.0	27.4	25.3	22.6	17.5	14.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.7	10.4	11.3	13.0	11.9	11.1	10.5	10.8	11.1	11.7	11.4	9.2		
		MCDBR	11.9	13.0	14.4	15.4	13.9	13.2	12.2	12.9	13.9	13.6	13.7	11.1		
	5% WB	MCWBR	7.6	7.8	6.4	5.7	4.6	4.0	3.7	3.7	4.0	5.4	7.2	7.2		
		MCWBR	8.7	9.9	11.2	11.5	11.3	11.0	10.5	10.4	10.6	9.2	8.8	8.7		
(40) Clear-Sky Solar Irradiance	taub		0.309	0.313	0.346	0.386	0.445	0.470	0.513	0.513	0.412	0.365	0.336	0.309		
		taud	2.533	2.520	2.450	2.328	2.191	2.158	2.057	2.044	2.309	2.441	2.468	2.551		
	Ebn at Noon		906	940	928	901	846	822	784	776	847	867	862	884		
		Edh at Noon	81	92	107	126	147	152	167	166	122	98	86	76		
(44) All-Sky Solar Radiation	RadAvg		2.59	3.14	4.24	5.39	5.96	6.19	5.87	5.48	4.72	3.94	2.90	2.19		
	RadStd		0.17	0.40	0.34	0.35	0.47	0.47	0.44	0.31	0.46	0.48	0.32	0.23		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (39 neighbors)		+0.49	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+146	+101

Nomenclature: See separate page