

GILMER, TX, USA

WMO: 722112

Lat: 32.699N

Lon: 94.949W

Elev: 127

StdP: 99.81

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 53982

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.8	-1.3	-10.3	1.6	2.2	-7.8	2.0	2.7	8.4	13.8	7.7	14.1	1.1	0	0.379

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.8	37.2	24.7	36.0	24.5	34.1	24.3	26.5	32.2	26.0	31.8	25.6	31.4	2.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.2	20.6	28.0	24.4	19.6	27.8	24.0	19.2	27.6	83.0	32.1	81.0	32.4	79.2	31.3	28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.5	6.6	5.6	-6.2	38.4	2.0	1.1	-7.7	39.3	-8.9	39.9	-10.0	40.6	-11.5	41.4		
			-7.5	27.4	1.9	0.8	-8.9	28.0	-10.1	28.4	-11.1	28.9	-12.5	29.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.0	8.6	10.4	15.0	18.5	22.9	27.1	28.1	28.5	25.4	19.3	13.6	9.5
	DBStd	8.31	5.43	5.77	5.12	4.25	3.44	2.29	1.98	2.27	3.00	4.68	5.19	5.30
	HDD10.0	269	92	61	14	2	0	0	0	0	0	1	23	76
	HDD18.3	1197	304	228	128	49	7	0	0	0	1	46	157	278
	CDD10.0	3539	49	72	171	257	398	514	560	574	461	291	132	61
	CDD18.3	1426	3	6	25	54	147	264	302	316	211	77	16	4
	CDH23.3	14843	7	24	156	430	1299	2916	3455	3717	2104	643	78	13
	CDH26.7	6741	0	2	17	86	446	1390	1698	1929	966	198	8	1
Wind	WSAvg	2.1	2.4	2.6	2.8	2.8	2.3	2.0	1.7	1.5	1.5	1.8	2.1	2.2
Precipitation	PrecAvg	1232	107	97	111	103	114	112	87	77	98	115	101	108
	PrecMax	1720	254	218	211	235	192	222	246	225	263	402	262	211
	PrecMin	668	7	1	41	35	16	13	1	6	25	8	12	12
	PrecStd	283	62	57	48	60	57	66	64	46	69	91	61	56
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.1	26.2	28.0	31.3	33.2	37.4	37.8	37.9	37.2	32.5	27.8	25.0
		MCWB	17.3	17.3	19.1	21.9	23.2	24.5	24.7	24.8	23.2	21.8	20.9	19.0
	2%	DB	22.5	23.7	27.1	28.7	32.2	36.0	36.3	37.3	34.9	31.0	25.9	22.8
		MCWB	16.5	17.1	18.8	20.7	23.1	24.3	24.8	25.0	23.2	22.4	19.9	18.6
	5%	DB	20.5	22.2	25.2	27.4	31.0	34.0	34.6	36.1	33.0	28.9	23.4	21.1
		MCWB	16.2	17.0	17.9	20.0	22.8	24.1	24.8	24.7	23.3	21.4	19.1	17.7
	10%	DB	18.0	19.8	22.9	26.1	29.0	32.8	33.4	34.2	32.2	27.3	22.1	18.9
		MCWB	14.2	15.8	17.3	19.1	22.3	24.4	24.7	24.6	23.1	21.0	18.7	15.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.7	20.1	21.4	23.5	25.5	26.9	26.9	27.4	26.1	25.1	22.3	21.1
		MCDB	22.3	23.3	25.9	27.7	29.9	32.0	31.2	32.7	30.7	28.8	25.5	23.1
	2%	WB	18.6	19.2	20.3	22.5	24.5	26.1	26.3	26.6	25.4	24.1	21.4	19.6
		MCDB	20.9	22.0	24.4	26.6	29.2	31.9	31.8	32.8	30.4	27.7	24.2	22.0
	5%	WB	17.4	18.2	19.5	21.7	23.8	25.6	25.8	26.1	24.9	23.3	20.4	18.5
		MCDB	19.2	20.6	23.4	25.7	28.6	31.3	31.5	32.3	29.8	26.8	23.0	20.7
	10%	WB	14.7	16.7	18.7	20.8	23.2	25.1	25.4	25.6	24.3	22.4	18.9	16.6
		MCDB	17.4	19.1	22.3	24.4	27.8	30.6	31.2	31.7	29.1	25.6	21.5	18.3
Mean Daily Temperature Range	5% DB	MDBR	10.5	10.3	11.3	11.6	10.6	10.3	10.2	10.8	11.5	11.6	11.2	10.6
		MCDBR	13.1	12.1	12.0	12.2	11.5	11.8	11.7	12.5	12.9	12.3	11.9	12.4
		MCWBR	8.2	7.5	5.7	5.8	4.1	3.3	3.0	3.1	4.0	5.0	7.0	8.8
	5% WB	MCDBR	10.6	10.4	10.0	9.9	9.9	9.9	9.8	10.7	10.2	9.8	10.1	10.7
		MCWBR	8.3	7.9	5.9	5.6	4.4	3.7	3.4	3.4	3.6	5.0	7.4	8.6
Clear-Sky Solar Irradiance	taub	0.322	0.337	0.359	0.396	0.427	0.448	0.461	0.458	0.410	0.360	0.345	0.327	
	taud	2.496	2.464	2.419	2.317	2.288	2.271	2.269	2.270	2.362	2.478	2.469	2.495	
	Ebn at Noon	898	918	919	894	864	842	829	827	856	880	862	871	
	Edh at Noon	87	99	111	129	134	136	135	133	117	96	89	83	
All-Sky Solar Radiation	RadAvg	2.73	3.08	4.29	5.33	5.80	6.33	6.40	5.98	5.06	4.04	2.94	2.39	
	RadStd	0.25	0.50	0.38	0.34	0.46	0.56	0.46	0.47	0.45	0.56	0.36	0.31	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (32 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page