

CROSS CITY, FL, USA

WMO: 722120

Lat: 29.633N

Lon: 83.105W

Elev: 38

StdP: 14.68

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 12833

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.5	30.8	15.4	12.0	37.8	20.0	15.0	41.2	20.7	67.3	18.7	63.5	1.7	30	0.347

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	16.6	93.8	76.8	92.3	76.6	90.9	76.3	80.6	87.7	79.8	87.1	78.9	86.3	6.8	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.0	150.6	83.5	77.8	144.9	83.1	77.0	140.6	82.6	44.2	88.0	43.1	86.8	42.3	86.4	86.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.5	15.3	12.7	21.2	97.0	3.1	2.2	18.9	98.6	17.1	99.9	15.3	101.2	13.1	102.8		
			19.9	81.9	3.6	1.5	17.3	83.0	15.2	83.9	13.2	84.8	10.6	85.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	69.1	53.4	57.6	62.1	68.0	75.0	80.2	81.2	81.6	79.0	71.3	61.8	57.2
	DBStd	11.87	9.32	8.72	7.61	5.97	4.34	2.90	2.20	2.28	3.26	7.04	7.96	9.38
	HDD50	157	73	28	8	0	0	0	0	0	0	0	8	40
	HDD65	1241	371	229	145	39	2	0	0	0	0	29	151	275
	CDD50	7126	179	242	382	541	774	907	968	980	869	661	362	261
	CDD65	2736	12	23	54	130	311	457	503	515	419	225	55	32
	CDH74	25031	76	164	482	1315	3128	4335	4776	4850	3475	1819	435	176
	CDH80	9782	1	15	62	328	1263	1942	2080	2049	1419	551	62	10
(14) Wind	WSAvg	4.9	5.3	5.6	6.0	5.6	5.0	4.5	3.9	4.0	4.6	4.7	4.8	5.1
(15) Precipitation	PrecAvg	54.2	3.9	3.0	4.1	3.1	2.0	6.9	8.5	8.1	5.9	3.4	2.2	2.9
	PrecMax	71.0	8.4	12.0	14.3	9.4	5.2	15.9	21.2	14.2	16.6	7.4	5.7	7.9
	PrecMin	34.1	1.1	0.5	0.6	0.5	0.0	2.3	4.1	3.9	2.4	0.4	0.2	0.6
	PrecStd	10.1	2.0	2.4	3.0	2.1	1.5	2.4	3.8	3.0	3.7	2.0	1.3	2.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.3	82.2	84.8	88.5	93.4	96.0	95.3	95.2	93.3	90.1	84.5	81.4
		MCWB	67.5	67.3	66.9	70.5	73.1	76.3	77.5	78.4	76.5	75.3	72.3	70.1
	2%	DB	76.3	78.7	81.7	85.9	90.8	93.5	93.2	93.0	91.2	87.8	81.7	78.7
		MCWB	66.2	66.7	67.0	69.2	71.9	76.1	77.2	78.1	76.1	74.3	70.1	68.8
	5%	DB	72.8	75.5	79.4	83.8	88.9	91.5	91.5	91.3	89.9	85.6	79.1	75.6
		MCWB	64.4	64.9	66.1	68.7	71.6	76.0	77.1	77.9	75.7	72.9	67.9	67.8
	10%	DB	69.3	72.4	76.6	81.6	86.8	89.6	89.8	89.8	88.0	83.3	76.3	72.5
		MCWB	62.9	63.5	64.5	67.8	71.3	75.8	77.3	77.9	75.6	71.6	66.3	66.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.6	71.5	73.2	75.0	77.5	81.1	82.6	81.8	80.1	78.4	75.8	73.3
		MCDB	75.5	76.9	78.0	82.4	85.1	88.3	87.7	89.1	87.3	84.9	80.8	77.5
	2%	WB	68.5	69.5	71.0	73.2	76.1	79.5	80.7	80.6	78.7	77.1	73.3	71.5
		MCDB	72.9	75.1	76.5	80.7	84.4	87.7	87.2	88.0	86.3	83.3	78.3	75.4
	5%	WB	66.5	68.0	69.2	71.8	75.1	78.3	79.6	79.9	78.0	75.8	71.1	69.8
		MCDB	70.9	73.4	75.1	79.4	83.6	86.8	86.6	87.2	85.6	82.1	75.6	73.9
	10%	WB	64.1	65.8	67.3	70.4	74.0	77.4	78.6	79.0	77.2	74.5	68.7	67.4
		MCDB	68.5	70.4	73.7	77.9	82.4	85.9	86.0	86.2	84.6	80.4	73.9	71.8
(35) Mean Daily Temperature Range	5% DB	MDBR	24.4	24.1	25.3	25.1	23.6	19.0	17.5	16.6	18.1	22.1	25.2	23.6
		MCDBR	24.9	24.9	26.2	26.6	25.8	22.0	20.3	19.1	20.4	21.5	24.4	22.7
		MCWBR	15.8	14.5	13.7	12.3	10.4	8.1	7.7	7.1	7.7	9.7	13.6	14.3
	5% WB	MCDBR	20.8	19.7	20.2	21.4	20.9	18.4	17.4	16.7	16.7	17.1	19.1	18.5
		MCWBR	14.8	13.0	12.7	11.7	9.2	7.8	8.0	7.1	7.1	8.4	12.2	13.1
(40) Clear-Sky Solar Irradiance	taub		0.338	0.345	0.365	0.390	0.426	0.461	0.497	0.476	0.432	0.384	0.354	0.337
	taud		2.513	2.496	2.445	2.351	2.302	2.275	2.179	2.246	2.351	2.465	2.483	2.540
	Ebn at Noon		285	293	292	287	275	264	254	259	268	276	277	280
	Edh at Noon		28	31	35	40	42	43	47	44	38	32	29	27
(44) All-Sky Solar Radiation	RadAvg		1046	1252	1646	1974	2145	1943	1850	1741	1586	1443	1161	945
	RadStd		72	129	147	139	124	120	128	124	132	108	72	80

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (34 neighbors)	+0.81	N/A	N/A	N/A	N/A	N/A	-16	-101	+275	+198

Nomenclature: See separate page