

CROSS CITY, FL, USA

WMO: 722120

Lat: 29.633N

Lon: 83.105W

Elev: 12

StdP: 101.19

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 12833

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.5	-0.7	-9.2	1.7	3.2	-6.7	2.1	5.1	9.2	19.6	8.4	17.5	0.8	30	0.347

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.2	34.3	24.9	33.5	24.8	32.7	24.6	27.0	30.9	26.6	30.6	26.1	30.2	3.0	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.1	21.5	28.6	25.5	20.7	28.4	25.0	20.1	28.1	84.9	31.1	82.5	30.4	80.6	30.2	30.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.8	6.8	5.7	-6.0	36.1	1.7	1.2	-7.3	37.0	-8.3	37.7	-9.3	38.4	-10.5	39.3		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			-6.7	27.7	2.0	0.9	-8.1	28.4	-9.3	28.9	-10.4	29.3	-11.9	30.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.6	11.9	14.2	16.7	20.0	23.9	26.8	27.3	27.6	26.1	21.8	16.6	14.0	
	DBStd	6.60	5.18	4.84	4.23	3.32	2.41	1.61	1.22	1.26	1.81	3.91	4.42	5.21	
	HDD10.0	87	41	16	4	0	0	0	0	0	0	4	22		
	HDD18.3	689	206	127	81	22	1	0	0	0	16	84	153		
	CDD10.0	3959	99	134	212	301	430	504	538	544	483	367	201	145	
	CDD18.3	1520	7	13	30	72	173	254	279	286	233	125	31	18	
	CDH23.3	13906	42	91	268	731	1738	2408	2653	2694	1931	1011	242	98	
	CDH26.7	5434	1	8	34	182	702	1079	1156	1138	788	306	34	6	
Wind	WSAvg	2.2	2.4	2.5	2.7	2.5	2.3	2.0	1.7	1.8	2.0	2.1	2.2	2.3	
Precipitation	PrecAvg	1376	98	77	103	80	52	175	216	207	151	86	56	74	
	PrecMax	1804	213	306	363	238	132	404	539	361	422	188	145	201	
	PrecMin	866	28	12	16	13	0	58	104	99	61	10	5	15	
	PrecStd	257	51	62	76	54	39	60	97	76	94	50	34	54	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.3	27.9	29.3	31.4	34.1	35.6	35.2	35.1	34.0	32.3	29.2	27.4	
		MCWB	19.7	19.6	19.4	21.4	22.8	24.6	25.3	25.8	24.7	24.1	22.4	21.2	
	2%	DB	24.6	26.0	27.6	29.9	32.7	34.2	34.0	33.9	32.9	31.0	27.6	26.0	
		MCWB	19.0	19.3	19.4	20.7	22.2	24.5	25.1	25.6	24.5	23.5	21.2	20.5	
	5%	DB	22.7	24.2	26.3	28.8	31.6	33.0	33.0	33.0	32.1	29.8	26.2	24.2	
		MCWB	18.0	18.3	18.9	20.4	22.0	24.4	25.1	25.5	24.3	22.7	19.9	19.9	
	10%	DB	20.7	22.4	24.8	27.6	30.5	32.0	32.1	32.1	31.1	28.5	24.6	22.5	
		MCWB	17.1	17.5	18.0	19.9	21.8	24.3	25.2	25.5	24.2	22.0	19.0	19.2	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.4	21.9	22.9	23.9	25.3	27.3	28.1	27.7	26.7	25.8	24.3	23.0
			MCDB	24.2	25.0	25.5	28.0	29.5	31.3	31.0	31.7	30.7	29.4	27.1	25.3
2%		WB	20.3	20.8	21.6	22.9	24.5	26.4	27.0	27.0	26.0	25.0	23.0	21.9	
		MCDB	22.7	23.9	24.7	27.0	29.1	30.9	30.6	31.1	30.2	28.5	25.7	24.1	
5%		WB	19.1	20.0	20.7	22.1	23.9	25.7	26.4	26.6	25.6	24.4	21.7	21.0	
		MCDB	21.6	23.0	23.9	26.3	28.7	30.4	30.3	30.7	29.8	27.9	24.2	23.3	
10%		WB	17.8	18.8	19.6	21.3	23.3	25.2	25.9	26.1	25.1	23.6	20.4	19.6	
		MCDB	20.3	21.3	23.2	25.5	28.0	30.0	30.0	30.1	29.2	26.9	23.3	22.1	
Mean Daily Temperature Range	5% DB	MDBR	13.6	13.4	14.1	13.9	13.1	10.5	9.7	9.2	10.0	12.3	14.0	13.1	
		MCDBR	13.8	13.9	14.6	14.8	14.4	12.2	11.3	10.6	11.3	11.9	13.5	12.6	
		MCWBR	8.8	8.0	7.6	6.9	5.8	4.5	4.3	3.9	4.3	5.4	7.6	8.0	
	5% WB	MCDBR	11.6	10.9	11.2	11.9	11.6	10.2	9.7	9.3	9.3	9.5	10.6	10.3	
		MCWBR	8.2	7.2	7.1	6.5	5.1	4.3	4.4	3.9	4.0	4.7	6.8	7.3	
Clear-Sky Solar Irradiance	taub	0.338	0.345	0.365	0.390	0.426	0.461	0.497	0.476	0.432	0.384	0.354	0.337		
	taud	2.513	2.496	2.445	2.351	2.302	2.275	2.179	2.246	2.351	2.465	2.483	2.540		
	Ebn at Noon	898	923	922	905	868	833	802	817	844	869	872	882		
	Edh at Noon	89	99	111	126	133	136	149	138	120	101	91	84		
All-Sky Solar Radiation	RadAvg	3.30	3.95	5.19	6.22	6.76	6.12	5.83	5.49	5.00	4.55	3.66	2.98		
	RadStd	0.23	0.41	0.46	0.44	0.39	0.38	0.40	0.39	0.41	0.34	0.23	0.25		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (34 neighbors)	+0.45	N/A	N/A	N/A	N/A	N/A	-9	-56	+153	+110

Nomenclature: See separate page