

WAYCROSS-WARE COUNTY AP, GA, USA

WMO: 722130

Lat: 31.250N

Lon: 82.400W

Elev: 142

StdP: 14.62

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 13861

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.1	31.9	12.6	10.5	43.1	18.6	14.1	41.6	22.2	60.9	19.2	57.6	2.8	290	0.363

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.0	97.3	78.3	95.2	77.6	93.1	77.2	82.3	91.2	81.4	90.0	80.5	88.7	6.5	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.4	158.4	85.8	79.3	152.8	85.1	78.7	149.7	84.5	46.0	91.8	45.0	89.5	44.1	89.1	86.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.0	15.7	12.9	DB	23.7	99.0	3.5	2.6	21.2	100.8	19.2	102.3	17.2	103.8	14.7	105.6	
			WB	21.3	83.3	3.2	1.6	19.0	84.5	17.2	85.4	15.4	86.3	13.1	87.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	69.0	52.5	56.2	62.0	68.4	75.5	81.5	83.3	82.8	79.0	70.3	60.6	55.8
	DBStd	12.90	9.70	8.88	8.37	6.68	5.35	3.92	2.89	2.83	4.18	7.13	8.18	9.48
	HDD50	192	89	35	10	1	0	0	0	0	0	0	10	47
	HDD65	1398	399	270	157	42	3	0	0	0	0	34	180	313
	CDD50	7146	166	208	381	553	790	944	1031	1018	870	630	328	227
	CDD65	2875	11	22	63	144	328	494	566	553	420	199	47	28
	CDH74	28155	74	163	578	1431	3297	5099	6067	5658	3729	1558	361	140
	CDH80	12241	4	18	129	454	1446	2503	2974	2617	1545	476	58	17
(14) Wind	WSAvg	5.0	5.6	5.6	6.0	5.7	5.4	4.6	4.4	4.1	4.6	4.5	4.7	5.1
(15) Precipitation	PrecAvg	50.8	4.5	3.8	4.6	3.0	3.5	5.9	6.4	6.3	4.1	2.6	2.5	3.4
	PrecMax	73.7	14.8	8.5	11.7	10.5	12.0	12.3	13.5	11.2	18.2	8.9	7.6	6.9
	PrecMin	33.0	0.7	0.8	0.3	0.2	0.2	1.0	1.3	1.5	0.4	0.0	0.1	0.4
	PrecStd	9.2	2.8	1.9	2.8	2.3	2.6	2.6	2.5	2.6	3.1	2.3	1.9	1.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.6	82.3	87.6	91.2	96.8	99.6	99.9	98.3	95.6	91.2	84.6	82.5
		MCWB	69.0	67.3	70.4	73.3	72.2	78.0	79.6	79.9	73.5	74.6	73.1	72.6
	2%	DB	75.3	79.3	83.7	88.3	93.1	97.1	97.3	95.9	92.6	88.2	81.5	78.0
		MCWB	65.8	66.3	68.7	70.9	72.6	78.1	79.1	79.7	75.9	73.6	69.9	68.5
	5%	DB	72.1	75.0	80.8	84.9	90.6	94.1	94.9	93.3	90.7	84.6	78.8	74.6
		MCWB	64.3	64.7	66.9	69.2	72.5	77.1	78.8	78.8	76.5	72.0	68.1	68.5
	10%	DB	68.2	71.7	76.9	82.0	88.2	91.3	92.7	91.2	88.4	82.1	74.9	71.7
		MCWB	62.7	63.2	64.6	67.6	72.1	76.5	78.2	78.5	76.1	70.9	66.9	67.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.5	71.6	73.5	76.3	78.4	82.4	83.5	83.5	81.9	79.1	77.5	75.2
		MCDB	75.1	77.0	80.7	85.5	87.4	92.9	92.8	93.1	87.5	86.1	81.1	78.4
	2%	WB	68.7	69.2	71.3	74.1	77.0	81.1	82.3	82.3	80.5	77.3	74.4	72.6
		MCDB	73.8	75.5	79.3	83.1	86.0	91.5	91.5	91.0	86.8	83.5	77.9	75.5
	5%	WB	66.3	66.9	69.5	72.3	75.6	79.9	81.3	81.4	79.2	75.7	71.2	69.8
		MCDB	70.5	73.1	76.8	80.8	84.6	90.2	90.4	89.5	85.7	81.1	76.0	73.1
	10%	WB	63.4	64.6	67.6	70.5	74.4	78.6	80.3	80.4	78.2	74.1	68.4	66.8
		MCDB	66.5	69.9	74.2	78.4	83.2	88.2	89.0	87.8	84.6	78.8	73.7	70.6
(35) Mean Daily Temperature Range	5% DB	MDBR	21.9	22.1	23.4	23.7	22.4	19.6	19.0	17.6	17.9	21.3	23.2	21.2
		MCDBR	24.0	24.7	25.6	25.7	24.8	22.7	21.5	19.9	20.1	21.8	24.0	22.0
		MCWBR	15.2	14.0	12.3	10.3	8.5	7.6	6.9	7.1	7.4	9.9	13.2	14.0
	5% WB	MCDBR	20.2	21.2	21.6	21.5	20.2	19.8	18.9	17.9	16.6	17.1	18.2	18.3
		MCWBR	14.9	13.9	12.2	10.4	8.3	7.9	7.4	7.3	7.2	8.7	11.9	13.3
(40) Clear-Sky Solar Irradiance	taub		0.328	0.335	0.376	0.390	0.432	0.478	0.513	0.502	0.428	0.382	0.349	0.336
	taud		2.517	2.500	2.403	2.359	2.276	2.209	2.114	2.147	2.349	2.445	2.487	2.523
	Ebn at Noon		285	294	287	286	273	259	250	251	267	273	275	277
	Edh at Noon		28	31	36	39	43	46	50	48	38	32	28	26
(44) All-Sky Solar Radiation	RadAvg		964	1156	1516	1853	2026	1930	1919	1748	1525	1335	1069	845
	RadStd		59	132	139	136	115	130	120	115	122	126	72	74

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (36 neighbors)	+0.88	N/A	N/A	N/A	N/A	N/A	N/A	-140	+302	+205

Nomenclature: See separate page