

SALLISAW, OK, USA

WMO: 722133

Lat: 35.438N

Lon: 94.803W

Elev: 528

StdP: 14.42

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 53946

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 17.9	(c) 21.1	(d) 5.1	(e) 7.3	(f) 22.3	(g) 9.9	(h) 9.3	(i) 28.3	(j) 23.5	(k) 42.7	(l) 20.3	(m) 45.7	(n) 4.3	(o) 340	(p) 0.412

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 21.7	(c) 99.5	(d) 74.5	(e) 97.1	(f) 75.0	(g) 94.6	(h) 74.9	(i) 78.4	(j) 91.6	(k) 77.6	(l) 90.9	(m) 76.6	(n) 89.4	(o) 5.9	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.0	133.9	83.7	73.3	126.0	82.8	72.7	123.6	82.4	42.5	90.0	41.3	91.5	40.2	89.4	83.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 18.9	(b) 16.6	(c) 14.2	(e) 7.0	(f) 102.7	(g) 5.5	(h) 4.5	(i) 3.0	(j) 106.0	(k) -0.2	(l) 108.6	(m) -3.3	(n) 111.1	(o) -7.4	(p) 114.4		
(a) 18.9	(b) 16.6	(c) 14.2	(e) 6.9	(f) 79.9	(g) 5.7	(h) 2.1	(i) 2.8	(j) 81.4	(k) -0.6	(l) 82.6	(m) -3.8	(n) 83.8	(o) -8.0	(p) 85.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.9	40.2	44.2	53.9	61.3	69.1	78.7	82.0	81.0	74.5	62.7	51.9	42.4		
	DBStd	16.79	9.93	10.32	9.59	8.26	7.49	4.57	4.83	5.45	6.75	9.09	9.47	9.11		
	HDD50	998	332	216	70	11	1	0	0	0	0	10	88	270		
	HDD65	3195	770	583	361	164	48	0	0	0	8	156	403	702		
	CDD50	5348	28	55	193	349	594	861	991	961	734	402	146	34		
	CDD65	2070	1	2	19	53	176	411	526	496	292	83	10	1		
	CDH74	22114	3	21	159	480	1543	4427	6198	5525	2864	760	131	3		
	CDH80	10487	0	4	25	96	494	2068	3324	2895	1278	240	63	0		
(14) Wind	WSAvg	5.4	5.8	6.4	7.2	7.0	5.2	4.7	4.1	4.0	4.1	4.8	5.7	5.9		
(15) Precipitation	PrecAvg	48.0	2.9	2.7	3.9	5.0	5.6	5.0	3.5	2.8	5.0	3.7	3.9	3.4		
	PrecMax	71.2	8.5	7.3	10.4	11.2	13.7	10.6	11.8	7.1	10.2	8.5	12.2	6.5		
	PrecMin	29.4	0.2	0.1	0.8	1.9	2.3	1.3	0.4	0.0	0.4	0.5	0.3	0.3		
	PrecStd	8.1	2.0	2.1	2.4	2.4	2.6	2.2	2.7	1.7	2.6	2.3	3.0	1.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.6	76.9	82.4	86.5	91.2	99.1	104.0	106.0	97.5	90.3	83.6	72.6		
		MCWB	58.6	61.7	64.0	67.6	72.7	74.9	73.6	74.2	73.8	70.8	67.5	61.0		
	2%	DB	68.2	71.7	78.9	82.1	88.4	95.3	99.6	99.6	93.4	86.3	75.3	67.9		
		MCWB	57.4	59.2	62.4	65.2	71.7	75.2	74.1	75.2	73.0	69.7	61.8	58.3		
	5%	DB	63.3	66.3	73.4	80.5	85.9	92.6	97.1	97.0	90.8	81.8	72.1	63.1		
		MCWB	54.5	55.6	60.1	64.3	70.6	74.7	74.9	75.2	72.4	66.8	60.7	54.3		
	10%	DB	57.0	62.7	71.5	76.5	81.9	90.4	94.5	92.8	88.3	78.7	67.9	58.6		
		MCWB	48.5	53.4	58.8	62.7	69.2	73.9	75.2	74.6	71.8	65.1	57.8	50.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	64.2	64.4	67.0	71.0	76.3	79.3	80.1	80.2	77.4	74.3	68.5	65.0		
		MCDB	67.9	73.2	79.8	81.7	87.3	93.9	90.6	92.4	90.5	85.6	78.0	70.5		
	2%	WB	59.8	61.8	65.0	68.5	74.1	77.5	78.5	78.4	76.0	72.3	65.0	60.4		
		MCDB	66.1	69.0	75.4	78.7	84.9	91.0	91.2	91.6	88.8	82.2	71.7	65.8		
	5%	WB	54.7	58.0	62.9	66.9	72.4	76.4	77.7	77.4	74.7	70.3	62.3	56.1		
		MCDB	62.1	64.8	71.6	76.2	82.4	89.1	90.9	90.7	87.0	78.0	69.1	61.3		
	10%	WB	49.4	53.9	60.5	65.3	71.0	75.1	76.6	76.2	73.3	67.7	59.4	51.9		
		MCDB	56.7	60.1	68.2	73.6	79.9	86.9	89.3	88.8	84.8	75.2	66.2	56.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	21.4	20.7	22.1	22.5	20.3	20.4	21.7	21.3	22.6	22.9	23.4	20.0		
		MCDBR	30.1	27.5	27.1	26.3	24.1	24.0	25.3	25.1	25.2	26.0	28.2	27.3		
		MCWBR	19.3	17.4	15.0	12.8	10.8	8.9	6.9	6.8	9.1	12.0	16.7	18.0		
	5% WB	MCDBR	25.2	23.3	22.1	21.2	20.0	20.5	21.2	21.4	22.0	19.9	23.4	21.7		
		MCWBR	18.2	16.8	13.5	12.3	10.2	8.7	8.3	8.0	8.9	10.2	17.3	17.5		
(40) Clear-Sky Solar Irradiance	taub		0.312	0.317	0.355	0.392	0.428	0.436	0.455	0.455	0.401	0.355	0.326	0.304		
	taud		2.483	2.484	2.406	2.312	2.272	2.279	2.268	2.243	2.361	2.470	2.502	2.520		
	Ebn at Noon		283	295	290	283	273	270	263	261	272	277	275	279		
	Edh at Noon		27	30	35	41	43	43	43	43	36	30	26	24		
(44) All-Sky Solar Radiation	RadAvg		803	957	1296	1612	1778	2021	2035	1858	1571	1185	863	689		
	RadStd		80	134	82	96	162	217	124	119	118	161	103	90		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (31 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page