

SALLISAW, OK, USA

WMO: 722133

Lat: 35.438N

Lon: 94.803W

Elev: 161

StdP: 99.41

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 53946

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.8	-6.1	-14.9	1.0	-5.4	-12.3	1.3	-2.0	10.5	5.9	9.1	7.6	1.9	340	0.412

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.1	37.5	23.6	36.2	23.9	34.8	23.8	25.8	33.1	25.3	32.7	24.8	31.9	2.6	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.9	19.1	28.7	22.9	18.0	28.2	22.6	17.7	28.0	81.0	32.2	78.2	33.0	75.5	31.9	28.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.4	7.4	6.3	-13.9	39.3	3.1	2.5	-16.1	41.1	-17.9	42.6	-19.6	44.0	-21.9	45.8		
			-14.0	26.6	3.2	1.2	-16.2	27.5	-18.1	28.1	-19.9	28.8	-22.2	29.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.6	4.5	6.8	12.2	16.3	20.6	25.9	27.8	27.2	23.6	17.0	11.1	5.8
	DBStd	9.33	5.52	5.73	5.33	4.59	4.16	2.54	2.68	3.03	3.75	5.05	5.26	5.06
	HDD10.0	554	184	120	39	6	1	0	0	0	0	6	49	150
	HDD18.3	1775	428	324	201	91	27	0	0	0	4	87	224	390
	CDD10.0	2971	16	31	107	194	330	478	551	534	408	223	81	19
	CDD18.3	1150	1	1	11	29	98	228	292	276	162	46	6	1
	CDH23.3	12286	2	12	88	267	857	2459	3443	3069	1591	422	73	2
	CDH26.7	5826	0	2	14	53	274	1149	1847	1608	710	133	35	0
Wind	WSAvg	2.4	2.6	2.9	3.2	3.1	2.3	2.1	1.8	1.8	1.8	2.2	2.6	2.6
Precipitation	PrecAvg	1219	73	68	100	127	141	126	90	72	128	93	98	86
	PrecMax	1808	215	185	263	285	348	268	299	181	258	216	310	165
	PrecMin	747	5	3	21	48	58	33	11	1	11	13	7	7
	PrecStd	205	50	53	61	60	67	57	69	43	65	58	75	43
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.6	24.9	28.0	30.3	32.9	37.3	40.0	41.1	36.4	32.4	28.7	22.6
		MCWB	14.8	16.5	17.8	19.8	22.6	23.8	23.1	23.5	23.2	21.5	19.7	16.1
	2%	DB	20.1	22.1	26.1	27.8	31.3	35.2	37.5	37.6	34.1	30.2	24.0	20.0
		MCWB	14.1	15.1	16.9	18.5	22.1	24.0	23.4	24.0	22.8	20.9	16.5	14.6
	5%	DB	17.4	19.0	23.0	27.0	29.9	33.7	36.2	36.1	32.7	27.7	22.3	17.3
		MCWB	12.5	13.1	15.6	17.9	21.4	23.7	23.8	24.0	22.5	19.3	15.9	12.4
	10%	DB	13.9	17.1	22.0	24.7	27.7	32.4	34.7	33.8	31.3	25.9	20.0	14.8
		MCWB	9.2	11.9	14.9	17.0	20.7	23.3	24.0	23.7	22.1	18.4	14.4	10.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.9	18.0	19.4	21.7	24.6	26.3	26.7	26.8	25.2	23.5	20.3	18.4
		MCDB	20.0	22.9	26.6	27.6	30.7	34.4	32.6	33.5	32.5	29.8	25.6	21.4
	2%	WB	15.5	16.5	18.3	20.3	23.4	25.3	25.8	25.8	24.4	22.4	18.3	15.8
		MCDB	18.9	20.6	24.1	26.0	29.4	32.8	32.9	33.1	31.6	27.9	22.0	18.8
	5%	WB	12.6	14.4	17.1	19.4	22.4	24.7	25.4	25.2	23.7	21.3	16.8	13.4
		MCDB	16.7	18.2	22.0	24.5	28.0	31.7	32.7	32.6	30.5	25.5	20.6	16.3
	10%	WB	9.7	12.2	15.8	18.5	21.7	24.0	24.8	24.6	23.0	19.8	15.2	11.1
		MCDB	13.7	15.6	20.1	23.1	26.6	30.5	31.8	31.6	29.3	24.0	19.0	13.5
Mean Daily Temperature Range	5% DB	MDBR	11.9	11.5	12.3	12.5	11.3	11.3	12.1	11.8	12.6	12.7	13.0	11.1
		MCDBR	16.7	15.3	15.0	14.6	13.4	13.3	14.1	13.9	14.0	14.4	15.6	15.2
		MCWBR	10.7	9.6	8.3	7.1	6.0	5.0	3.8	3.8	5.1	6.6	9.3	10.0
	5% WB	MCDBR	14.0	12.9	12.3	11.8	11.1	11.4	11.8	11.9	12.2	11.0	13.0	12.1
		MCWBR	10.1	9.3	7.5	6.8	5.6	4.9	4.6	4.4	4.9	5.7	9.6	9.7
Clear-Sky Solar Irradiance	taub	0.312	0.317	0.355	0.392	0.428	0.436	0.455	0.455	0.401	0.355	0.326	0.304	
	taud	2.483	2.484	2.406	2.312	2.272	2.279	2.268	2.243	2.361	2.470	2.502	2.520	
	Ebn at Noon	892	929	915	893	861	850	830	824	856	872	867	880	
	Edh at Noon	84	94	111	128	135	134	135	136	115	94	82	76	
All-Sky Solar Radiation	RadAvg	2.53	3.02	4.09	5.08	5.61	6.37	6.42	5.86	4.95	3.73	2.72	2.17	
	RadStd	0.25	0.42	0.26	0.30	0.51	0.68	0.39	0.37	0.37	0.51	0.32	0.28	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (31 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page