

VIDALIA, GA, USA

WMO: 722134

Lat: 32.193N

Lon: 82.372W

Elev: 84

StdP: 100.33

Time Zone: -5.00 (NAE)

Period: 01-19

WBAN: 63822

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.1	0.1	-12.2	1.3	4.8	-9.1	1.7	5.3	8.4	13.4	7.6	13.1	1.9	320	0.355

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.5	36.1	24.0	35.0	24.2	33.1	23.8	26.8	31.9	26.1	31.2	25.7	30.5	2.7	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.3	20.6	28.2	25.1	20.4	28.1	24.6	19.8	27.8	84.3	31.9	81.5	31.4	78.9	30.9	30.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.4	6.2	5.4	-4.3	37.4	1.9	2.0	-5.7	38.8	-6.8	40.0	-7.9	41.1	-9.3	42.5		
			-5.8	27.4	1.9	1.2	-7.2	28.3	-8.3	29.0	-9.3	29.6	-10.7	30.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.8	10.4	12.2	15.3	19.5	23.6	26.9	28.1	27.8	25.5	20.4	15.0	12.1
	DBStd	7.37	5.26	4.90	4.59	3.66	3.08	1.94	1.69	1.71	2.50	4.01	4.27	4.94
	HDD10.0	143	61	30	11	1	0	0	0	0	0	8	33	
	HDD18.3	923	251	179	114	29	3	0	0	1	26	117	202	
	CDD10.0	3711	72	91	175	287	423	507	561	553	464	322	157	99
	CDD18.3	1449	4	7	21	66	168	257	303	295	214	89	16	9
	CDH23.3	13469	20	49	167	613	1558	2479	3141	2841	1798	665	103	35
	CDH26.7	5691	1	5	23	165	631	1154	1506	1278	735	183	10	1
Wind	WSAvg	2.2	2.4	2.4	2.6	2.5	2.3	2.0	1.9	1.8	2.1	2.1	2.1	2.2
Precipitation	PrecAvg	1197	113	97	119	66	61	135	124	134	97	90	70	88
	PrecMax	1514	246	199	235	153	143	206	236	260	298	268	168	198
	PrecMin	888	33	29	9	29	8	31	50	58	2	10	14	27
	PrecStd	188	51	45	70	36	31	53	49	56	68	68	43	44
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.0	27.4	28.7	32.4	35.2	37.3	37.5	37.2	35.2	32.3	27.8	26.2
		MCWB	19.8	19.6	19.4	20.9	20.9	23.7	24.8	25.4	23.2	22.6	20.6	20.0
	2%	DB	22.8	25.0	27.3	30.2	32.9	35.2	36.1	35.2	33.0	30.2	26.2	24.1
		MCWB	18.3	17.6	18.4	19.8	21.2	23.5	24.2	25.5	23.3	21.8	18.8	18.7
	5%	DB	21.1	22.5	25.2	28.0	32.1	33.9	34.9	33.9	32.4	28.7	24.1	22.2
		MCWB	17.0	16.0	16.7	18.7	21.0	23.6	24.6	25.2	23.2	21.3	18.2	19.0
	10%	DB	18.0	20.9	22.9	27.2	30.2	32.5	32.9	32.6	31.1	27.3	22.5	20.1
		MCWB	15.2	15.9	16.0	18.1	20.8	23.3	24.4	24.8	23.2	20.2	17.7	17.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.9	20.7	21.3	23.0	24.5	26.6	27.3	28.0	26.5	25.5	23.3	21.9
		MCDB	23.2	24.0	25.5	28.5	30.1	33.1	32.3	33.7	30.1	28.5	26.1	24.3
	2%	WB	19.4	19.4	20.0	22.1	23.5	25.7	26.4	27.1	25.7	24.3	21.8	20.7
		MCDB	22.4	23.4	24.3	26.7	28.7	31.7	32.2	32.1	29.4	27.0	24.0	22.0
	5%	WB	17.9	18.0	18.8	21.1	22.9	25.2	25.8	26.3	25.1	23.1	20.5	19.5
		MCDB	19.7	20.8	23.2	25.4	27.9	30.8	31.5	31.0	29.0	26.2	22.5	21.6
	10%	WB	16.5	16.8	17.8	20.2	22.3	24.6	25.4	25.7	24.4	22.3	18.8	17.9
		MCDB	18.2	19.2	21.3	24.6	27.1	29.9	30.9	30.2	28.7	25.5	21.8	19.7
Mean Daily Temperature Range	5% DB	MDBR	11.0	11.5	12.0	12.4	11.7	10.6	10.5	9.9	10.3	11.5	12.1	10.8
		MCDBR	12.0	13.7	13.6	13.9	13.5	12.6	12.2	11.3	11.8	12.1	13.2	11.5
		MCWBR	7.7	7.8	6.2	5.3	4.1	3.7	3.4	3.5	3.7	4.9	7.0	7.3
	5% WB	MCDBR	10.4	11.3	11.2	11.2	10.6	10.5	10.5	10.0	9.2	9.0	9.5	10.1
	MCWBR	7.8	7.8	6.3	5.8	4.1	3.8	3.7	3.9	3.6	4.8	6.5	7.6	
Clear-Sky Solar Irradiance	taub	0.324	0.331	0.362	0.388	0.431	0.480	0.512	0.509	0.421	0.380	0.349	0.326	
	taud	2.508	2.484	2.427	2.347	2.261	2.188	2.107	2.111	2.349	2.431	2.467	2.531	
	Ebn at Noon	900	927	918	902	862	815	788	784	847	860	861	878	
	Edh at Noon	86	97	111	125	138	148	159	157	119	102	90	81	
All-Sky Solar Radiation	RadAvg	2.95	3.56	4.66	5.80	6.32	6.25	6.13	5.57	4.84	4.16	3.25	2.56	
	RadStd	0.16	0.36	0.39	0.40	0.41	0.45	0.36	0.31	0.41	0.43	0.24	0.24	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (36 neighbors)	+0.55	N/A	N/A	N/A	N/A	N/A	N/A	-90	+188	+130

Nomenclature: See separate page