

BRUNSWICK GOLDEN ISLES, GA, USA

WMO: 722136

Lat: 31.259N

Lon: 81.466W

Elev: 26

StdP: 14.68

Time Zone: -5.00 (NAE)

Period: 98-19

WBAN: 53883

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.2	31.9	17.2	13.1	39.7	21.1	15.8	41.3	20.5	60.0	18.7	58.7	2.0	290	0.380

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.6	96.2	78.3	93.3	78.1	91.3	77.9	82.1	90.1	81.1	88.7	80.2	87.3	7.5	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.5	158.7	85.6	79.2	151.9	84.1	78.7	149.2	83.8	45.6	91.0	44.6	88.3	43.5	87.7	98.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.7	16.6	14.7	DB	23.1	99.0	4.5	2.0	19.9	100.4	17.2	101.6	14.7	102.7	11.4	104.2	
			WB	21.8	84.2	4.2	3.9	18.8	87.0	16.4	89.3	14.1	91.5	11.0	94.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	68.2	52.1	55.1	60.5	67.2	74.6	80.6	82.7	81.9	78.0	69.7	60.2	54.8
	DBStd	12.84	9.63	8.63	8.12	6.89	5.54	3.79	3.01	3.09	4.16	6.99	7.84	8.92
	HDD50	212	93	41	13	1	0	0	0	0	0	0	11	53
	HDD65	1501	411	293	183	57	3	0	0	0	1	37	183	333
	CDD50	6853	157	185	339	518	762	918	1015	989	841	612	316	201
	CDD65	2665	10	16	44	124	300	468	550	524	392	183	38	16
	CDH74	25885	52	106	364	1035	2852	4881	6078	5481	3392	1334	236	74
	CDH80	9956	4	10	55	240	977	2061	2790	2318	1187	292	20	2
(14) Wind	WSAvg	5.8	5.7	5.9	6.7	6.8	6.5	5.7	5.3	5.2	5.6	5.2	5.1	5.3
(15) Precipitation	PrecAvg	49.9	3.0	3.2	3.7	2.6	2.8	6.7	5.1	6.7	6.1	5.9	1.7	2.6
	PrecMax	67.1	9.8	8.9	8.2	6.3	7.4	11.1	9.2	13.3	11.6	17.2	4.7	7.8
	PrecMin	32.4	0.0	1.0	0.2	0.6	0.6	1.4	2.0	2.0	2.4	0.8	0.0	0.8
	PrecStd	9.8	2.5	2.0	2.4	1.6	1.8	2.8	1.8	2.3	2.8	4.2	1.4	1.8
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.3	81.4	85.6	90.4	95.0	98.4	98.9	97.7	93.2	89.6	82.1	79.4
		MCWB	69.0	68.1	67.4	71.4	73.7	78.3	79.2	79.3	77.8	76.9	72.0	69.4
	2%	DB	73.4	77.4	81.3	85.9	91.2	95.1	96.2	94.7	90.5	86.0	79.4	76.5
		MCWB	65.7	66.0	67.2	69.7	73.2	77.8	79.0	79.2	77.0	74.8	70.0	68.6
	5%	DB	71.6	73.1	78.8	82.1	88.2	92.0	93.2	91.5	88.4	82.7	77.1	72.6
		MCWB	64.8	64.1	66.3	69.1	73.0	77.1	79.0	79.1	76.3	72.5	68.5	67.0
	10%	DB	67.6	70.1	74.7	80.6	85.7	90.0	91.0	90.2	86.4	81.1	73.2	69.7
		MCWB	62.1	62.8	64.5	68.3	72.7	77.2	78.9	79.1	75.8	72.0	66.4	65.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.2	70.9	73.2	75.9	78.3	82.2	83.4	83.9	81.4	80.5	75.9	72.4
		MCDB	75.8	76.6	78.3	83.0	87.8	91.9	93.0	92.3	86.8	84.0	79.2	76.2
	2%	WB	69.0	68.8	70.4	73.7	76.7	80.8	82.0	82.1	80.1	78.4	73.2	70.2
		MCDB	73.0	74.7	76.5	80.4	84.9	89.2	90.8	89.6	84.8	81.7	77.6	73.9
	5%	WB	66.1	66.4	68.6	72.4	75.5	79.7	81.0	81.1	78.9	76.4	70.9	68.1
		MCDB	70.3	72.4	75.4	78.7	83.3	87.5	89.4	88.1	83.8	80.7	74.9	71.7
	10%	WB	63.3	63.9	66.5	70.7	74.5	78.5	80.0	80.1	78.1	74.7	68.7	65.7
		MCDB	65.3	67.3	73.1	76.8	82.0	85.9	88.2	86.6	83.4	79.1	72.5	69.3
(35) Mean Daily Temperature Range	5% DB	MDBR	21.4	22.0	22.7	21.9	20.0	17.8	17.6	16.4	15.7	19.2	21.4	20.8
		MCDBR	23.6	24.3	24.6	22.9	22.4	20.7	19.7	18.4	18.3	19.4	21.8	22.1
		MCWBR	15.6	15.1	12.9	10.7	8.5	7.9	7.5	7.3	7.4	9.6	13.2	15.3
	5% WB	MCDBR	20.4	21.4	21.0	19.4	18.4	18.0	18.1	17.2	14.7	14.6	17.2	20.0
		MCWBR	14.9	14.8	13.3	10.8	8.2	7.8	8.0	8.0	7.1	8.5	11.9	15.4
(40) Clear-Sky Solar Irradiance	taub		0.336	0.344	0.378	0.400	0.442	0.492	0.515	0.502	0.429	0.397	0.359	0.349
	taud		2.525	2.504	2.427	2.359	2.273	2.190	2.135	2.176	2.380	2.431	2.492	2.511
	Ebn at Noon		283	291	287	283	271	256	249	251	267	269	272	272
	Edh at Noon		28	31	36	39	43	47	49	47	37	33	28	27
(44) All-Sky Solar Radiation	RadAvg		962	1153	1525	1890	2042	1955	1958	1777	1506	1326	1062	851
	RadStd		58	126	145	122	115	147	116	115	126	127	64	69

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) N/A	(e) +3.31	(f) N/A	(g) N/A	(h) N/A	(i) -1.78	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (30 neighbors)	+0.88	+1.37	N/A	N/A	N/A	N/A	N/A	-131	+301	+216

Nomenclature: See separate page