

BRUNSWICK GOLDEN ISLES, GA, USA

WMO: 722136

Lat: 31.259N

Lon: 81.466W

Elev: 8

StdP: 101.23

Time Zone: -5.00 (NAE)

Period: 98-19

WBAN: 53883

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -2.1	(c) -0.1	(d) -8.2	(e) 1.9	(f) 4.3	(g) -6.0	(h) 2.3	(i) 5.1	(j) 9.2	(k) 15.6	(l) 8.4	(m) 14.8	(n) 0.9	(o) 290	(p) 0.380

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.8	35.7	25.7	34.1	25.6	32.9	25.5	27.8	32.3	27.3	31.5	26.8	30.7	3.4	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.0	22.7	29.8	26.2	21.7	28.9	26.0	21.3	28.8	88.3	32.8	85.9	31.3	83.4	31.0	37.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.4	7.4	6.6	-4.9	37.2	2.5	1.1	-6.7	38.0	-8.2	38.7	-9.6	39.3	-11.4	40.1
			-5.7	29.0	2.3	2.2	-7.3	30.6	-8.7	31.8	-10.0	33.1	-11.6	34.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	20.1	11.1	12.8	15.9	19.6	23.6	27.0	28.2	27.7	25.6	21.0	15.6	12.7		
	DBStd	7.13	5.35	4.80	4.51	3.83	3.08	2.10	1.67	1.72	2.31	3.88	4.35	4.96		
	HDD10.0	118	52	23	7	1	0	0	0	0	0	0	6	29		
	HDD18.3	834	228	163	102	32	2	0	0	0	1	21	102	185		
	CDD10.0	3807	87	103	188	288	423	510	564	549	467	340	176	112		
	CDD18.3	1481	6	9	24	69	167	260	306	291	218	102	21	9		
	CDH23.3	14381	29	59	202	575	1584	2712	3377	3045	1884	741	131	41		
(14) Wind	WSAvg	2.6	2.5	2.7	3.0	3.1	2.9	2.5	2.4	2.3	2.5	2.3	2.3	2.4		
	PrecAvg	1267	75	81	94	65	71	171	129	170	154	150	42	66		
	PrecMax	1704	248	227	209	160	188	283	234	339	294	437	120	197		
	PrecMin	824	0	26	5	16	15	36	52	50	62	21	0	20		
	PrecStd	248	63	52	60	41	45	71	45	58	70	107	35	46		
	DB	26.3	27.5	29.8	32.4	35.0	36.9	37.2	36.5	34.0	32.0	27.8	26.3	20.8		
	MCWB	20.6	20.1	19.7	21.9	23.2	25.7	26.2	26.3	25.4	25.0	22.2	20.8	20.8		
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	23.0	25.2	27.4	30.0	32.9	35.0	35.7	34.8	32.5	30.0	26.3	24.7	21.0		
	2% MCWB	18.7	18.9	19.6	21.0	22.9	25.5	26.1	26.2	25.0	23.8	21.1	20.3	20.3		
	5% DB	22.0	22.8	26.0	27.8	31.2	33.3	34.0	33.0	31.4	28.2	25.0	22.5	20.3		
	5% MCWB	18.2	17.8	19.1	20.6	22.8	25.1	26.1	26.2	24.6	22.5	20.3	19.5	19.5		
	10% DB	19.8	21.2	23.7	27.0	29.8	32.2	32.8	32.3	30.2	27.3	22.9	21.0	21.0		
	10% MCWB	16.7	17.1	18.0	20.2	22.6	25.1	26.0	26.2	24.4	22.2	19.1	18.6	18.6		
	WB	21.8	21.6	22.9	24.4	25.7	27.9	28.6	28.9	27.4	26.9	24.4	22.4	22.4		
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% MCDB	24.3	24.8	25.7	28.3	31.0	33.3	33.9	33.5	30.5	28.9	26.2	24.6	24.6		
	2% WB	20.6	20.5	21.3	23.2	24.8	27.1	27.8	27.9	26.7	25.8	22.9	21.2	21.2		
	2% MCDB	22.8	23.7	24.7	26.9	29.4	31.8	32.7	32.0	29.3	27.6	25.4	23.3	23.3		
	5% WB	18.9	19.1	20.4	22.4	24.2	26.5	27.2	27.3	26.1	24.7	21.6	20.0	20.0		
	5% MCDB	21.3	22.5	24.1	26.0	28.5	30.9	31.9	31.2	28.8	27.1	23.8	22.1	22.1		
	10% WB	17.4	17.7	19.1	21.5	23.6	25.8	26.7	26.7	25.6	23.7	20.4	18.7	18.7		
	10% MCDB	18.5	19.6	22.8	24.9	27.8	29.9	31.2	30.3	28.6	26.2	22.5	20.7	20.7		
(35) Mean Daily Temperature Range	MDBR	11.9	12.2	12.6	12.1	11.1	9.9	9.8	9.1	8.7	10.7	11.9	11.5	11.5		
	5% DB MCDBR	13.1	13.5	13.6	12.7	12.5	11.5	10.9	10.2	10.1	10.8	12.1	12.3	12.3		
	5% DB MCWBR	8.7	8.4	7.2	5.9	4.7	4.4	4.2	4.1	4.1	5.3	7.3	8.5	8.5		
	5% WB MCDBR	11.3	11.9	11.7	10.8	10.2	10.0	10.1	9.5	8.2	8.1	9.6	11.1	11.1		
	5% WB MCWBR	8.3	8.2	7.4	6.0	4.5	4.3	4.4	4.4	3.9	4.7	6.6	8.5	8.5		
(40) Clear-Sky Solar Irradiance	taub	0.336	0.344	0.378	0.400	0.442	0.492	0.515	0.502	0.429	0.397	0.359	0.349	0.349		
	taud	2.525	2.504	2.427	2.359	2.273	2.190	2.135	2.176	2.380	2.431	2.492	2.511	2.511		
	Ebn at Noon	892	917	905	893	853	806	786	792	843	847	857	856	856		
	Edh at Noon	87	97	112	124	136	147	155	147	116	103	89	84	84		
(44) All-Sky Solar Radiation		RadAvg	3.03	3.63	4.81	5.96	6.44	6.16	6.17	5.60	4.75	4.18	3.35	2.68		
(45) RadStd		0.18	0.40	0.46	0.39	0.36	0.46	0.37	0.36	0.40	0.40	0.20	0.22	0.22		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	+1.84	N/A	N/A	N/A	-0.99	N/A	N/A	N/A	N/A
(47) Regional (30 neighbors)		+0.49	+0.76	N/A	N/A	N/A	N/A	N/A	-73	+167	+120

Nomenclature: See separate page