

HARBOR SPRINGS, MI, USA

WMO: 722145

Lat: 45.426N

Lon: 84.913W

Elev: 206

StdP: 98.87

Time Zone: -5.00 (NAE)

Period: 04-19

WBAN: 04884

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-19.4	-16.3	-23.1	0.5	-18.7	-20.2	0.6	-15.2	10.6	-2.2	9.2	-3.0	1.5	50	0.517

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	28.3	20.6	27.3	19.9	26.1	19.4	22.6	26.3	21.7	25.3	20.8	24.3	3.0	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.3	16.4	24.6	20.5	15.6	24.1	19.7	14.8	23.2	67.6	26.2	64.4	25.2	61.2	24.7	26.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.8	7.7	6.8	-23.5	32.2	4.3	0.8	-26.7	32.8	-29.2	33.3	-31.6	33.7	-34.7	34.3		
(5)			-23.8	24.3	4.2	1.1	-26.9	25.1	-29.3	25.7	-31.7	26.3	-34.8	27.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.3	-5.5	-5.8	-1.1	5.2	11.5	16.7	19.9	19.5	16.1	9.4	3.2	-2.2	(6)
(7)		DBStd	10.27	5.65	5.56	6.11	4.92	4.68	3.73	2.94	2.87	4.05	4.59	4.70	4.69	(7)
(8)		HDD10.0	2123	480	442	348	159	36	1	0	0	3	67	209	377	(8)
(9)		HDD18.3	4197	738	676	603	394	218	72	18	19	90	278	453	636	(9)
(10)		CDD10.0	1146	0	0	4	14	83	203	306	295	186	50	5	0	(10)
(11)		CDD18.3	179	0	0	0	0	7	24	66	56	23	3	0	0	(11)
(12)		CDH23.3	1142	0	0	2	3	64	173	419	328	137	16	0	0	(12)
(13)		CDH26.7	178	0	0	0	0	11	29	67	49	20	1	0	0	(13)
(14)	Wind	WSAvg	2.7	3.1	3.1	2.7	3.1	2.5	2.1	1.9	2.1	2.2	2.9	3.1	3.4	(14)
(15)	Precipitation	PrecAvg	797	56	39	41	58	74	81	69	83	90	91	71	60	(15)
(16)		PrecMax	931	105	61	137	103	133	178	127	152	166	199	130	104	(16)
(17)		PrecMin	665	16	9	1	20	17	23	36	20	29	29	28	7	(17)
(18)		PrecStd	76	23	15	29	24	28	40	26	35	30	44	28	25	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.0	9.0	20.4	23.0	27.9	30.1	31.3	30.9	29.0	25.9	18.9	12.3	(19)
(20)			MCWB	6.2	6.5	14.2	13.2	18.6	21.0	22.3	22.2	20.9	18.6	13.4	10.7	(20)
(21)		2%	DB	5.1	5.1	13.3	19.8	25.0	27.2	28.0	27.8	27.0	22.5	14.7	7.2	(21)
(22)			MCWB	3.4	3.0	9.4	11.9	17.5	19.3	20.6	20.7	20.0	17.5	10.9	5.5	(22)
(23)		5%	DB	3.0	2.8	10.1	16.1	22.2	25.4	27.2	26.6	24.8	19.9	12.3	5.0	(23)
(24)			MCWB	1.7	1.1	6.7	9.4	15.3	18.5	20.0	19.8	19.1	15.9	9.0	3.5	(24)
(25)		10%	DB	2.0	1.5	6.3	12.7	19.8	23.6	26.0	25.1	23.0	16.6	10.1	3.6	(25)
(26)			MCWB	0.9	0.1	3.1	7.5	14.5	17.8	19.6	19.5	18.4	13.1	7.7	2.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.8	7.0	13.7	15.5	20.5	22.7	24.0	23.4	22.7	20.9	14.0	10.8	(27)
(28)			MCDWB	7.7	8.9	18.9	20.8	26.1	27.5	28.6	27.2	26.2	24.0	17.8	11.9	(28)
(29)		2%	WB	3.6	3.2	9.8	12.5	18.8	20.8	22.5	22.5	21.5	18.6	11.4	5.7	(29)
(30)			MCDWB	5.0	4.8	12.8	17.9	23.2	25.0	26.2	26.1	24.6	21.1	14.1	6.8	(30)
(31)		5%	WB	2.0	1.4	6.4	10.1	16.9	19.8	21.7	21.6	20.4	15.7	9.5	3.8	(31)
(32)			MCDWB	3.0	2.6	10.4	15.3	21.2	23.9	25.2	25.0	23.7	19.1	12.0	4.8	(32)
(33)		10%	WB	0.8	0.2	3.6	8.0	14.7	18.8	20.7	20.6	19.1	13.6	7.8	2.5	(33)
(34)			MCDWB	1.7	1.3	6.0	12.1	18.5	22.3	24.3	23.8	22.4	16.5	9.7	3.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.3	7.5	9.0	9.6	10.9	10.2	9.9	9.6	10.1	8.2	6.4	5.3	(35)
(36)			MCDBR	6.4	7.9	12.2	15.2	14.6	12.8	11.6	11.1	11.6	11.9	10.2	7.1	(36)
(37)			MCWBR	5.5	6.7	8.4	8.9	8.1	6.7	6.0	6.0	6.4	7.6	7.2	6.4	(37)
(38)		5% WB	MCDBR	6.0	7.5	11.8	14.1	13.0	10.3	9.3	8.6	9.7	10.8	9.7	6.7	(38)
(39)			MCWBR	5.5	6.7	8.4	9.0	8.2	6.4	5.5	5.4	6.4	7.8	7.4	6.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.297	0.292	0.316	0.353	0.377	0.392	0.389	0.382	0.369	0.337	0.303	0.278	(40)	
(41)		taud	2.315	2.324	2.385	2.347	2.354	2.342	2.373	2.390	2.413	2.490	2.518	2.446	(41)	
(42)		Ebn at Noon	804	890	917	906	891	876	873	867	848	832	808	802	(42)	
(43)		Edh at Noon	78	94	102	117	120	122	117	111	100	80	65	62	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.16	2.09	3.54	4.63	5.65	6.14	6.18	5.25	4.01	2.34	1.24	0.85	(44)	
(45)		RadStd	0.13	0.21	0.37	0.47	0.48	0.44	0.23	0.32	0.34	0.27	0.18	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (40 neighbors)	-1.34	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page