

MOULTRIE, GA, USA

WMO: 722147

Lat: 31.083N

Lon: 83.800W

Elev: 283

StdP: 14.55

Time Zone: -5.00 (NAE)

Period: 04-19

WBAN: 53817

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 31.6	(c) 33.7	(d) 12.2	(e) 10.4	(f) 41.2	(g) 18.4	(h) 14.0	(i) 43.7	(j) 18.6	(k) 57.5	(l) 16.9	(m) 56.1	(n) 3.1	(o) 300	(p) 0.332

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.0	96.5	74.2	94.7	74.2	91.3	74.1	79.6	87.7	78.5	86.8	77.9	86.4	5.3	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.4	143.9	82.3	77.0	141.9	82.1	75.3	134.1	81.3	43.3	86.5	42.1	85.8	41.4	86.6	83.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 15.6	(b) 12.7	(c) 11.0	(e) 26.7	(f) 97.8	(g) 3.0	(h) 2.2	(i) 24.6	(j) 99.4	(k) 22.8	(l) 100.7	(m) 21.1	(n) 101.9	(o) 18.9	(p) 103.6		
(a) 15.6	(b) 12.7	(c) 11.0	(e) 23.5	(f) 80.7	(g) 2.7	(h) 1.7	(i) 21.6	(j) 82.0	(k) 20.0	(l) 83.0	(m) 18.6	(n) 84.0	(o) 16.6	(p) 85.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	68.5	52.6	55.6	60.7	67.6	75.0	81.0	82.4	82.3	78.8	70.1	59.7	55.4
	DBStd	12.73	9.48	8.75	7.95	6.16	5.08	3.34	2.83	2.94	3.73	7.18	7.80	8.99
	HDD50	200	84	41	14	1	0	0	0	0	0	1	13	46
	HDD65	1445	395	277	177	43	4	0	0	0	0	38	193	318
	CDD50	6953	165	199	345	528	776	930	1005	1001	863	623	304	214
	CDD65	2725	11	15	44	121	315	480	540	536	413	195	34	21
	CDH74	25344	40	87	341	1083	2900	4759	5510	5263	3605	1474	214	68
	CDH80	10545	0	5	48	275	1167	2217	2567	2346	1487	408	24	1
(14) Wind	WSAvg	3.9	4.5	4.5	4.8	4.6	4.1	3.5	3.1	3.0	3.4	3.6	3.8	4.2
(15) Precipitation	PrecAvg	50.9	4.9	3.9	5.6	3.0	2.5	5.8	6.1	4.8	4.9	3.1	2.6	3.5
	PrecMax	71.5	17.2	6.3	10.8	6.1	6.4	11.9	10.9	10.1	14.7	10.3	7.7	6.0
	PrecMin	35.5	0.6	0.6	0.2	0.7	0.2	1.9	3.6	2.4	0.6	0.6	0.1	0.9
	PrecStd	9.9	3.5	1.8	3.6	1.5	1.4	2.7	2.1	1.9	4.2	2.4	1.9	1.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.6	80.9	84.2	89.7	95.1	98.9	97.5	98.5	95.2	90.3	82.3	79.2
		MCWB	66.7	66.2	64.9	66.7	70.4	73.4	74.4	76.1	73.5	71.2	68.4	67.9
	2%	DB	73.4	77.0	81.2	86.2	91.1	95.4	95.3	95.1	91.3	87.7	79.3	76.6
		MCWB	64.9	64.0	64.4	66.4	69.0	73.4	74.8	75.8	72.9	71.0	66.5	66.9
	5%	DB	71.7	72.8	78.6	82.3	89.8	93.0	93.2	92.7	90.3	84.4	76.7	72.6
		MCWB	64.3	62.9	63.7	65.5	68.9	73.3	75.0	75.6	72.9	70.1	65.5	66.6
	10%	DB	67.9	70.1	73.4	80.9	86.5	90.6	90.9	90.5	88.3	81.6	72.7	70.1
		MCWB	62.4	61.8	61.9	64.8	69.2	73.3	75.5	75.7	73.1	68.7	63.6	65.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.9	69.7	70.5	73.2	75.4	79.5	80.5	81.4	78.4	77.5	73.9	71.8
		MCDB	73.2	74.4	75.7	80.2	83.3	87.9	89.2	89.6	84.8	84.7	79.8	75.6
	2%	WB	67.3	67.7	68.8	71.3	74.2	78.1	79.3	80.1	77.4	75.6	71.6	70.1
		MCDB	72.1	73.8	74.1	79.0	82.4	87.5	87.9	88.0	85.5	81.9	75.7	72.7
	5%	WB	65.4	66.0	66.9	69.9	73.1	77.2	78.3	78.8	76.4	74.0	69.2	68.4
		MCDB	70.0	71.8	73.8	76.6	81.6	86.9	87.2	86.6	84.7	80.2	72.5	71.4
	10%	WB	63.1	63.5	65.2	68.1	72.1	76.2	77.6	78.1	75.4	72.4	66.1	65.6
		MCDB	66.1	66.8	72.1	75.8	80.9	85.6	86.7	85.9	83.7	78.5	71.9	69.9
(35) Mean Daily Temperature Range	5% DB	MDBR	19.0	20.1	21.2	21.5	20.6	18.4	18.0	17.2	17.9	20.1	21.2	18.6
		MCDBR	20.1	22.3	23.9	24.2	23.6	21.5	20.0	19.4	20.8	21.0	22.9	19.3
		MCWBR	12.1	12.8	10.3	8.7	6.7	5.8	5.7	5.6	6.5	8.3	11.6	12.3
	5% WB	MCDBR	17.6	18.7	19.1	19.2	17.9	17.6	17.5	16.7	16.6	15.9	16.3	16.8
		MCWBR	12.3	13.2	11.2	11.1	6.5	6.4	6.4	6.3	6.2	7.5	11.3	12.8
(40) Clear-Sky Solar Irradiance	taub		0.325	0.332	0.355	0.388	0.429	0.480	0.511	0.497	0.428	0.374	0.348	0.331
	taud		2.513	2.491	2.444	2.347	2.266	2.184	2.106	2.146	2.326	2.453	2.469	2.520
	Ebn at Noon		287	295	294	287	274	259	250	252	267	277	276	279
	Edh at Noon		28	31	35	40	43	47	51	48	39	32	29	26
(44) All-Sky Solar Radiation	RadAvg		974	1159	1533	1873	2053	1922	1914	1739	1569	1372	1087	851
	RadStd		64	135	128	145	134	134	114	115	130	127	81	79

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (29 neighbors)	+0.83	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+288	+184

Nomenclature: See separate page