

MOULTRIE, GA, USA

WMO: 722147

Lat: 31.083N

Lon: 83.800W

Elev: 86

StdP: 100.29

Time Zone: -5.00 (NAE)

Period: 04-19

WBAN: 53817

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -0.2	(c) 0.9	(d) -11.0	(e) 1.5	(f) 5.1	(g) -7.6	(h) 2.0	(i) 6.5	(j) 8.3	(k) 14.2	(l) 7.5	(m) 13.4	(n) 1.4	(o) 300	(p) 0.332

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.0	35.9	23.4	34.8	23.5	33.0	23.4	26.4	30.9	25.8	30.4	25.5	30.2	2.4	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.2	20.6	28.0	25.0	20.3	27.9	24.1	19.2	27.4	82.8	30.3	80.0	29.9	78.4	30.3	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.0	5.7	4.9	-2.9	36.5	1.7	1.2	-4.1	37.4	-5.1	38.2	-6.0	38.9	-7.3	39.8
			-4.7	27.1	1.5	1.0	-5.8	27.8	-6.6	28.3	-7.5	28.9	-8.5	29.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	20.3	11.5	13.1	15.9	19.8	23.9	27.2	28.0	27.9	26.0	21.2	15.4	13.0		
	DBStd	7.07	5.27	4.86	4.42	3.42	2.82	1.85	1.57	1.63	2.07	3.99	4.33	4.99		
	HDD10.0	111	47	23	8	1	0	0	0	0	0	1	7	26		
	HDD18.3	803	219	154	98	24	2	0	0	0	0	21	107	177		
	CDD10.0	3863	92	111	192	293	431	517	558	556	479	346	169	119		
	CDD18.3	1514	6	8	24	67	175	267	300	298	229	108	19	12		
	CDH23.3	14080	22	48	189	602	1611	2644	3061	2924	2003	819	119	38		
	CDH26.7	5858	0	3	27	153	648	1232	1426	1303	826	227	13	1		
(14) Wind	WSAvg	1.8	2.0	2.0	2.1	2.1	1.8	1.5	1.4	1.3	1.5	1.6	1.7	1.9		
(15) Precipitation	PrecAvg	1293	124	99	142	75	64	148	155	123	125	80	67	88		
	PrecMax	1816	436	159	275	156	162	301	276	257	373	261	196	153		
	PrecMin	902	14	15	4	19	6	47	92	62	14	15	3	23		
	PrecStd	252	88	45	91	39	35	68	54	48	106	60	48	34		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.9	27.2	29.0	32.0	35.0	37.2	36.4	37.0	35.1	32.4	27.9	26.2		
		MCWB	19.3	19.0	18.3	19.3	21.4	23.0	23.5	24.5	23.0	21.8	20.2	19.9		
	2%	DB	23.0	25.0	27.3	30.1	32.8	35.2	35.2	35.1	33.0	30.9	26.3	24.8		
		MCWB	18.3	17.8	18.0	19.1	20.5	23.0	23.8	24.3	22.7	21.7	19.2	19.4		
	5%	DB	22.0	22.6	25.9	27.9	32.1	33.9	34.0	33.7	32.4	29.1	24.9	22.6		
		MCWB	17.9	17.2	17.6	18.6	20.5	22.9	23.9	24.2	22.7	21.1	18.6	19.2		
	10%	DB	19.9	21.2	23.0	27.2	30.3	32.5	32.7	32.5	31.3	27.6	22.6	21.1		
		MCWB	16.9	16.6	16.6	18.2	20.6	22.9	24.2	24.3	22.8	20.4	17.6	18.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.1	21.0	21.4	22.9	24.1	26.4	26.9	27.5	25.8	25.3	23.3	22.1		
		MCDB	22.9	23.6	24.3	26.8	28.5	31.1	31.8	32.0	29.3	29.3	26.6	24.2		
	2%	WB	19.6	19.8	20.4	21.8	23.4	25.6	26.3	26.7	25.2	24.2	22.0	21.1		
		MCDB	22.3	23.2	23.4	26.1	28.0	30.8	31.1	31.1	29.7	27.7	24.3	22.6		
	5%	WB	18.6	18.9	19.4	21.1	22.9	25.1	25.7	26.0	24.7	23.3	20.7	20.2		
		MCDB	21.1	22.1	23.2	24.8	27.5	30.5	30.7	30.4	29.3	26.8	22.5	21.9		
	10%	WB	17.3	17.5	18.4	20.1	22.3	24.6	25.3	25.6	24.1	22.5	19.0	18.6		
		MCDB	18.9	19.3	22.3	24.3	27.1	29.8	30.4	29.9	28.7	25.8	22.1	21.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.6	11.2	11.8	12.0	11.5	10.2	10.0	9.5	10.0	11.2	11.8	10.4		
		MCDBR	11.1	12.4	13.3	13.4	13.1	12.0	11.1	10.8	11.5	11.7	12.7	10.7		
	5% WB	MCWBR	6.7	7.1	5.7	4.8	3.7	3.2	3.2	3.1	3.6	4.6	6.4	6.8		
		MCWBR	9.8	10.4	10.6	10.7	9.9	9.8	9.7	9.3	9.2	8.8	9.1	9.4		
(40) Clear-Sky Solar Irradiance	taub		0.325	0.332	0.355	0.388	0.429	0.480	0.511	0.497	0.428	0.374	0.348	0.331		
		taud	2.513	2.491	2.444	2.347	2.266	2.184	2.106	2.146	2.326	2.453	2.469	2.520		
	Ebn at Noon		905	931	928	904	864	816	789	796	843	872	869	879		
		Edh at Noon	87	98	110	126	137	148	160	152	122	100	91	83		
(44) All-Sky Solar Radiation	RadAvg		3.07	3.65	4.83	5.90	6.47	6.06	6.03	5.48	4.95	4.33	3.43	2.68		
	RadStd		0.20	0.42	0.40	0.46	0.42	0.42	0.36	0.36	0.41	0.40	0.26	0.25		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (29 neighbors)		+0.46	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+160	+102		

Nomenclature: See separate page