

DALTON, GA, USA

WMO: 722154

Lat: 34.722N

Lon: 84.869W

Elev: 710

StdP: 14.32

Time Zone: -5.00 (NAE)

Period: 99-19

WBAN: 53885

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 19.0	(c) 22.9	(d) 8.6	(e) 8.8	(f) 28.0	(g) 11.5	(h) 10.2	(i) 29.4	(j) 20.2	(k) 33.9	(l) 18.5	(m) 35.7	(n) 5.8	(o) 340	(p) 0.366

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 20.7	(c) 93.1	(d) 75.3	(e) 90.9	(f) 75.0	(g) 90.0	(h) 74.7	(i) 79.8	(j) 87.6	(k) 77.9	(l) 86.8	(m) 76.7	(n) 85.6	(o) 4.5	(p) 350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.4	146.2	83.2	75.1	135.5	82.2	73.3	127.2	79.8	43.9	88.5	41.7	86.9	40.4	86.4	90.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
16.9	15.0	12.4	DB	13.1	95.3	4.3	3.0	10.0	97.5	7.5	99.2	5.2	100.9	2.1	103.0	
			WB	12.2	81.0	4.4	3.4	9.1	83.5	6.6	85.5	4.1	87.4	0.9	89.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	60.5	40.3	44.7	51.9	60.8	68.0	75.7	78.1	78.1	71.8	60.8	50.6	43.6	(6)
	DBStd	15.21	9.90	9.03	8.61	7.51	6.46	4.06	3.54	3.63	5.51	8.10	8.22	8.59	(7)
	HDD50	953	331	193	81	8	0	0	0	0	12	89	239		(8)
	HDD65	3245	765	569	410	165	47	0	0	13	176	437	663		(9)
	CDD50	4773	31	46	141	333	560	770	870	871	655	348	107	41	(10)
	CDD65	1588	0	1	5	40	141	320	405	406	218	47	4	1	(11)
	CDH74	14175	0	8	67	451	1280	2793	3590	3737	1795	425	29	0	(12)
	CDH80	5580	0	0	4	80	373	1120	1559	1696	650	95	3	0	(13)
(14) Wind	WSAvg	3.9	5.4	5.3	5.3	4.5	3.4	2.7	2.4	2.6	3.0	3.5	4.2	4.7	(14)
(15) Precipitation	PrecAvg	56.3	5.3	5.2	5.7	4.5	4.2	5.0	5.2	3.9	4.3	3.1	4.9	4.9	(15)
	PrecMax	71.3	10.2	12.5	10.6	9.6	13.2	7.4	9.4	6.3	8.5	7.6	10.0	8.3	(16)
	PrecMin	33.8	2.6	1.9	2.5	1.9	0.6	1.3	1.5	0.9	1.0	0.2	2.7	2.0	(17)
	PrecStd	9.6	1.9	2.5	2.3	1.9	2.6	1.8	2.2	1.3	2.0	2.2	1.9	1.8	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	69.6	74.6	80.6	86.1	90.4	94.9	95.2	97.2	93.0	88.0	78.8	70.3	(19)
		MCWB	60.9	63.6	63.3	68.7	74.4	78.1	76.8	73.1	69.4	72.1	64.7	62.7	(20)
	2%	DB	64.0	68.4	75.1	81.9	87.7	91.0	92.5	93.2	90.1	81.8	72.3	65.5	(21)
		MCWB	58.2	59.6	61.3	66.3	72.3	76.0	76.8	74.7	70.9	68.1	61.9	61.6	(22)
	5%	DB	61.1	63.8	71.9	79.3	84.0	89.8	90.4	90.9	87.6	79.1	69.6	62.0	(23)
		MCWB	56.3	56.4	59.6	64.1	70.1	75.2	76.3	74.5	72.0	66.0	60.6	57.0	(24)
	10%	DB	55.4	60.9	67.7	76.5	81.4	86.5	88.4	89.7	83.7	74.8	64.2	58.6	(25)
		MCWB	51.3	53.1	57.1	63.6	68.5	73.7	75.5	74.4	70.8	64.4	57.6	54.2	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	63.2	65.3	66.3	72.8	78.2	83.1	84.5	80.8	77.0	73.9	69.9	66.8	(27)
		MCDB	65.4	71.7	74.6	81.8	87.7	90.6	89.8	88.4	86.1	82.4	73.3	68.1	(28)
	2%	WB	60.4	62.5	64.0	69.3	73.7	78.9	79.9	78.5	75.2	71.5	66.0	62.6	(29)
		MCDB	63.4	66.5	70.3	77.9	82.4	87.0	87.1	87.9	83.3	78.3	70.0	64.2	(30)
	5%	WB	57.3	59.0	62.0	67.2	71.9	77.1	77.9	77.2	73.8	69.4	63.0	58.7	(31)
		MCDB	60.9	63.2	67.9	75.8	80.7	85.8	86.2	87.0	81.5	74.7	65.7	60.8	(32)
	10%	WB	53.5	54.6	59.7	65.0	70.4	75.4	76.6	76.0	72.4	67.2	60.0	54.6	(33)
		MCDB	56.1	58.5	66.0	72.6	78.2	83.5	85.3	85.1	79.4	72.9	63.7	57.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	18.4	19.6	21.3	23.3	21.5	20.4	19.6	20.7	21.0	23.0	22.0	17.7	(35)
		MCDBR	21.6	25.5	27.3	27.3	25.5	24.0	22.6	24.1	26.0	27.0	26.6	21.1	(36)
	5% WB	MCWBR	15.6	17.1	14.6	13.6	11.9	10.8	9.7	9.4	10.2	13.8	16.2	15.2	(37)
		MCWBR	18.1	20.5	21.5	22.5	21.2	20.5	20.3	20.5	19.4	20.9	18.9	16.0	(38)
(40) Clear-Sky Solar Irradiance	taub		0.318	0.322	0.357	0.403	0.461	0.492	0.539	0.538	0.430	0.375	0.343	0.317	(40)
		taud	2.503	2.487	2.417	2.280	2.152	2.102	1.989	1.976	2.263	2.413	2.446	2.528	(41)
	Ebn at Noon		282	294	290	280	264	255	242	239	263	271	270	276	(42)
		Edh at Noon	26	30	35	42	48	51	56	56	40	32	28	24	(43)
(44) All-Sky Solar Radiation	RadAvg		788	958	1316	1689	1868	1962	1857	1738	1492	1227	894	668	(44)
	RadStd		57	124	115	108	144	144	130	95	141	153	102	69	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (38 neighbors)	+0.88	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+261	+184

Nomenclature: See separate page